

Gas Service/Breakdown Record

Certificate Ref.

5 Atkins Croft 2025

Certificate No 5 Atkins Croft 2025

Installation DetailsInstallation
Address:Surinder Sharma
5 Adkins Croft
Fillongley

Postcode: CV7 8PA

Client DetailsClient
Address:Surinder Sharma
5 Adkins Croft
Fillongley

Postcode: CV7 8PA

Appliance DetailsCO/CO2
Ratio:

0.0005

Service:

YES

Breakdown:

N/A

CO2

Reading:

9.5 %

CO Reading:

47 ppm

Boiler Make:

Baxi

Boiler Model:

825 Heat

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks**Satisfactory**

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution	YES		
Ventilation Size/H-L	YES		
Water/Fuel - Sound	YES		
Electrically Fused	YES		
Correct Valving Arrangement	YES		
Isolation Available - Electrical/Fuel (Within 1 metre)	YES		
Boiler/Plant room Clean & Clear	YES		

Service Checks**Satisfactory**

Heat Exchanger	YES		
Ignition	YES		
Gas Valve	YES		
Fan	YES		
Safety Device	YES		
Control Box	YES		
Burner & Pilot	YES		
Fuel Pressure & Type	YES		

Service Operations**Satisfactory**

Burner Washed & Clean			
Pilot Assembly Cleaned & Adjusted			
Ignition System Cleaned & Adjusted			
Burner Fan & Airways Cleaned			
Heat Exchanger/Flueways Clean & Clear			NA
Fuel & Electrical Supply Connected & Sound	YES		
Interlocks in Place			

Additional Notes

cleaned filter and condense trap

Spares Required

none

Engineers Details

Trading Title:

Coventry Gas Services Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

927997

Time of
Arrival:

09:50 am

Gas ID Number

5739462

Time of

Departure:

09:50 am

Telephone Number

07961768920

Report Issued By

Name:

Andrew King-Page

Signature:



Date:

Mon-20-Jan-2025

Report Received By

Name:

Signature:

Date:

Mon-20-Jan-2025