

Gas Service/Breakdown Record

Certificate Ref.

6 Hampton Way 2025

Certificate No 6 Hampton Way 2025

Installation DetailsInstallation Address: Ciaran Whyte
6 Hampdon Way
Wellesbourne

Postcode: CV35 9NX

Client DetailsClient Address: Ciaran Whyte
6 Hampdon Way
Wellesbourne

Postcode: CV35 9NX

Appliance DetailsCO/CO2
Ratio:

0.0008

Service:

YES

Breakdown:

N/A

CO2

Reading:

9.0 %

CO Reading:

67 ppm

Boiler Make: Worcester

Boiler Model:

Greenstar 32CDi Comp

Boiler Serial No:

Appliance Make:

Appliance Model:

Appliance Serial No:

Preliminary Checks**Satisfactory**

YES

NO

NA

Flue:Atmospheric/Fan assisted/Fan Dilution

YES

Ventilation Size/H-L

YES

Water/Fuel - Sound

YES

Electrically Fused

YES

Correct Valving Arrangement

YES

Isolation Available - Electrical/Fuel (Within 1 metre)

YES

Boiler/Plant room Clean & Clear

YES

Service Checks**Satisfactory**

Heat Exchanger

YES

Ignition

YES

Gas Valve

YES

Fan

YES

Safety Device

YES

Control Box

YES

Burner & Pilot

YES

Fuel Pressure & Type

YES

Service Operations**Satisfactory**

Burner Washed & Clean

Pilot Assembly Cleaned & Adjusted

Ignition System Cleaned & Adjusted

Burner Fan & Airways Cleaned

Heat Exchanger/Flueways Clean & Clear

NA

Fuel & Electrical Supply Connected & Sound

YES

Interlocks in Place

Additional Notes

cleaned condense trap and filter

Spares Required

none

Engineers Details

Trading Title:

Coventry Gas Services Ltd
47 Alspath Road
Meriden

Postcode: CV7 7LU

Gas Safe Number

927997

Time of
Arrival:

09:55 am

Gas ID Number

5739462

Time of

Departure:

09:55 am

Telephone Number

07961768920

Report Issued By

Name: Andrew King-Page

Signature:



Date:

Mon-13-Jan-2025

Report Received By

Name:

Signature:

Date:

Mon-13-Jan-2025