



# Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

12 Kent Close CV3 5HT

Certificate No: 12 Kent Close CV3 5HT

## Engineers Details

Trading Title: Coventry Gas Ltd

Address: 47 Alspath Road  
Meriden  
Post Code: CV7 7LU

Gas Safe No: 927997 Telephone No: 07961768920

## Installation Details

Installation Address: 12 Kent Close CV3 5HT  
12 Kent Close CV3 5HT  
12 Kent Close CV3 5HT  
12 Kent Close CV3 5HT  
Post Code:

Telephone No:

## Client Details

Client Address: Citizen Housing Group Ltd  
Lakeside  
4040 Solihull Pkwy,  
Birmingham  
Post Code: B37 7YN

Telephone No:

## Appliance Details

## Inspection Details

|   | Location        | Appliance Type | Make      | Model      | CO2 Reading (%) | CO Reading (ppm) | Flue Type (OF/RS/FL) | Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only) | Combustion Analysis Reading (CO/CO2) | Landlords Appliance (YES/NO/NA) | Operating Pressure(mbar) or Heat Input(kW) | Safety Device(s) Correct Operation (YES/NO/NA) | Ventilation Provision Satisfactory (YES/NO) | Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA) | Flue Performance Test (PASS/FAIL/NA) | Appliance Serviced (YES/NO/NA) | Appliance Safe To Use (YES/NO) |
|---|-----------------|----------------|-----------|------------|-----------------|------------------|----------------------|------------------------------------------------------------------|--------------------------------------|---------------------------------|--------------------------------------------|------------------------------------------------|---------------------------------------------|-------------------------------------------------------------------|--------------------------------------|--------------------------------|--------------------------------|
| 1 | Airing Cupboard | Combi Boiler   | Worcester | 28i Junior | 9.9             | 90               | RS                   | YES                                                              | 0.0009                               | YES                             | 28.38 kw                                   | YES                                            | YES                                         | YES                                                               | N/A                                  | NO                             | YES                            |
| 2 | Kitchen         | Cooker         | Kenwood   | Unknown    | NA              | NA               | FL                   | YES                                                              | NA                                   | YES                             | 18 mb                                      | YES                                            | YES                                         | NA                                                                | N/A                                  | NO                             | YES                            |
| 3 |                 |                |           |            |                 |                  |                      |                                                                  |                                      |                                 |                                            |                                                |                                             |                                                                   |                                      |                                |                                |
| 4 |                 |                |           |            |                 |                  |                      |                                                                  |                                      |                                 |                                            |                                                |                                             |                                                                   |                                      |                                |                                |
| 5 |                 |                |           |            |                 |                  |                      |                                                                  |                                      |                                 |                                            |                                                |                                             |                                                                   |                                      |                                |                                |

## Faults/Notes

## Remedial Work Taken

## Warning Notice Fixed

|   |  |  |
|---|--|--|
| 1 |  |  |
| 2 |  |  |
| 3 |  |  |
| 4 |  |  |
| 5 |  |  |

Emergency Control Valve Accessible: YES Gas Tightness Satisfactory: YES

Gas Installation Pipework Visual Inspection Satisfactory: YES

Number of Appliances Tested: 2 Equipotential Bonding: YES

NEXT INSPECTION DUE ON OR BEFORE: Fri-28-Aug-2026 Installation Pass: YES

CO Alarm fitted & working? NA Smoke alarm fitted & working? NA

## Signatures

Report Issued By:

Name: Andrew King-Page

Report Received By:

Name:

Gas ID Number: 5924929

Signed:

Date: Thu-28-Aug-2025

Signed:

Date: Thu-28-Aug-2025