



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

188 Emscote Road 2025

Certificate No: 188 Emscote Road 2025

Engineers Details

Trading Title
Coventry Gas Services Ltd

Address
47 Alspath Road
Meriden

Post Code: CV7 7LU

Gas Safe No: 927997

Telephone No: 07961768920

Installation Details

Installation Address
The Tenant
188 Emscote Road
Warwick

Post Code: CV34 5QN

Telephone No: 07971666080

Client Details

Client Address
Stuart Cole
43 Beechhill Road
Sutton Coldfield

Post Code: B72 1BY

Telephone No: 07384007177

Appliance Details

Inspection Details

	Location	Appliance Type	Make	Model	CO2 Reading (%)	CO Reading (ppm)	Flue Type (OF/RS/FL)	Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure(mbar) or Heat Input(kW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1	Lounge	Fire	Morso	1480 Gas Stove	NA	NA	OF	YES	NA	YES	NA mb	NA	YES	YES	N/A	NA	NA
2	Kitchen	Cooker	Beiling	Country range 100df	NA	NA	FL	YES	NA	YES	22 mb	YES	YES	NA	N/A	NO	YES
3	Utility	Combi Boiler	Worcester	Greenstar 25i	9.6	72	RS	YES	0.0007	YES	24.75 kw	YES	YES	YES	N/A	YES	YES
4																	
5																	

Faults/Notes

Remedial Work Taken

Warning Notice Fixed

1		
2		
3		
4		
5		

Emergency Control Valve Accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

YES

Number of Appliances Tested:

3

Equipotential Bonding:

YES

NEXT INSPECTION DUE ON OR BEFORE:

Sat-13-Jun-2026

Installation Pass:

YES

CO Alarm fitted & working?

YES

Smoke alarm fitted & working?

YES

Signatures

Report Issued By:

Name: Andrew King-Page

Signed:

Date: Thu-05-Jun-2025

Report Received By:

Name:

Signed:

Date: Thu-05-Jun-2025

Gas ID Number: 5739462