



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

Flat 8 34 Newbold 2025

Certificate No: Flat 8 34 Newbold 2025

Engineers Details

Trading Title:

Address:

Gas Safe No: Telephone No:

Installation Details

Installation Address:

Telephone No:

Client Details

Client Address:

Telephone No:

Appliance Details

Inspection Details

	Location	Appliance Type	Make	Model	CO2 Reading (%)	CO Reading (ppm)	Flue Type (OF/RS/FL)	Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure(mbar) or Heat Input(kW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1	Kitchen	Hob	Stoves	Newhome	NA	NA	FL	YES	NA	YES	19 mb	NA	YES	NA	N/A	NO	YES
2	Kitchen	Combi Boiler	Worcester	Greenstar 24i system	9.9	100	RS	YES	0.0010	YES	23.17 kw	YES	YES	YES	N/A	NO	YES
3																	
4																	
5																	

Faults/Notes

Remedial Work Taken

Warning Notice Fixed

1		
2		
3		
4		
5		

Emergency Control Valve Accessible: Gas Tightness Satisfactory:

Gas Installation Pipework Visual Inspection Satisfactory:

Number of Appliances Tested: Equipotential Bonding:

NEXT INSPECTION DUE ON OR BEFORE: Installation Pass:

CO Alarm fitted & working? Smoke alarm fitted & working?

Signatures

Report Issued By:

Name:

Report Received By:

Name:

Gas ID Number:

Signed:

Date:

Signed: _____

Date: