



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

43 Bromhurst Way 2025

Certificate No: 43 Bromhurst Way 2025

Engineers Details

Trading Title: Coventry Gas Services Ltd
Address: 47 Alspath Road, Meriden
Post Code: CV7 7LU
Gas Safe No: 927997
Telephone No: 07961768920

Installation Details

Installation Address: 43 Bromhurst Way, Warwick
Post Code: CV34 6NS
Telephone No: 07748 503798

Client Details

Client Address: Mr A Biss, 20 Shresers Dyche, Warwick
Post Code: CV34 6BX
Telephone No: 07976392321

Appliance Details

Inspection Details

	Location	Appliance Type	Make	Model	CO2 Reading (%)	CO Reading (ppm)	Flue Type (OF/RS/FL)	Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure (mbar) or Heat Input (kW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1	Kitchen	Hob	Neff	Unknown	NA	NA	FL	YES	NA	YES	21 mb	NA	YES	NA	N/A	NO	YES
2	Airing Cupboard	Central Heating Boiler	ALPHA	E Tec 25R	9.9	32	RS	YES	0.0003	YES	24.17 kw	YES	YES	YES	N/A	YES	YES
3																	
4																	
5																	

Faults/Notes

Remedial Work Taken

Warning Notice Fixed

1		
2		
3		
4		
5		

Emergency Control Valve Accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

YES

Number of Appliances Tested:

2

Equipotential Bonding:

YES

NEXT INSPECTION DUE ON OR BEFORE:

Sun-06-Apr-2025

Installation Pass:

YES

CO Alarm fitted & working?

YES

Smoke alarm fitted & working?

YES

Signatures

Report Issued By:

Name: Andrew King-Page

Signed:

Date: Tue-11-Mar-2025

Report Received By:

Name: Andrew King-Page

Signed:

Date: Tue-11-Mar-2025

Gas ID Number: 5739462