



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out. This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

101 POOLE ROAD 2025

Certificate No: 101 POOLE ROAD 2025

Engineers Details

Trading Title:

Address:

Gas Safe No: Telephone No:

Installation Details

Installation Address:

Telephone No:

Client Details

Client Address:

Telephone No:

Appliance Details

Inspection Details

	Location	Appliance Type	Make	Model	CO2 Reading (%)	CO Reading (ppm)	Flue Type (OF/RS/FL)	Appliance Inspected (YES/NO/NA/IO) (IO = Visual Inspection Only)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure(mbar) or Heat Input(kW)	Safety Device(s) Correct Operation (YES/NO/NA)	Ventilation Provision Satisfactory (YES/NO)	Visual Condition Of Flue and Termination Satisfactory (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
1	Airing Cupboard	Combi Boiler	Worcester	28i Junior	9.3	64	RS	YES	0.0007	YES	27.45 kw	YES	YES	YES	N/A	NO	YES
2	Kitchen	Cooker	Beiling	Fsg60	NA	NA	FL	YES	NA	YES	21 mb	YES	YES	NA	N/A	NO	YES
3	Lounge	Fire	Straxgas	Unknown	NA	NA	OF	YES	NA	YES	6.45 kw	YES	YES	YES	PASS	NO	YES
4																	
5																	

Faults/Notes

Remedial Work Taken

Warning Notice Fixed

1		
2		
3		
4		
5		

Emergency Control Valve Accessible: Gas Tightness Satisfactory:

Gas Installation Pipework Visual Inspection Satisfactory:

Number of Appliances Tested: Equipotential Bonding:

NEXT INSPECTION DUE ON OR BEFORE: Installation Pass:

CO Alarm fitted & working? Smoke alarm fitted & working?

Signatures

Report Issued By:

Name:

Report Received By:

Name:

Gas ID Number:

Signed:

Date:

Signed: _____

Date: