



# Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure. Unless stated otherwise, no detailed internal inspection of flues (Integrity, Construction and Lining) has been carried out.  
This safety check complies with (but is not limited to) Regulation 26(9) of GSIUR.

Certificate Reference

3 Union Road 2025

Certificate No: 3 Union Road 2025

## Engineers Details

Trading Title  
Coventry Gas Services Ltd

Address  
47 Alspath Road  
Meriden

Post Code: CV7 7LU

Gas Safe No: 927997

Telephone No: 07961768920

## Installation Details

Installation  
Address

Rooms 1-7  
3 Union Road, Leamington Spa, CV32 5LT  
3 Union Road, Leamington Spa, CV32 5LT

Post Code: CV32 5LR

## Client Details

Client  
Address

Mr E McFadden  
C/o Leaders 10 Parade, Leamington Spa CV3  
C/o Leaders 10 Parade, Leamington Spa CV32

Post Code: CV32 4DW

## Appliance Details

## Inspection Details

|   | Location        | Appliance Type | Make    | Model           | CO2 Reading (%) | CO Reading (ppm) | Flue Type<br>(OF/RS/FL) | Appliance<br>Inspected<br>(YES/NO/NA/IO)<br>(IO = Visual Inspection Only) | Combustion<br>Analysis Reading<br>(CO/CO2) | Landlords<br>Appliance<br>(YES/NO/NA) | Operating<br>Pressure(mbar)<br>or<br>Heat Input(kW) | Safety Device(s)<br>Correct<br>Operation<br>(YES/NO/NA) | Ventilation<br>Provision<br>Satisfactory<br>(YES/NO) | Visual Condition<br>Of Flue and<br>Termination<br>Satisfactory<br>(YES/NO/NA) | Flue Performance<br>Test<br>(PASS/FAIL/NA) | Appliance<br>Serviced<br>(YES/NO/NA) | Appliance<br>Safe To Use<br>(YES/NO) |
|---|-----------------|----------------|---------|-----------------|-----------------|------------------|-------------------------|---------------------------------------------------------------------------|--------------------------------------------|---------------------------------------|-----------------------------------------------------|---------------------------------------------------------|------------------------------------------------------|-------------------------------------------------------------------------------|--------------------------------------------|--------------------------------------|--------------------------------------|
| 1 | Kitchen         | Hob            | Candy   | Unknown         | NA              | NA               | FL                      | YES                                                                       | NA                                         | YES                                   | 21 mb                                               | YES                                                     | YES                                                  | NA                                                                            | N/A                                        | NO                                   | YES                                  |
| 2 | Airing Cupboard | Combi Boiler   | Ariston | Clas Net One 38 | 9.7             | 50               | RS                      | YES                                                                       | 0.0005                                     | YES                                   | 37.45 kw                                            | YES                                                     | YES                                                  | YES                                                                           | N/A                                        | YES                                  | YES                                  |
| 3 |                 |                |         |                 |                 |                  |                         |                                                                           |                                            |                                       |                                                     |                                                         |                                                      |                                                                               |                                            |                                      |                                      |
| 4 |                 |                |         |                 |                 |                  |                         |                                                                           |                                            |                                       |                                                     |                                                         |                                                      |                                                                               |                                            |                                      |                                      |
| 5 |                 |                |         |                 |                 |                  |                         |                                                                           |                                            |                                       |                                                     |                                                         |                                                      |                                                                               |                                            |                                      |                                      |

## Faults/Notes

## Remedial Work Taken

## Warning Notice Fixed

|   |  |  |
|---|--|--|
| 1 |  |  |
| 2 |  |  |
| 3 |  |  |
| 4 |  |  |
| 5 |  |  |

Emergency Control Valve  
Accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

YES

Number of Appliances Tested:

2

Equipotential Bonding:

YES

NEXT INSPECTION DUE ON  
OR BEFORE:

Fri-13-Feb-2026

Installation Pass:

YES

CO Alarm fitted & working?

YES

Smoke alarm fitted & working?

YES

## Signatures

Report Issued By:

Name: Andrew King-Page

Signed:

Date: Wed-22-Jan-2025

Report Received By:

Name:

Signed:

Date: Wed-22-Jan-2025

Gas ID Number: 5739462