Propane Tank Inspection Report

Organization: Demo Propane Company Address:123 Industrial Blvd, Demo City,

DC 12345

Inspector: Bruno Larizza Compliance Mode: US NFPA 58

Executive Summary

Inspection identified issues requiring immediate attention for TANK-002 at Secondary Facility - Building B. Leak detection failed and corrective action is required to restore compliance with US NFPA 58 standards.

Inspection Overview

Date	Equipment ID	Location	Test Type	Result	Technician
January 19, 2025 at 09:30 AM	TANK-002	Secondary Facility - Building B	Leak Detection & Visual Inspection	FAIL	Bruno Larizza

Regulatory Compliance

- X Leak Detection Test
- Visual Inspection
- ✓ Documentation Complete

✓ Inspector Certification Valid

Corrective Action Required

Action Required:

Replace gasket and retest system pressure. Schedule follow-up inspection within 24 hours. Isolate affected system until repair is completed.

Inspector Signature	Digital Signature	
Bruno Larizza Date: January 19, 2025 at 09:30 AM	Digitally Signed Date: September 21, 2025 at 03:51 PM	

This report certifies compliance with NFPA 58 standards for propane tank inspection.

Report generated by TankLog on September 21, 2025 at 03:51 PM