



ControlLogix SERCOS Generic Interface Module, Firmware Revision 19

Catalog Number 1756-M08SEG

When to Use These Release Notes

Use these release notes for information about firmware revisions.

IMPORTANT

Before updating your ControlLogix SERCOS generic interface module, we strongly recommend that you review information pertinent to previous major firmware revisions. For example, when updating from revision 18.xx to 19.xx, view information in the ControlLogix SERCOS Generic Interface Module, Revision 18 Release Notes, publication [1756-RN671](#), in addition to the content of these release notes.

Compatible Versions of Software

To use firmware revisions 19.6, these minimum software versions are required.

Software	Required Version
RSLink Classic	2.57 (CPR 9, SR3)
RSLink Enterprise	5.30 (CPR 9, SR3)
RSLogix 5000	19.00 (CPR 9, SR3)
ControlLogix controller	19.xx
RSNetWorx for ControlNet	10.01 (CPR 9, SR2)
RSNetWorx for DeviceNet	
RSNetWorx for EtherNet/IP	



Additional Resources

For more information on using the ControlLogix SERCOS Generic Interface Module, see these publications.

Publication Title	Publication Number
ControlLogix SERCOS Generic Interface Module, Firmware Revision 18 Release Notes, publication 1756-RN671	Information about firmware revision 18.
SERCOS Motion Configuration and Startup User Manual, publication MOTION-UM001	Install, configure, and operate 1756-M02AE and 1756-M02AS analog modules.

You can view or download Rockwell Automation publications at <http://www.rockwellautomation.com/literature/>.

These documents contain additional information concerning related Rockwell Automation products.

Resource	Description
Industrial Automation Wiring and Grounding Guidelines, publication 1770-4.1	Provides general guidelines for installing a Rockwell Automation industrial system.
Product Certifications website, http://www.ab.com	Provides declarations of conformity, certificates, and other certification details.

You can view or download publications at <http://www.rockwellautomation.com/literature/>. To order paper copies of technical documentation, contact your local Rockwell Automation distributor or sales representative.

Allen-Bradley, Rockwell Software, Rockwell Automation, ControlLogix, RSLinx Classic, RSLinx Enterprise, RSLogix 5000, RSNetWorx for ControlNet, RSNetWorx for DeviceNet, and RSNetWorx for EtherNet/IP are trademarks of Rockwell Automation, Inc.

Trademarks not belonging to Rockwell Automation are property of their respective companies.

Rockwell Otomasyon Ticaret A.Ş., Kar Plaza İş Merkezi E Blok Kat:6 34752 İçerenköy, İstanbul, Tel: +90 (216) 5698400

www.rockwellautomation.com

Power, Control and Information Solutions Headquarters

Americas: Rockwell Automation, 1201 South Second Street, Milwaukee, WI 53204-2496 USA, Tel: (1) 414.382.2000, Fax: (1) 414.382.4444

Europe/Middle East/Africa: Rockwell Automation NV, Pegasus Park, De Kleetlaan 12a, 1831 Diegem, Belgium, Tel: (32) 2 663 0600, Fax: (32) 2 663 0640

Asia Pacific: Rockwell Automation, Level 14, Core F, Cyberport 3, 100 Cyberport Road, Hong Kong, Tel: (852) 2887 4788, Fax: (852) 2508 1846

Publication 1756-RN682A-EN-P - September 2010

PN-85427

Copyright © 2010 Rockwell Automation, Inc. All rights reserved. Printed in the U.S.A.