



SoftLogix 5800 Analog Encoder Servo Card, Firmware Revision 16

Catalog Number 1784-PM02AE

When to Use These Release Notes

Use these release notes for firmware revision 16.1.

| Module | Catalog Number |
|--|----------------|
| SoftLogix 5800 analog encoder servo card | 1784-PM02AE |

Compatible Revisions

To use this revision, update your system as follows:

| Update | To Revision |
|--------------------------|---------------|
| RSLinx software | 2.51 or later |
| RSLogix 5000 software | 16 |
| SoftLogix5800 controller | 16 |

Enhancements

For a list of enhancements, see the SoftLogix 5800 Controller Firmware Revision 16 Release Notes, publication 1789-RN016.

Restrictions

This revision has these restrictions:

- **Do not** update the firmware of the card while the SoftLogix 5800 controller with the motion program is in the virtual chassis.
- Reboot the system after you update the firmware. This is especially important if you tied multiple cards together via a synchronization cable (catalog number 1784-PMCSY4).

Rockwell Automation Support

Rockwell Automation provides technical information on the Web to assist you in using its products. At <http://support.rockwellautomation.com>, you can find technical manuals, a knowledge base of FAQs, technical and application notes, sample code and links to software service packs, and a MySupport feature that you can customize to make the best use of these tools.

For an additional level of technical phone support for installation, configuration, and troubleshooting, we offer TechConnect Support programs. For more information, contact your local distributor or Rockwell Automation representative, or visit <http://support.rockwellautomation.com>.

Installation Assistance

If you experience a problem with a hardware module within the first 24 hours of installation, please review the information that's contained in this manual. You can also contact a special Customer Support number for initial help in getting your module up and running.

| | |
|-----------------------|--|
| United States | 1.440.646.3223 Monday – Friday, 8am – 5pm EST |
| Outside United States | Please contact your local Rockwell Automation representative for any technical support issues. |

New Product Satisfaction Return

Rockwell tests all of its products to ensure that they are fully operational when shipped from the manufacturing facility. However, if your product is not functioning, it may need to be returned.

| | |
|-----------------------|---|
| United States | Contact your distributor. You must provide a Customer Support case number (see phone number above to obtain one) to your distributor in order to complete the return process. |
| Outside United States | Please contact your local Rockwell Automation representative for return procedure. |

Allen-Bradley, ControlLogix, Kinetix, RSLinx, RSLogix 5000, Ultra3000, and TechConnect are trademarks of Rockwell Automation, Inc.

Trademarks not belonging to Rockwell Automation are property of their respective companies.

www.rockwellautomation.com

Power, Control and Information Solutions Headquarters

Americas: Rockwell Automation, 1201 South Second Street, Milwaukee, WI 53204-2496 USA, Tel: (1) 414.382.2000, Fax: (1) 414.382.4444

Europe/Middle East/Africa: Rockwell Automation, Vorstlaan/Boulevard du Souverain 36, 1170 Brussels, Belgium, Tel: (32) 2 663 0600, Fax: (32) 2 663 0640

Asia Pacific: Rockwell Automation, Level 14, Core F, Cyberport 3, 100 Cyberport Road, Hong Kong, Tel: (852) 2887 4788, Fax: (852) 2508 1846

Publication 1784-RN535A-EN-E - January 2007

Supersedes Publication 1784-RN534A-EN-E

PN 953030-98

Copyright © 2007 Rockwell Automation, Inc. All rights reserved. Printed in the U.S.A.