

## Certificate of Thorough Inspection & Conformity

This document is to certify that the material or products detailed herein conform to the requirements of the manufacturers specification and have been inspected and tested (where applicable) by a competent and certified inspector.

Customer Reference: alfa Block Walling System

Customer Order: Alfabloc41017
Delivery Date: 06/10/2017
Attached Documents: N/A

**Product:** 2.5T Spread Anchor Ring Clutch

## **Test Method**

This report is intended as evidence of the latest thorough examination report as required by LOLER regulation 9. This certificate is issued following an inspection and examination by a competent person and should be retained by the owner of the products as a record of inspection and reinspection.

## **Results:**

Identification	Description	Quantity	Proof Load	Safe Working
Number		Tested	Applied (kg)	Load (kg)
89433, 89439, 89445, 89441	2.5T Spread Anchor Ring Clutch	4	5000	2500

Inspection Date: 04/10/2017	Re-Inspection Date: 04/04/2018
· · ·	

## **Inspection Results:**

All of the inspected products complied with the dimension specified on the manufacturer's drawings and were free from cracks, flaws and defects.

Tested by: BGW-BOHR GMBH

**Inspected By:** Simply Precast Accessories Ltd

Signed on behalf of Simply Precast Accessories Limited

Aidan Monaghan Managing Director