In sludge processing stages, specific gravity is close to?

Select the correct option

- [x] 1.0
- [ ] 1000
- [ ] 100
- [ ] 10

A sludge with a level of dry solids of 2% has water content of_____.

Select the correct option

- 96%
- 90%
- 98%
- 97%

In primary treatment system, primary sludge takes how much time for slu quid phase?

Select the correct option

- Years
- Months
- Weeks
- Days

In a dewatering process the dry solid level in the dewaterd sludge of filter press ----------.

Select the correct option

- 30-45%
- 60-90%
- 25-40%
- 20-30%

The concentration of solids in sludge is expressed in the form of?

Select the correct option

- ○ Solids
- ○ Semi solids
- ● Dry solids
- ○ Liquid

All of these are artificial processes of pathogen removal except?

Select the correct option

- ○ Chlorination
- ○ UV radiation
- ○ Ozonisation
- ● Land treatment

The sludge production is a function of the waste water treatment system used for the_____.

Select the correct option

- ○ Solid phase
- ○ Gaseous phase
- ● Liquid phase
- ○ All

Gamma radiations are used for_____.

Select the correct option

- [x] Disinfection
- [ ] Conditioning
- [ ] Dewatering
- [ ] Thickening

Which methods are costly for removal of disease causing organisms?

Select the correct option

●	Artificial
○	None
○	Natural
○	Both

Which of the following method affects the reproduction of the pathogenic agents?

Select the correct option

- Maturation ponds
- Natural
- UV radiation
- None

Most frequently used unit for concentration of sludge is?

Select the correct option

- mg/L
- mg
- %
- Grams

Which of the following is highly recommended system for pathogen removal?

Select the correct option

- Ozonisation
- UV radiation
- Chlorination
- Maturation ponds

A very effective method for removal of disease causing organisms is?

Select the correct option

○	Maturation ponds
●	Ozonisation
○	Chlorination
○	UV radiation

All of these are artificial processes of pathogen removal except?

Select the correct option

○	Chlorination
●	Land treatment
○	UV radiation
○	Ozonisation

For sludge stabilization, chemical stabilization is accompanied by ..... of an organic matter. ororganic matter?

Select the correct option

- Oxidation
- Bacteria
- Reduction
- Both B& C

Which methods are costly for removal of disease causing organisms?

Select the correct option

- Artificial
- None
- Both
- Natural

Click to Save Answer & Move to Next Question

Which of the following sludge management stage include preparation for dewatering?

Select the correct option

- ○ Dewatering
- ● Conditioning
- ○ Thickening
- ○ Stabilization

In UASB + polishing pond dry solid level ranges between?

Select the correct option

●	3-4%
○	2-3%
○	4-5%
○	1-2%

In primary treatment system, primary sludge takes how much time for sludge removal from liquid phase?

Select the correct option

- Months
- Years
- Weeks
- Days

Click to Save

Which of the following pathogen removal system does not need chemicals?

Select the correct option

○	Chlorination
○	UV radiation
●	Maturation ponds
○	Ozonisation

Toxic by-products can be generated in which of the following system?

Select the correct option

- Chlorination
- UV radiation
- Maturation ponds
- Ozonisation

Which of the following method for pathogen removal affects the reproduction of pathogenic agents.

Select the correct option

○	Maturation pond
○	Land treatment
○	Chlorination
●	UV radiation

Click to

In the removal of pathogenic organisms, natural process involve?

Select the correct option

- Ozonisation
- Maturation ponds
- Chlorination
- UV radiation

Thickening in sludge management is removal of _____.

Select the correct option

- Non-organic matter
- Organic matter
- Pathogenic organisms
- Water

Free water in the sludge can be removed by which method?

Select the correct option

○	Capillary action
○	Suction
●	Gravity
○	None

In a dewatering process the dry solid level in the dewaterd sludge of filter press ----------.

Select the correct option

- 30-45%
- 25-40%
- 20-30%
- 80-90%

The design of sludge treatment and final disposal stages is based on which of the following?

Select the correct option

○	Sludge flow
○	Dry solids load
●	Both
○	None

Large areas are required for which pathogen removal system?

Select the correct option

- Land treatment
- Maturation ponds
- Natural
- Chlorination

Adsorbed water in the sludge can be removed by?

Select the correct option

- Adhesive agents
- Cohesive agents
- Chemical agents
- Flocculating agents

Stages of sludge processing involve?

Select the correct option

- ○ Thickening
- ● All
- ○ Digestion and dewatering
- ○ Final disposal

Question # 3 of 10 (Start time: 05:48:38 PM, 30 January 2023)

A sludge with a level of dry solids of 2% has water content of _____.

Select the correct option

- 98%
- 96%
- 97%
- 90%

Which of following process does not introduce chemical products into the liquid.

Select the correct option

- UV radiation
- Chlorination
- Membranes
- Maturation ponds

Which of the following method for pathogen removal affects the reproduction of pathogenic agents.

Select the correct option

- ○ Chlorination
- ○ Maturation pond
- ● UV radiation
- ○ Land treatment

Criteria for analysis of waste water treatment include?

Select the correct option

- ○ Technical
- ○ Economical
- ○ Quantitative and qualitative
- ● All

Facultative ponds require how much time for sludge removal from liquid phase?

Select the correct option

○	Weeks
●	Decades
○	Months
○	Days

Removal of organic matter in sludge management is known as-------.

Select the correct option

●	Mass reduction
○	Disinfection
○	Dewatering
○	Volume reduction

--------- process is an appropriate method for sludge stabilization in nurseries, horticulture and landscaping.

Select the correct option

- ○ Thermal drying
- ● Composting
- ○ Lime stabilization
- ○ Anerobic digestion

How much dry solid content is found in hard solid?

Select the correct option

○	0%-25%
○	60%-80%
○	25%-35%
●	35%-60%

------following chemicals are added in the sludge preparation process.

Select the correct option

○	Sulphur
○	Coagulants
○	Polyelectrolytes
●	Both a&c

Density of the liquid sludge range between?

Select the correct option

○	0.1-0.2
●	1.02-1.03
○	0.2-0.3
○	2.1-2.3

Toxic by-products can be generated in which of the following system?

Select the correct option

- Ozonisation
- UV radiation
- Maturation ponds
- Chlorination

.....is the main natural water removal mechanism/s in the sludge dewatering.

Select the correct option

○	Landfill
○	Incineration
○	Digestion
●	Percolation

Density of sludge in processing stages is close to?

Select the correct option

○	500kg/m3
●	1000kg/m3
○	100kg/m3
○	10kg/m3

For which of the following waste water treatment system the equipment depends on the post treatment process used.

Select the correct option

○	Substrate infiltration
○	Slow rate treatment
○	Rapid infiltration
●	UASB reactor + post-treatment

A sludge with a solids load of 120 kgSS/d and a solids concentration of 2.0 % (20,000 mg/L) will have a flow of?

lect the correct option

- 6.0 m3/d
- 4.0 m3/d
- 7.0 m3/d
- 5.0 m3/d

Water content influences which properties of the sludge?

Select the correct option

- Physical
- Biological
- Chemical
- mechanical

For sludge stabilization, chemical stabilization is accompanied by ..... of an organic matter. ororganic matter?

Select the correct option

- Oxidation
- Bacteria
- Reduction
- Both B& C

Which of the following method for removal of pathogenic organisms do not need chemical products or energy, but require large areas.

Select the correct option

- Membranes
- Maturation ponds
- UV radiation
- Chlorination

The concentration of solids in sludge is expressed in the form of?

Select the correct option

- Dry solids
- Solids
- Liquid
- Semi solids

The design of sludge treatment and final disposal stages is based on which of the following?

Select the correct option

- ○ Sludge flow
- ● Both
- ○ None
- ○ Dry solids load

Which of the following sludge management stage accomplished through the removal of the biodegradable organic matter

Select the correct option

- Thickening
- Conditioning
- Dewatering
- Stabilization

In the process of dissolved air flotation release of oxygen in the form of bubbles is known as---------.

Select the correct option

- Depressurization
- Belt presses
- Non cyclic
- Continual

If the sludge is to be incinerated then the following --------process is not necessary.

Select the correct option

●	Disinfection
○	Thickenng
○	Stabilization
○	Dewatering

Which of the following method for removal of pathogenic organisms do not need chemical products or energy, but require large ar

Select the correct option

- Maturation ponds
- UV radiation
- Chlorination
- Membranes

In UASB + polishing pond dry solid level ranges between?

Select the correct option

○	2-3%
●	3-4%
○	4-5%
○	1-2%

Capillary water maintain itself adsorbed in which of the following phase?

Select the correct option

- ○ Semi solid
- ○ Gaseous
- ● Solid
- ○ Liquid

In the removal of pathogenic organisms, natural process involve?

Select the correct option

- ○ UV radiation
- ○ Chlorination
- ○ Ozonisation
- ● Maturation ponds

---------- metallic coagulants is/are used in conditioning of sludge.

Select the correct option

●	Both A& B
○	Ferric chloride
○	Aluminium sulphate
○	Ferrous chloride

A process in sludge management for preparation for dewatering is known as_____.

Select the correct option

○	Disinfection
●	Conditioning
○	Stabilization
○	Dewatering

Criteria for analysis of waste water treatment include?

Select the correct option

○	Economical
○	Quantitative and qualitative
○	Technical
●	All

How much dry solid content is found in fluid sludge?

Select the correct option

○	35%-60%
○	25%-35%
●	0%-25%
○	60%-80%

---------is used for thickening of sludge.

Select the correct option

○	Centrifuge
●	Both b&c
○	Belt presses
○	Resistant barrier