


N-G2 - Mobilization = 50%  
N-E1 - Misc Elec Work = 25%  
E-10 - Pullbox Type I = 3  
E-13 - 1.5" GRC Conduit = 140'

SHEET NOTES:

- 1 INTERCEPT EXISTING STREETLIGHT CONDUIT WITH A TYPE I PULL BOX ON SIDEWALK SURFACE. SPLICE NEW WIRES AND EXISTING WIRES IN EXISTING SUB-SIDEWALK BASEMENT PULL BOX.
- 2 PROVIDE 10A FUSE AND FUSE HOLDER FOR NEW PEDESTRIAN LIGHTS.
- 3 R/C STREET LIGHT POLE, ARM AND FIXTURE.
- 4 DETECTABLE SURFACE TILES SHALL BE OFFSET FROM OUTER EDGE OF ANCHOR BOLTS BY 6-INCHES. THE SIDEWALK AND STREET SIDE OF THE LIGHT SHALL HAVE NO DETECTABLE SURFACE TILES.

NOTE:  
THIS AUTOCAD DRAWING HAS BEEN REVISED AND REPLOTTED SUBSEQUENT TO INTERNAL ENGINEERING APPROVAL AND SIGN-OFF. FOR THOSE SIGNATURES, SEE THE DRAWING PLOTTED AND ISSUED PREVIOUSLY DURING BIDDING. THE SIGNED DRAWING REMAINS VALID EXCEPT FOR THE CHANGES ONLY AS CLEARLY MARKED ON THIS DRAWING AND ISSUED UNDER THIS LATEST REVISION NUMBER AS SHOWN IN THE TABLE OF REVISIONS LOCATED AT THE LOWER LEFT CORNER OF THE DRAWING. ALL ISSUED REVISIONS SUBSEQUENT TO PREVIOUSLY PLOTTED DRAWING DURING BIDDING REMAIN VALID UNLESS SUPERSEDED BY LATER ISSUED REVISIONS. CHECK ALL ISSUED REVISIONS OF THIS DRAWING.



NO.	DATE	DESCRIPTION	BY	APP.
1	9/17/18	PCO #6 Natoma Extension	ST	SL
TABLE OF REVISIONS				


REFERENCE INFORMATION  
& FILE NO. OF SURVEYS



BUREAU OF DESIGN & ENGINEERING  
CITY & COUNTY OF SAN FRANCISCO  
SAN FRANCISCO PUBLIC WORKS  
30 VAN NESS AVENUE, 5TH FLOOR  
SAN FRANCISCO, CA 94102 - 6028

Section Mgr:	PHILIP THWIN	Date:	
Deputy Bureau Mgr:	IQBALBHAI DHAPA		
Bureau Mgr:	PATRICK RIVERA		

DESIGNED:	DATE:
ST/RN	9/18
DRAWN:	DATE:
ST	9/18
CHECKED:	DATE:
SL/RN	9/18



SCALE:  
1" = 5'-0"  
SHEET OF SHEETS

2ND STREET STREETSCAPE  
IMPROVEMENTS PROJECT  
  
STREET LIGHTING PLAN  
NATOMA STREET, 2ND ST TO TRANSBAY TERMINAL

CONTRACT NO.	1064J
DRAWING NO.	NE-1
FILE NO.	106,287.1
REV. NO.	1