

AWSS LOCATION (2ND STREET AND BRANNAN STREET)

SCALE: AS SHOWN

GENERAL NOTES:

- 1. DRAWING IS DIAGRAMMATIC AND CORRECT FOR GENERAL DESIGN ONLY. SEE MECHANICAL DRAWINGS FOR DIMENSIONS AND EXACT LOCATIONS OF AWSS CONTROLLER CABINET, BATTERY VAULT, MOTORIZED GATE VALVE EQUIPMENT, PIPES, CONDUITS, ETC.
- 2. PRIOR TO START OF PROJECT, CONTRACTOR SHALL COORDINATE WITH SFPUC CDD VIA THE ENGINEER. PROVIDE MINIMUM 14 WORKING DAYS NOTICE.
- 3. CONTRACTOR SHALL MAKE A WATER TIGHT SEAL AT EVERY CONDUIT PENETRATION TO CONTROLLER CABINET. PROVIDE CONDUIT BOOTH FITTINGS ENTERING BELOW GRADE ENCLOSURE. DUCT SEAL OPENING OF CONDUITS. PROVIDE 1/4" NYLON PULL ROPE IN ALL CONDUITS.
- 4. CONTRACTOR TO PICK UP BATTERY VAULT AND BATTERY ENCLOSURE AT SFPUC CDD YARD 1990 NEWCOMB AVE. CONTACT SFPUC ELECTRIC SHOP REPRESENTATIVE MICHAEL SHEA AT (415) 717-1854 OR TONY OLFERT (415) 672-8284.

SHEET NOTES:

- FIELD VERIFY, LABEL, AND DISCONNECT ALL EXISTING POWER, SIGNAL, AND CONTROL WIRING FOR TO REUSE AT THE NEW LOCATION EXCEPT ANTENNA WIRING. ANTENNA POLE WILL BE REPLACED BY WIRELESS SYSTEM BY OTHERS. REFER TO MECHANICAL DWGS FOR R/S AND R/C OF AWSS EQUIPMENT.
- 2 ABANDON CONDUIT AND REUSE EXISTING WIRING.
- CONTRACTOR TO RELOCATE EXISTING AWSS CONTROLLER CABINET TO NEW LOCATION. REFER TO NEC 250.4 FOR GENERAL REQUIREMENTS FOR GROUNDING & BONDING. CONDUIT ENTRY AND BOLT PATTERN TO MATCH EXISTING. REFER TO STRUCTURAL DWGS FOR FOUNDATION AND BOLLARD DETAIL.
- CONTRACTOR TO INSTALL NEW BATTERY VAULT AND BATTERY ENCLOSURE PROVIDED BY SFPUC. SFPUC CDD TO INSTALL BATTERIES. CONDUIT ENTRY TO VAULT TO MATCH EXISTING. VAULT SHALL CLEAR EXISTING AT&T DUCT BANK.
- FIELD VERIFY AND INTERCEPT EXISTING CONDUIT WITH NEW CONDUIT. NEW CONDUIT SHALL MATCH EXISTING SIZE AND TYPE. PULL BACK ALL WIRES RELATED TO AWSS GATE VALVE AND SUMP PUMP ETC. AND REUSE AND RECONNECT TO NEW CABINET LOCATION.
- CONTRACTOR TO PROVIDE WIRES FOR TEMPERATURE SENSOR AND FLOAT SWITCH TO MATCH EXISTING.

 6 BATTERY CHARGER AND ANCILLARY CABLES BY SFPUC CDD.
- FIELD VERIFY AND INTERCEPT EXISTING CONDUIT WITH NEW CONDUIT TO MATCH EXISTING. REUSE EXISTING SERVICE WIRE FROM EXISTING CABINET TO NEW CABINET LOCATION.
- COORDINATE WITH SFPUC CDD FOR FINAL ACCEPTANCE TESTING AND INSPECTION. PROVIDE MINIMUM 14 WORKING DAYS NOTICE.

| REFERENCE INFORMATION & FILE NO. OF SURVEYS | BUREAU OF ENGINEERING | Deputy Bureau Mgr; FERNANDO CISNEROS / / DRAWN: DATE: | 2ND STREET STREETSCAPE IMPROVEMENTS PROJECT CONTRACT NO. 1064J DRAWING NO. E-6.0 |
|--|--|--|---|
| NO. DATE DESCRIPTION BY APP. TABLE OF REVISIONS | SAN FRANCISCO PUBLIC WORK 30 VAN NESS AVENUE, 5TH FLOOR SAN FRANCISCO, CA 94102 - 6028 | Acting Bureau Mgr: IQBAL DHAPA I/22/2020 GL 10/2019 NO. E15417 SHEET OF SHEETS SL 11/2019 OF CALLED I/15/1400 | 2ND STREET AND BRANNAN STREET AWSS EQUIPMENT RELOCATION FILE NO. REV. NO. |