



NOTE

* OR MJ SLEEVE WITH MJ RESTRAINTS
(FOR 16" ONLY)

	MATERIALS	BP-6x12	BP-8x12	BP-8x16
CONTRACTOR	TEE	6"x6" (1)	8"x8" (1)	8"x8" (1)
	GATE VALVE	6" (1)	8" (1)	8" (1)
	BOX COVER	6" (1)	8" (1)	8" (1)
	STEEL BASE PLATE	6" (1)	8" (1)	8" (1)
	FIELD LOK GASKET	6" (5)	8" (5)	8" (5)
	TIE ROD	5/8" (2)	3/4" (2)	3/4" (2)
SFWD	90° BEND	6" (1)	8" (1)	8" (1)
	MJ TEE	12"x6" (1)	12"x8" (1)	16"x8" (1)
	HYMAX GRIP	6" (2)	8" (2)	16" (2)
	FIELD LOK GASKET	6" (2)	8" (2)	8" (2)
	TIE ROD	5/8" (2)	3/4" (2)	3/4" (2)
	EBA 1100DEC	6"(1),12"(2)	8"(1),12"(2)	8"(1),16" (2)



San Francisco
**Water
Power
Sewer**

Services of the San Francisco Public Utilities Commission

WATER ENTERPRISE -- CITY DISTRIBUTION DIVISION STANDARD PLANS

**NEW BYPASS TO EXISTING PIPE CONNECTION
FOR NEW 6" OR 8" PIPE TO EXISTING 12" OR 16"
PIPE**

DATE **JAN 2020**

REV.

DRAWING NO.

SHEET

SCALE **N.T.S.**

0

CDD-LP-103

12