



|            | MATERIALS        | ML-16x6       | ML-16x8       |
|------------|------------------|---------------|---------------|
| CONTRACTOR | FLEX RING TEE    | 16"x6" (1)    | 16"x8" (1)    |
|            | GATE VALVE       | 6" (1)        | 8" (1)        |
|            | FASTITE GASKET   | 16"(2), 6"(1) | 16"(2), 8"(1) |
|            | FIELD LOK GASKET | 6" (2)        | 8" (2)        |
|            | BOX COVER        | 6" (1)        | 8" (1)        |
|            | STEEL BASE PLATE | 6" (1)        | 8" (1)        |
|            | EBAA 15PF00TD    | 6" (1)        | 8" (1)        |
|            | 45° BEND         | 6" (2)        | 8" (2)        |
|            | HYMAX GRIP       | 6" (1)        | 8" (1)        |
|            | FIELD LOK GASKET | 6"(4)         | 8" (4)        |
| SFWD       | TIE ROD          | 5/8" (2)      | 3/4" (2)      |

#### NOTES

\* OR TR FLEX WITH TYTON GASKET



San Francisco  
**Water  
Power  
Sewer**

Services of the San Francisco Public Utilities Commission

WATER ENTERPRISE - CITY DISTRIBUTION DIVISION STANDARD PLANS

#### NEW LATERAL MAIN CONNECTION TO EXISTING BRANCH FOR NEW 16" MAIN TO EXISTING 6" OR 8" BRANCH

|       |          |      |             |       |
|-------|----------|------|-------------|-------|
| DATE  | JAN 2020 | REV. | DRAWING NO. | SHEET |
| SCALE | N.T.S.   | 0    | CDD-LP-127  | 36    |