



_____ — SFWD
 _____ — CONTRACTOR
 - - - - - — EXISTING

NOTES

* OR TR FLEX WITH TYTON GASKET

	MATERIALS	BPT-12x16
CONTRACTOR	FLEX RING TEE	12"x12" (1)
	FIELD FLEX RING	12" (1)
	GATE VALVE	12" (1)
	EBAA 15PF00TD	12" (1)
	FIELD LOK GASKET	12" (2)
	BOX COVER	8" (1)
	STEEL BASE PLATE	8" (1)
	FASTITE GASKET	12"(3)
SFWD	90° BEND	12" (1)
	FIELD LOK GASKET	12" (1)
	TAPPING SLEEVE	16"x12" (1)
	FLANGExTYTON GV	12" (1)
	EBAA 1100DEC	12" (2)



San Francisco
**Water
Power
Sewer**

Services of the San Francisco Public Utilities Commission

WATER ENTERPRISE – CITY DISTRIBUTION DIVISION STANDARD PLANS

**NEW BYPASS TAP TO EXISTING PIPE CONNECTION
FOR NEW 12" PIPE TO EXISTING 16" PIPE**

DATE	JAN 2020	REV.	DRAWING NO.	SHEET
SCALE	N.T.S.	0	CDD-LP-108	17