



\_\_\_\_\_ — SFWD  
 \_\_\_\_\_ — CONTRACTOR  
 - - - - - — EXISTING

	MATERIALS	NH-12	NH-16
CONTRACTOR	FLEX RING TEE	12"x6" (1)	16"x6" (1)
	GATE VALVE	6" (1)	6" (1)
	HYDRANT BURY	6" (1)	6" (1)
	BOX COVER	6" (1)	6" (1)
	STEEL BASE PLATE	6" (1)	6" (1)
	FASTITE GASKET	12"(2), 6"(1)	16"(2), 6"(1)
	FIELD LOK GASKET	6" (3)	6"(3)
	EBAA 15PF00TD	6" (1)	6" (1)
	TIE ROD	5/8" (2)	5/8" (2)

#### NOTES

\* OR TR FLEX WITH TYTON GASKET



San Francisco  
**Water  
Power  
Sewer**

Services of the San Francisco Public Utilities Commission

WATER ENTERPRISE – CITY DISTRIBUTION DIVISION STANDARD PLANS

## NEW HYDRANT CONNECTION FOR 12" OR 16" PIPE

DATE JAN 2020

REV.

DRAWING NO.

SHEET

SCALE N.T.S.

0

CDD-LP-131

40