



_____ — SFWD
 _____ — CONTRACTOR
 - - - - - — EXISTING

	MATERIALS	PNM-6x4	PNM-8x4	PNM-8x6
SFWD	45° BEND	6" (2)	8" (2)	8" (2)
	HYMAX GRIP	4" (1)	4" (1)	6" (1)
	BELLxSPIGOT REDUCER	6"x4" (1)	8"x4" (1)	8"x6" (1)
	FIELD LOK GASKET	4"(1), 6"(4)	4"(1), 8"(4)	6"(1), 8"(4)
	TIE ROD	5/8" (4)	3/4" (4)	3/4" (4)



San Francisco
**Water
Power
Sewer**

Services of the San Francisco Public Utilities Commission

WATER ENTERPRISE – CITY DISTRIBUTION DIVISION STANDARD PLANS

**NEW PARALLEL MAIN CONNECTION
FOR NEW 6" OR 8" PIPE REDUCING TO EXISTING
4" OR 6" PIPE**

DATE **JAN 2020**

REV.

DRAWING NO.

SHEET

SCALE **N.T.S.**

0

CDD-LP-114

23