



VALVE COVER ADJUSTMENT NOTES FOR SIDEWALKS:

1. SIDEWALK TRAFFIC RATED BOX SIZES ARE AS FOLLOWS. BOXES SHALL BE CHRISTY G05T OR APPROVED EQUIVALENT. BOX INSCRIPTION SHALL BE THE SAME AS THE EXISTING VALVE COVER.

| <u>EXISTING VALVE BOX TYPE:</u> | <u>CHRISTY ASSEMBLY:</u> | <u>COMMODITY CODE:</u> |
|-----------------------------------|--------------------------|------------------------|
| 1.1. EXISTING 6-INCH DIAMETER BOX | G05T W/ SFWD LID | 056-25-0910 |
| | G05T W/ SFFD LID | 056-25-0910 |
| EXISTING 8-INCH DIAMETER BOX | G05T W/ SFWD LID | 056-25-0910 |

2. BOX COVER LOCKING BOLTS SHALL **NOT** BE INSTALLED.
3. MINIMUM DISTANCE BETWEEN VALVE OPERATING NUT AND VALVE BOX COVER SHALL BE SIX (6) INCHES.
4. (E) IRON VALVE BOX SHALL BE CUT OR GROUND SUCH THAT THE CHRISTY BOX DOES NOT REST ON THE THE MODIFIED IRON VALVE BOX. TRAFFIC LOADS SHALL NOT BE TRANSFERRED TO THE IRON VALVE BOX.
5. BOXES OVER BRONZE AND / OR GALVANIZED SERVICE VALVES SHALL BE CORRUGATED PVC OR HDPE.



San Francisco
**Water
Power
Sewer**

Services of the San Francisco Public Utilities Commission

WATER ENTERPRISE – CITY DISTRIBUTION DIVISION STANDARD PLANS

**VALVE BOXES & COVERS
ADJUSTMENT OF POTABLE VALVE BOXES AND
COVERS ON WATER LATERALS TO SIDEWALK GRADE**

| | | | | |
|-------|-----------|------|-------------|-------|
| DATE | 7/21/2017 | REV. | DRAWING NO. | SHEET |
| SCALE | N.T.S. | 1 | CDD-LP-254 | 89 |