



\_\_\_\_\_ — SFWD  
 \_\_\_\_\_ — CONTRACTOR  
 - - - - - — EXISTING

	MATERIALS	NH-6	NH-8
CONTRACTOR	TEE	6"x6" (1)	8"x6" (1)
	GATE VALVE	6" (1)	6" (1)
	HYDRANT BURY	6" (1)	6" (1)
	BOX COVER	6" (1)	6" (1)
	STEEL BASE PLATE	6" (1)	6" (1)
	FIELD LOK GASKET	6" (6)	6"(4), 8"(2)
	TIE ROD	5/8" (4)	5/8" (4)



San Francisco  
**Water  
Power  
Sewer**

Services of the San Francisco Public Utilities Commission

WATER ENTERPRISE — CITY DISTRIBUTION DIVISION STANDARD PLANS

## NEW HYDRANT CONNECTION FOR 6" OR 8" PIPE

DATE JAN 2020

REV.

DRAWING NO.

SHEET

SCALE N.T.S.

0

CDD—LP—130

39