



— SFWD
— CONTRACTOR
— EXISTING

	MATERIALS	BP-12x16
CONTRACTOR	FLEX RING TEE	12"x12" (1)
	BOX COVER	8" (1)
	GATE VALVE	12" (1)
	STEEL BASE PLATE	8" (1)
	EBAA 15PF00TD	12" (1)
	FASTITE GASKET	12" (3)
	FIELD LOK GASKET	12" (1)
SFWD	90° MJ BEND	12" (1)
	MJ TEE	16"x12" (1)
	HYMAX GRIP	16" (2)
	EBAA 1100DEC	16"(2), 12"(3)
	FIELD LOK GASKET	12" (1)

NOTE

* OR TR FLEX WITH TYTON GASKET

** OR MJ SLEEVE WITH MJ RESTRAINTS



San Francisco
**Water
Power
Sewer**
Services of the San Francisco Public Utilities Commission

WATER ENTERPRISE - CITY DISTRIBUTION DIVISION STANDARD PLANS

NEW BYPASS TO EXISTING PIPE CONNECTION FOR NEW 12" PIPE TO EXISTING 16" PIPE

DATE	1/17/2020	REV.	DRAWING NO.	SHEET
SCALE	N.T.S.	0	CDD-LP-105	14