



NOTES

* OR TR FLEX WITH TYTON GASKET

NOTE

* OR TR FLEX WITH TYTON GASKET

_____ — SFWD
 _____ — CONTRACTOR
 - - - - - — EXISTING

	MATERIALS	LAT-16x6	LAT-16x8	LAT-16x12	LAT-16x16
CONTRACTOR	FLEX RING TEE	16"x6" (1)	16"x8" (1)	16"x12" (1)	16"x16" (1)
	GATE VALVE	6" (1)	8" (1)	12" (1)	
	FIELD LOK GASKET	6"(2)	8"(2)	12"(2)	
	EBAA 15PF00TD	6" (1)	8" (1)	12" (1)	
	MJ GATE VALVE				16" (1)
	EBAA 1100DEC				16" (2)
	BOX COVER	6" (1)	8" (1)	8" (1)	8" (1)
	STEEL BASE PLATE	6" (1)	8" (1)	8" (1)	8" (1)
	FIELD LOK GASKET	6"(2)	8"(2)	12"(2)	16" (2)
	FASTITE GASKET	16"(2), 6"(1)	16"(2), 8"(1)	16"(2), 12"(1)	16" (3)
	FIELD FLEX RING	6" (1)	8" (1)	12" (1)	16" (1)



San Francisco
**Water
 Power
 Sewer**

Services of the San Francisco Public Utilities Commission

WATER ENTERPRISE – CITY DISTRIBUTION DIVISION STANDARD PLANS

NEW LATERAL MAIN CONNECTION FOR NEW 6", 8", 12" OR 16" BRANCH TO NEW 16" MAIN

DATE JAN 2020

REV.

DRAWING NO.

SHEET

SCALE N.T.S.

0

CDD-LP-119

28