



VALVE COVER ADJUSTMENT NOTES FOR ASPHALT WEARING SURFACES (>4" GRADE CHANGE):

1. TO RAISE VALVE COVERS GREATER THAN 4 INCHES TO (N) STREET GRADE, INSTALL NEW BELL & SPIGOT PIPE CUT TO SUIT. (CLASS 53).
2. (N) ASPHALT WEARING SURFACE SHALL ENCASE THE CIRCUMFERENCE, BUT NOT BE PLACED OVER THE TOP SURFACE OF THE SFWD VALVE COVER.
3. FOR COVER ADJUSTMENTS $\leq 4"$, SEE CDD-LP-253A.



San Francisco
**Water
Power
Sewer**

Services of the San Francisco Public Utilities Commission

WATER ENTERPRISE - CITY DISTRIBUTION DIVISION STANDARD PLANS

**VALVE BOXES & COVERS
ADJUSTMENT OF STANDARD POTABLE GATE COVER
TO NEW PAVEMENT GRADE (>4")**

DATE 7/5/2018

REV.

DRAWING NO.

SHEET

SCALE N.T.S.

0

CDD-LP-253B

88