

SPECIFICATION OF FURRED PARTITION

I. GENERAL

The “floating” wall construction will require two (2) layers of 15 mm gypsum boards constructed with a non-bridged air space between wall and structure. The independent wall construction allows isolation of the interior room from the building structure. The intent of the wall construction is as follows:

- A. Minimum 50mm drywall furring channel, 1mm thick (verify by others) on 400 to 600 centers separated by minimum 40 mm non-bridged air space.
- B. Two (2) layer of 15 mm shall be applied to the resiliently supported furring channel to sound isolated material from the wall.
- C. Furring channels are resiliently guided and braced to the building structure with resilient sound isolation clip.
- D. Full depth insulation shall be provided within the entire depth of the both stud rows.
- E. All ductwork penetrations (if any) shall be packed with packed with batt insulation or similar fire safing insulation and caulked.

II. ISOLATOR PHYSICAL PROPERTIES

- A. Wall Resilient Sound Isolation Clip: Isolation clips shall be made with a rubber element into which a standard galvanized steel furring channel is captured. The channel legs snap fit into the rubber element without any metal-to-metal or other rigid contact with building element. Sound isolation clip shall have a natural frequency not in excess of 12 Hz based on the weight of the wall area per clip and a vertical stiffness not in excess of 50% of the horizontal.

III. SHOP DRAWINGS AND SUBMITTALS

The following is the minimum required prior to acceptance of Project Manager:

- A. Load, deflection curves and details for all isolators.
- B. Drawing showing location and loading of all isolators which is coordinated with all trades. Penetrations are to be shown on drawings.
- C. All products associated with the installation.
- D. Installation and adjustment procedure.
- E. Catalog cut sheet of resilient mount.
- F. Sound Transmission Loss Test Report per ASTM E90 documenting a minimum STC 64 wall assembly for a 150mm concrete wall with one layer of gypsum board resiliently supported by sound isolation clip.

IV. APPROVED MANUFACTURERS

The following are manufacturers with products similar to that describe above (modification of standard product may be necessary):

- A. Kinetics Noise Control
- B. Mason Industries
- C. CDM
- D. Approved equivalent

V. FIELD ACOUSTIC PERFORMANCE

Acoustical Separation Requirement and Specification	
Space Separation	Noise Isolation Class (NIC)
Between Mechanical Equipment Rooms and Occupied Rooms	NIC 58

END OF SECTION