

Architectural Particular Specification

SANITARY FITTINGS AND ACCESSORIES

SECTION 10.2

Rev	Date	Description
0	14 APR 2022	First Issue

SECTION 10.2

SANITARY FITTINGS AND ACCESSORIES

PART 1 GENERAL

1.01 SUMMARY OF WORK

- A. Section Includes: The Work of this Section includes, but is not limited to, the supply and installation of all sanitary fittings for the following areas:-
 - 1. Lavatories
 - 2. Accessible Lavatories
 - 3. Pantry
 - 4. Janitor Room
 - 5. Any other premise as per indicated in drawings and schedule

1.02 REFERENCES

- A. BS ISO - British Standard by International Organization for Standardization:
 - 1. BS ISO 1456 - Metallic coatings. Electrodeposited coatings of nickel plus chromium and of copper plus nickel plus chromium.
- B. Local Code
 - 1. Design Manual - Barrier Free Access 2008

1.03 QUALITY ASSURANCE

- A. Source limitations: obtain each type of products from single source from single manufacturer.

1.04 PERFORMANCE REQUIREMENTS

- A. All sanitary fittings and accessories shall be proprietary products from a single supplier. Each component and accessory for one sanitary fitting item shall be from the same series by a single manufacturer/brand to ensure compatibility and consistency in quality.
- B. All sanitary fittings shall comply with the latest Building (Standards of Sanitary Fittings, Plumbing, Drainage Works and Latrines) Regulations.
- C. All pipe fittings shall comply with Waterworks Regulations and Water Supplies Department standard requirement & practice notes.
- D. All valve fittings shall be acceptable by Water Authority. Copies of certificates, or equivalent letter certifying acceptance of all valves fittings by Water Authority shall be submitted for approval of the Architect.
- E. All fittings for water closets and urinals shall be suitable for sea water application in local context. Manufacturer's certificates are required to be submitted for approval of the Architect.

- F. Dimensions of all proposed sanitary fittings shall be in accordance with the dimension of the attached schedule.
- G. Unit rates must include for the supply of all fixing, jointing, wall flanges and connecting accessories.
- H. All sanitary fittings shall be of white and matching colour unless otherwise specified.
- I. Unless otherwise specified, all chrome plated valves, mixers, taps pop up drain and other chrome plated items shall be of gold plate solid brass and chrome plate body.

1.05 ENVIRONMENTAL REQUIREMENTS

(NOT USED)

1.06 ENVIRONMENTAL, CLIMATIC & PSYCHOMETRIC CONDITIONS

(NOT USED)

1.07 SUBMITTALS

- A. Project Data: for each type of product indicated. Include constructions details, material description, dimensions of individual components and profiles, and finishes.
- B. Shop drawings shall be submitted to the Architect for approval. The proposed arrangement, location, details and setting out of sanitary fittings shall be shown.
- C. Samples for Verification: For each type of toilet accessory indicated
 - 1. Approved full size sample will be returned and may be used in the work.
- D. Product Schedule: For toilet accessories. Indicated types, quantities, sizes, and installation locations by room of each accessory required.
- E. Construction Drawings: Drawings showing location of each built-in anchor supporting toilet accessories, including anchors to be installed as work of other Sections, drawn to scale and coordinating anchorage with toilet accessories. Show the following:
 - 1. Locations, dimensions and profiles of wall and floor reinforcements.
 - 2. Locations and installation details do built-in anchors.
 - 3. Elevations of each toilet accessories showing dimensions of accessory, preparations of receiving anchors, and locations of anchorage.
 - 4. Details of attachment of each toilet accessory to built-in anchor.
- F. Weld certificates
- G. Maintenance data: For toilet accessories to include in maintenance manuals
- H. Warranties: sample of special warranties.
- I. Other informational Submittals:
 - 1. Examination reports documenting inspection of substrates, areas, and conditions.
 - 2. Anchor inspection reports, documenting inspections of built-in and cast-in anchor.
 - 3. Field quality-control certifications signed by Contractor.

1.08 PRE-INSTALLATION CONFERENCE

- A. Coordinate accessory locations with other work to prevent interference with clearances required for access by people with disabilities, and for proper installation, adjustment, operation, cleaning, and servicing of accessories.
- B. Coordinate wall construction to ensure that actual opening dimensions correspond to dimensions required for recessed toilet accessories.

1.09 DELIVERY STORAGE AND HANDLING

- A. Protect all work from damage during transportation, storage at job site, erection, and subsequent construction activities.
- B. Do not deliver to site components which cannot be put immediately into suitably dry, floored and covered storage. Stack on bearers, separated with spacers to prevent damage to projecting ironmongery, beads, etc.
- C. During delivery, storage, fixing and thereafter with Substantial Completion, maintain conditions of temperature and humidity to suit specified moisture content(s) of components. The contractor shall provide the test components with an approved moisture meter to manufacturer's recommendations as instructed by Architect.
- D. Exposed materials shall be wrapped with heavy reinforced, non-staining paper or other approved methods before installation.
- E. After installation, provide additional temporary protection as required to protect all work from damage during subsequent construction activities.
- F. Any defective or improperly installed components shall be replaced with new materials at the expense of the Contractor.

1.10 MOCK-UPS

This part shall be read in conjunction with Clause 8.03 of Specification Preliminaries for the requirements for prototypes and trial areas.

1.11 TESTING

- A. The contractor shall submit a proposed testing method one month before completion of the installation work to the Architect for approval. The contractor shall propose at least one reliable and common testing method for demonstrating the performance of the installed system or material is in accordance with the contract requirements.
- B. The Architect can modify, or delete any test proposed by the contractor and request the contractor to perform additional test at the contractor's expenses if the contractor's proposal is considered not acceptable.
- C. The contractor shall arrange the field test work or any necessary drain tests and invite the Architect's representative to witness the test. Each test shall be recorded and submitted together with photo record in a consolidated report format within one week's time after the test to the Architect / Engineer for record, or to the relevant government department in accordance with the current statutory requirements.
- D. Catalogue and certificates of the sanitary wares selected showing the compliance with the local statutory requirement shall be submitted to the Architect for approval prior to ordering and installation.

1.12 WARRANTY

- A. This part shall be read in conjunction with Clause 8.04 of Specification Preliminaries for the list of material/ system requiring joint written guarantees.
- B. Special Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace toilet accessories that fail in materials or workmanship within specified warranty period.
 - 1. Failures include, but are not limited to, the following;
 - a. Structural failures including deflection exceeding 6.3mm
 - b. Faulty operation of hardware.
 - c. Deterioration of metals, metal finishes, and other materials.
 - 2. Warranty period: Five (5) years from date of practical completion.

1.13 SPARE PARTS

This part shall be read in conjunction with Clause 8.05 of Specification Preliminaries for the list of spares and spare parts.

PART 2 PRODUCTS

2.01 APPROVED MANUFACTURERS / SUPPLIERS

(NOT USED)

2.02 MATERIALS

- A. The Contractor shall include all necessary accessories and fittings to make the whole plumbing and drainage installation / system complete and functional and to the satisfaction of relevant government department / authorities and to the satisfaction of the Architect.
- B. Sanitary Fittings And Accessories
 - 1. Refer to drawing no. MC-CA-601 to MC-CA-602 for Sanitary Fitting Schedules and Specification.
- C. Material
 - 1. Brass: Rods, shapes, forgings, and flat products with finished edges; or castings.
 - 2. Fasteners: Screws, bolts, and other devices of same material as accessory unit and tamper-and-theft resistant where exposed, and of galvanized steel where concealed.
 - 3. Chrome Plating: BS ISO 1456, moderate service condition.
 - 4. Glass: Refer Division 08 "Glazing" for requirements.

2.03 FABRICATION

- A. General: fabricate units with tight seams and joints, and exposed edges rolled. Equip units for concealed anchorage and with corrosion-resistant backing plates.

PART 3 EXECUTION

2.01 EXAMINATION / INSPECTION

(NOT USED)

2.02 PREPARATION

(NOT USED)

2.03 INSTALLATION

- A. Install sanitary fittings and accessories according to manufacturers' written specification and instructions, using fasteners appropriate to substrate indicated and recommended by unit manufacturer.
- B. Install units level, plumb, and firmly anchored in locations and at heights indicate.

3.02 CLEANING

- A. Adjust accessories for unencumbered, smooth operation. Replace damaged or defective items.
- B. Remove temporary labels and protective coatings.
- C. Clean and polish exposed surfaces according to manufacturer's written recommendations

2.04 PROTECTION

- A. All installed fittings or accessories shall be protected properly from damage during the construction period.

2.05 MAINTENANCE

- A. Tool Kit

Provide six (6) sets of tools for use with security fastener, each packaged in a compartmented kit configured for easy handling storage.

END OF SECTION