

Architectural Particular Specification
TOILET CUBICLE
SECTION 10.6

Rev	Date	Description
0	13 MAY 2022	Tender Addendum No.2

SECTION 10.6

TOILET CUBICLE

PART 1 GENERAL

1.01 SUMMARY OF WORK

- A. The Contractor shall supply and install a proprietary panel partition system for all water closet, janitor's room and shower room as shown on drawings.

The system shall comprise 12mm compact laminate panel of impregnated homogenous core and homogeneously reinforced with up to 70% wood based fibers—all Kraft papers are manufactured using cellulose fibers as the base material.

The panel both sides plastic laminated veneer against melamine resin subjected to the combined action of pressure (9m Pa) and heat (150°C) in special presses (compiled with EN438) and scratch resistance for the cubicle's partition, door and pilaster, stainless steel skirting and ironmongery components specified in this document.

The whole installation works shall be carried out by a specialist contractor authorized by the manufacturer with relevant installation experiences in Hong Kong and shall be approved by the Architect.

1.02 REFERENCE

(NOT USED)

1.03 QUALITY ASSURANCE

(NOT USED)

1.04 PERFORMANCE REQUIREMENTS

- A. The cubicle system must satisfy the following international standard and certificates:

1. Greenguard indoor Air Quality Certified;
2. Carbon Trust's Carbon Reduction Label;
3. BS476 Part 6 and 7;
4. EN-438-2 -2016;
5. BS13823, BS ISO 11925-2, EN 13501-1, UL 94
6. ISO9001:2015,ISO14001:2015,OHSAS18001:2007

1.05 ENVIRONMENTAL REQUIREMENTS

(NOT USED)

1.06 ENVIRONMENTAL, CLIMATIC & PSYCHOMETRIC CONDITIONS

(NOT USED)

1.07 SUBMITTALS

- A. The Contractor shall submit detail shop drawings and sample modular unit showing the overall elevations, sections and every joinery details for Architect's confirmation of no adverse comment.
- B. Any adjustments to the size of panels and openings for pipe penetration and profile of back wall in order to suit the actual site condition shall be deemed to be included in the Contract Sum.

1.08 PRE-INSTALLATION CONFERENCE

(NOT USED)

1.09 DELIVERY STORAGE AND HANDLING

- A. Deliver compact laminate panels to Project site in manufacturer's original, labeled packaging, in undamaged condition.
- B. Store and handle compact laminate panel off the ground, under cover, and in a dry location to prevent their deterioration or damage due to moisture, temperature changes, contaminants, corrosion, and other causes. If units become wet, do not place until units are in an air-dried condition.
- C. Compact laminate panel too large to lift by hand shall be lifted with wide-belt slings; do not use wire rope or ropes that might cause staining. Move solid surfacing, if required, using dollies with cushioned wood supports.
- D. Compact laminate panel on pallets with non-staining separators and non-staining, waterproof covers. Ventilate under covers to prevent condensation.
- E. Protect materials from freezing and overheating in accordance with manufacturer's instructions.

1.10 MOCK-UPS

This part shall be read in conjunction with Clause 8.03 of Specification Preliminaries for the requirements for prototypes and trial areas.

1.11 TESTING

(NOT USED)

1.12 WARRANTY

- A. This part shall be read in conjunction with Clause 8.04 of Specification Preliminaries for the list of material/ system requiring joint written guarantees.

1.13 SPARE PARTS

This part shall be read in conjunction with Clause 8.05 of Specification Preliminaries for the list of spares and spare parts.

PART 2 PRODUCT

2.01 APPROVED MANUFACTURER

(NOT USED)

2.02 MATERIALS

- A. As specified in drawings and material schedules
- B. Toilet cubicles system is completed with 12mm thick (except otherwise specified) solid phenolic panel for door, pilaster and partition. The panel shall have impregnated homogenous black core with decorative and antimicrobial plastic laminate surface on both sides against melamine resin subjected to the combined action of pressure and heat in special presses (complied with EN438), side panel integrated with alarm wiring system for female toilet. Including all necessities in nylon and/or stainless steel ironmongeries & all in strict accordance to manufacturer's instruction.
- C. Corrosion Resistant Nylon and stainless steel Hardware
1. Recessed stainless steel headrail system with panel holder
 2. Gravity door hinges (self open / close at 30 degree)
 3. Recessed adjustable legs with steel core for reinforcement and floor leveling,
 4. Thumb Turn lock with indication and emergency opening
 5. Coat hook with rubber for doorstop function
 6. Flush door design
 7. Angle bracket for wall accommodation
 8. 100mm(H) pilaster base cover
- D. Anti-Bacterial
1. Anti-Bacterial Compact Laminates shall resist ten species of antibacterial which under JIS Z 2801:2000 Anti-microbial Efficacy Test Standard.
 2. Resist five species of fungus which under ASTM G21 – 9 fungus resistance test.
- Suede with two transparent overlays for better scratch resistance and produced by infusing each layer Melamine Resin impregnated wear layer.
- E. Dimension

Pilaster/Division Panel:	Refer to Drawings
Door Opening:	Refer to Drawings
Floor clearance:	150mmH (Max)
Hardware:	Nylon – Black, Grey, White Stainless Steel – Hairline finish to be submitted and approved by Architect
Panel Colour:	Wood pattern to be submitted and approved by Architect

F. Size of Cubicles

The width of the panels and doors shall be adjusted in accordance with overall wall to wall width and in any case the door clear width shall be kept to a minimum of 580mm wide and 750mm for disabled cubicle. The depth of the cubicle shall refer to the architectural drawings and in no case less than 1600mm. The height of the whole cubicle shall in no case be less than 2010 mm with the height to the bottom of panel above floor not more than 150mm. Full height of the partition panel shall attach to the back wall by following the wall profile. All panels shall be of one piece jointless construction.

Detailed dimensions refer to drawings.

G. Hardware

The system shall equip with nylon coated hardware with non-corroding iron with zinc electroplating material for its inner layer or stainless steel. Colour of the coating shall be submitted for Architect's approval. The hardware shall include:-

1. Recessed stainless steel headrail system with panel holder
2. Gravity door hinges (fully self open / close)
3. Recessed adjustable legs with steel core for reinforcement and floor levelling
4. Thumb Turn lock with indication and emergency opening
5. Coat hook with rubber for doorstep function
6. Flush door design
7. Angle bracket for wall accommodation
8. 100mm(H) pilaster base cover and all necessary accessories
9. They should resemble the following picture description in appearance: -



H. Cubicle Components

The surface of pilasters and cubicle doors shall be overlapped with rebate side edges so that there will be no open gap between the door and the pilaster when closed. No screws, brackets or hinges shall be seen from the outer side of cubicle.

I. Colour of Compact Laminate and Hardware

Colours of compact laminate and hardware shall be selected by the Architect from any of the standard colours and standard laminate range of plain colours, woodgrains & dust patterns, finished with fini velour or quarry finish that provides protection against abrasion at no extra cost.

Earliest submission of shop drawing and sample for Architect's comment shall be made by the contractor to ensure all necessary ordering and delivery to site of the Architect's chosen colour(s) will be carried out in accordance with the contractor's master programme. Limitation of Architect's choice of colours from the manufacturer's standard range due to late ordering and delivery schedule will not be accepted and any extra time and cost for delivery of the chosen colours will be at the contractor's own responsibility.

J. Sleeve for Concealed Conduit of Panic Alarm System

Built-in 10mm x 10mm sleeves for concealed conduits of panic alarm system shall be provided in the side panels of cubicle. These sleeves shall run horizontally connecting from ball wall to a suitable location for the panic alarm button.

2.03 ANCILLARY MATERIALS

(NOT USED)

PART 3 EXECUTION

3.01 EXAMINATION / INSPECTION

(NOT USED)

3.02 PREPARATION

(NOT USED)

3.03 INSTALLATION / APPLICATION

(NOT USED)

3.04 TOLERANCES

(NOT USED)

3.05 CLEANING

- A. In-Progress Cleaning: Clean countertops as work progresses. Remove adhesive, grout, mortar, and sealant smears immediately.
- B. Remove and replace cubicles of the following description:
 - 1. Broken, chipped, stained, or otherwise damaged surfacing.
 - 2. Defective joints, including misaligned joints.
 - 3. Surfaces and joints not matching selected samples.
 - 4. Surfaces not complying with other requirements indicated on Drawings.
- C. Replace in a manner that results in surfacing matching selected samples, complying with other requirements, and showing no evidence of replacement.
- D. Clean surfacing within 6 day after completion of sealant installation, using clean water and soft rags. Do not use wire brushes, acid-type cleaning agents, cleaning compounds with caustic or harsh fillers, or other materials or methods that may damage surfacing.

3.06 PROTECTION

(NOT USED)

END OF SECTION