

中國建築工程(香港)有限公司

標準工作程序

第十五號：機電安裝管理工作程序 (中文版)

編號：PRO/015

版本：第一版：2A

日期：2025 年 7 月



目 錄

1. 目 的
2. 範 圍
3. 參考資料
4. 定 義
 - 4.1 外部團體
 - 4.2 地盤監督
 - 4.3 工程師
 - 4.4 項目經理
 - 4.5 地盤代表
5. 操作程序
 - 5.1 材料/設備接收
 - 5.2 使用適當的測試設備
6. 測試與調試
 - 6.1 過程檢驗及測試與調試程序
 - 6.2 條款 7 內的測試與調試工作使用的表格
7. 項目管理計劃的準備
8. 標準表格

1. 目的

本程序旨在闡述適用於機電（E&M）及屋宇設備（BS）的安裝。

安裝工作包括以下內容：

- (a) 材料/設備接收與檢驗
- (b) 使用適當的測試設備
- (c) 檢驗、測試與調試
- (d) 項目管理計劃的準備

2. 範圍

本程序適用於所有空調、電氣、消防、低壓及超低壓、應急發電機及低壓配電制柜安裝工作

3. 參考資料

- 3.1 質量管理手冊
- 3.2 通用政府合約
- 3.3 英國屋宇設備測試與調試指南
- 3.4 建築署屋宇設備分部測試與調試程序
- 3.5 香港房屋署規範



4. 定義

- 4.1 外部團體
包括客戶及/或其代表、政府機關和公用事業公司、分包商和供應商。
- 4.2 地盤監督
被指定負責接收和檢查送達地盤的設備和材料的員工。
- 4.3 工程師
在項目經理的指導下，負責所有工程業務的員工。
- 4.4 項目經理
項目經理是指定的項目團隊領導者，承擔項目執行的管理和權限責任。項目經理應確保制定、維護並驗證項目管理計劃的實施。
- 4.5 地盤代表
地盤代表是所有地盤管理/協調問題的主要聯繫人，負責地盤的整體管理/協調，包括項目管理計劃的實施。



5. 操作程序

5.1 材料/設備驗收

- 5.1.1 地盤監督負責接收檢驗並保存相關檢驗記錄。
- 5.1.2 地盤監督驗證交付材料的質量合規性和數量，並在相關文件（表格 PMP-02）上簽字確認接受狀態，若發現質量缺陷需記錄備註。
- 5.1.3 對於特殊設備或機械（如冷水機組、配電櫃、發電機組等），製造商的出廠測試報告可作為符合質量要求的證明。
- 5.1.4 若無法在交付當日進行檢驗，地盤監督或項目工程師應在送貨單上記錄，並在交付後 14 天內完成檢驗。
- 5.1.5 若材料/設備被拒收，需記錄在表格 PRO5-07 中，並進行後續跟進。
- 5.1.6 所有交付到地盤且檢驗不合格的材料/設備，需在顯眼位置貼上“紅色”標籤。不符合質量要求的設備/材料需在 14 天內移除。
- 5.1.7 符合要求的材料應儲存在指定的儲存區域。



5.2 使用適當的測試設備

5.2.1 檢驗與測試設備的選擇

測試設備的使用在項目管理計劃中定義。選擇檢驗與測試設備時，需滿足以下標準：

- a. 設備的特定範圍和精度。
- b. 設備已按國際標準或指定要求校準。
- c. 校準有效期未過期。
- d. 設備適用於被測試的設備或材料。

5.2.2 檢驗與測試設備的批准與維護

5.2.2.1. 測試設備需經項目經理及客戶或其代表批准，批准記錄由項目經理保存。

5.2.2.2. 為確保檢驗/測試設備保持良好工作狀態，需在不使用時存放在指定位置，若發現設備損壞，需向地盤代表報告。

5.2.2.3 項目經理應編制項目測試與測量儀器/設備清單，納入項目管理計劃。



6. 測試與調試

6.1 檢驗、測試與調試程序

- 6.1.1 按合約規定進行檢驗與測試，以向客戶證明安裝工作符合指定要求，且性能符合設計條件。
- 6.1.2 項目經理負責從合約中識別檢驗與測試要求，並將相關信息傳達給項目人員執行。
- 6.1.3 項目經理應確保所有測試儀器按第 5.2 條款校準。
- 6.1.4 項目經理需向客戶及其他相關外部單位發出測試/調試見證邀請文件（如信函、備忘錄或電子郵件等）。
- 6.1.5 對於預調試測試，項目經理需提交測試與調試計劃及程序，包括方法聲明和空白測試/調試報告，符合項目要求。
- 6.1.6 對於需要連續運行測試的設備，測試/調試工程師需確保所有運行數據妥善記錄。
- 6.1.7 最終檢驗與測試工作在項目完成前進行。
- 6.1.8 項目經理負責安排必要資源進行最終檢驗與測試。
- 6.1.9 需由項目經理指派的工程師/單位負責檢驗/測試/調試：
 - a. 檢查並確認合同規定的所有檢驗與測試完成，安裝工作符合要求。
 - b. 確保所有檢驗與測試報告/結果妥善保存作為質量記錄。
 - c. 檢查合同中的所有工作完成，若有缺陷需整改。

6.2 測試與調試工作使用的表格包含在第 7 章中

7. Preparation of Project Management Plan

用於補充機電及建築服務安裝工作項目管理計劃準備的標準表格包括附件中的表格編號 PMP-01 至 PMP-18。

8. Standard Forms 標準表格

IFEE 001	-	Test Report For Motor Control Cubicle
IFEE 002	-	Inspection Report For Conduit/Trunking/Cable Tray/Cable Ladder Installation
IFEE 003	-	Inspection Checklist For Installation of L.V. Switchboard
IFEE 004	-	Inspection Report For Pump Installation
IFEE 005	-	Inspection Report For Earthing/Lightning Protection Installation
IFEE 006	-	Insulation Resistance & Earth Loop Impedance Test
IFEE 007	-	Tests on Emergency Generator Installation
IFEE 008	-	General Inspection, Testing & Commissioning of Burglar Alarm and Security System
IFAC 001	-	Inspection & Test For Pipework/Ductwork Installation
IFAC 002	-	Testing and Balancing of Air Distribution System
IFAC 003	-	Testing and Balancing of Chiller Water
IFFS 001	-	Inspection & Test of Fire Services Installation
PMP-01	-	Equipment/Material/Sample Submission Schedule
PMP-02	-	Inspection & Usage Record For Equipment/ Materials Delivered On Site
PMP-03	-	Equipment/Material Storage Plan
PMP-04	-	Drawing Submission Schedule
PMP-05	-	Site Memorandum
PMP-06	-	Facsimile Transmission
PMP-07	-	Letter of Transmittal
PMP-08	-	Query Sheet
PMP-09	-	Request For Inspection of Works
PMP-10	-	Site Instruction Record Sheet
PMP-11	-	Daily Report
PMP-12	-	Equipment/Material/Sample Submission Form
PMP-13	-	Sub-letting Plan
PMP-14	-	Method Statement Submission Plan
PMP-15	-	Use of Non-inspected Material/Equipment Record
PMP-16	-	Statistical Record of Non-conformity Found in Installation And Material/Equipment Inspection
PMP-17	-	Non-conformity Notice – Material/Equipment
PMP-18	-	Non-conformity Notice – Installation Works

註：為配合不同項目的要求，如經業主或其代表同意，上述標準表格可以變更。



TEST REPORT FOR MOTOR CONTROL CUBICLE

1. Visual Inspection

Mechanical Check

- | | |
|---|---------|
| 1.1 All earth bars connection inside panels completed. | _____ * |
| 1.2 All bolts and nuts, control wiring termination checked. | _____ |
| 1.3 Mechanical indication checked. | _____ |
| 1.4 ACB drawout position can be withdrawn freely from chasis. | _____ |
| 1.5 ACB chutes are fitted. | _____ |
| 1.6 Equipment are in good order and condition. | _____ |
| 1.7 All busbar sizes are in accordance with drawing no. _____ | _____ |
| 1.8 All segregation are in accordance with drawing no. _____ | _____ |
| 1.9 All equipment are fitted as per the approved drawing. | _____ |
| 1.10 Labelling. | _____ |

* Note : ✓ - Satisfactory
 X - Incomplete
 N/A - Not Applicable

Remarks :



TEST REPORT FOR MOTOR CONTROL CUBICLE

2. Operation & Inspection Test for Air Circuit Breaker Record

Panel No. _____

ACB No. _____

A. Air Circuit Breaker

2.1 Check information on name plates are completed. _____

2.2 Check ACB door lock function. _____

2.3 Rack ACB in and out, check freedom of movement. _____

2.4 Check the electrical on/off/trip operation of the circuit breaker both in "Service" and "Test" position _____

2.5 Check the manual on/off/trip operation of the circuit Breaker both in "Service" and "Test" position. _____

2.6 Check operation of shutter during racking ACB in an out. _____

2.7 Check on/off/trip indicator correct operation. _____

2.8 Check remote close and open ACB. _____

2.9 Check remote on/off/trip status. _____

2.10 Check remote other outgoing signals. _____

2.11 Check correct phase identification. _____

2.12 Check earthed condition of ACB. _____

B. Selector Switch

2.13 Operation/condition of ammeter selector switch & meter. _____

2.14 Operation/condition of voltmeter selector switch & meter. _____

* Note :
✓ - Satisfactory
X - Incomplete
N/A - Not Applicable

Remarks : _____



TEST REPORT FOR MOTOR CONTROL CUBICLE

3. Operation & Inspection Test of Switchgear Record

3.1 Close and open all fuse switches and isolators check freedom of movement.

*

3.2 Check mechanical interlock function.

3.3 Check correct labels fitted.

3.4 Check correct fuses fitted.

3.5 Check continuously of fuses.

* Note :
✓ - Satisfactory
X - Incomplete
N/A - Not Applicable

Remarks :



TEST REPORT FOR MOTOR CONTROL CUBICLE

4. Function Test of Starter

Panel No. _____

ACB No. _____

4.1 Check correct indicating light function.

*

4.2 Check local "Start"/ "Stop" function.

4.3 Check "Lamp Test" function.

4.4 Check remote "Start"/ "Stop" function.

4.5 Check remote on/off/trip status.

4.6 Check remote other outgoing signals.

4.7 Check O/L device operation.

4.7 Check O/L device operation.

* Note :
✓ - Satisfactory
X - Incomplete
N/A - Not Applicable

Remarks :



TEST REPORT FOR MOTOR CONTROL CUBICLE

5. Primary / Secondary Injection Test

(i) Overcurrent / Earth leakage Protection Relay Record

Panel No. _____

ACB No. _____

*

Equipment	Phase	Purpose	Type	Serial No.	Rating	Setting Range
I.D.M.T. UNIT	L1	O/C	TJM70		5A	50% - 200%
	L2	O/C	TJM70		5A	50% - 200%
	L3	O/C	TJM70		5A	50% - 200%
	N	E/F	TJM70		5A	50% - 200%



TEST REPORT FOR MOTOR CONTROL CUBICLE

5. (ii) Function Test of Starter

Panel No. _____ ACB No. _____

A. Duty : _____ MEASUREMENT (AMMETER) _____

Ratio : _____ VA _____ Class _____

Injection	Primary Current (A)	Secondary Current (A)				Ammeter Reading (A)			
		L1	L2	L3	N	L1	L2	L3	N
L1-L2									
L2-L3									
L3-L1									
L1-N									

B. Duty : _____ O/C PROTECTION _____

Ratio : _____ VA _____ Class _____

Injection	Primary Current (A)	Secondary Current (A)			
		L1	L2	L3	SPILL
L1-L2				-	
L2-L3		-			
L3-L1			-		

C. Duty : _____ E/F PROTECTION _____

Ratio : _____ VA _____ Class _____

Injection	Primary Current (A)	Secondary Current (A)		
		L1	N	SPILL
L1-N				



TEST REPORT FOR MOTOR CONTROL CUBICLE

5. (iii) Secondary Injection Test

Panel No. _____

ACB No, _____

A. I.D.M.T. Units Characteristics

Phase Injection	Relay Settings		Injected Current (A)	Operating Time (Sec)	
	Plug Setting	Time Setting	Secondary	Nominal	Actual
L1	100%	1	10	3.84	
			25	1.79	
			50	1.30	
L2	100%	1	10	3.84	
			25	1.79	
			50	1.30	
L3	100%	1	10	3.84	
			25	1.79	
			50	1.30	
E/F	100%	1	10	3.84	
			25	1.79	
			50	1.30	

B. The relays are being left at the following settings after tests

		L1-Phase	L2-Phase	L3-Phase	E/L
I.D.M.T.	Plug Setting	5	5	5	1
	Time Multiplier	1	1	1	1



TEST REPORT FOR MOTOR CONTROL CUBICLE

6. Ductor Test

Panel No. _____

Micro Ohm				
Phase Point	L1	L2	L3	NEUTRAL

Remarks :



TEST REPORT FOR MOTOR CONTROL CUBICLE

7. Insulation Resistance Record (1000V Meggar)

Panel/s : _____

Ambient Temperature _____ °C Relative Humidity : _____ %

	With all switching devices open (M ohm)	With all switching devices closed (M ohm)
L1 to E		
L2 to E		
L3 to E		
L1 to L2		
L2 to L3		
L3 to L1		
L1 to N		
L2 to N		
L3 to N		
E to N		

B. High Voltage Injection Test

Test Voltage : 2.5 KV AC

	Duration of Test (60 Sec)	Leakage Current (mA)
	With all switching devices closed	
L1 – I2 to L3 (E)		
L2 – L3 to L1 (E)		
L1 – L2 – L3 to E		



TEST REPORT FOR MOTOR CONTROL CUBICLE

8. Insulation Resistance Recorded after H.V. Injection Test

	With all switching devices closed (M ohm)
L1 to E	
L2 to E	
L3 to E	
L1 to L2	
L2 to L3	
L3 to L1	
L1 to N	
L2 to N	
L3 to N	
E to N	

Inspected by : _____ (CSMEEL)

Checked by : _____ (CSMEEL)

Witnessed by : _____ ()



標準工作程序

第一版：2A 日期：2025.07 機電安裝管理工作程序

第 20 頁

Form IFEE002

INSPECTION REPORT FOR CONDUIT / TRUNKING/ CABLE TRAY / CABLE LADDER INSTALLATION

Project : _____ Date : _____
Project Code : _____ Drawing No. : _____
Location : _____

Item	Checklist	Result*	Remarks
1	Material / Equipment		
2	Installation of Works		
3	Installation comply with approved drawings		
*4	Fittings, Elbows, Supports, etc. are connected properly		
*5	Wall / Floor Openings are sealed properly with fire resistant sealant		
6	No visible damage to Impair Safety		

Note : *1. Delete as appropriate
2. Use the following code for results or otherwise please specify in Remark column

S – Satisfactory
X – Incomplete
N.A. - Not applicable

Inspected by : _____ (CSMEEL)

Checked by : _____ (CSMEEL)

Witnessed by : _____ ()



標準工作程序

第一版：2A 日期：2025.07 機電安裝管理工作程序 第 21 頁
Form IFEE003/1

INSPECTION CHECKLIST FOR INSTALLATION OF L.V. SWITCHBOARD

Project : _____ Project Code : _____
Client : _____ Date : _____
Location : _____ Ref/Dwg No. _____

Item	Checklist	Result*	Remarks
1	Material / Equipment		
2	Installation comply with approved drawings.		
3	Connections between modular panels be bolted and tightened.		
4	Earth bar at bottom of each modular panel be connected.		
5	Protection from humidity and damages		
6	No visible damage to Impair Safety.		

Note : *1. Delete as appropriate
2. Use the following code for results or otherwise please specify in Remark column

S – Satisfactory
X – Incomplete
N.A. - Not applicable

Inspected by : _____ (CSMEEL)

Checked by : _____ CSMEEL)

Witnessed by : _____ ()



TEST CERTIFICATION OF L.V. SWITCHBOAFRD

Customer : _____

Board : _____

Manufacturer : _____

General Arrangement Drg. No. : _____

Main Busbar Current Rating : _____

Short Circuit Rating : _____

System Voltage : _____

Visual Test

All earthing completed _____

All nuts and electrical connections checked for tightness _____

Alignment of contacts mechanism correct and movement free on hand operation _____

Mechanical interlocking _____

Mechanical indication correct _____

Chassis enters cubicle without difficulty _____

Operation of auxiliary switches plugs & sockets correct _____

Equipment dust free and in good order _____

Arc chutes fitted correctly _____

The inter panels busbar connection links are correctly fitted _____

All alarms, control and indication circuits operate correctly in accordance with the diagrams listed below

Schematic diagram	_____	revision	_____
-------------------	-------	----------	-------

Schematic diagram	_____	revision	_____
-------------------	-------	----------	-------

Schematic diagram	_____	revision	_____
-------------------	-------	----------	-------

Schematic diagram	_____	revision	_____
-------------------	-------	----------	-------

Witnessed by : _____

Testing Engineer : _____

Date: _____

Date : _____



HIGH VOLTAGE INJECTION & INSULATION RESISTANCE TEST

Board : _____

Period : _____

Ambient temperature _____ °C Relative Humidity _____ %

Insulation Resistance (1000V megger)

	With all switching devices open (M ohm)	With all switching devices closed (M ohm)
L1 to earth		
L2 to earth		
L3 to earth		
L1 to L2		
L2 to L3		
L3 to L1		
L1 to N		
L2 to N		
L3 to N		
N to earth		

High Voltage Injection Test

Test Voltage KV AC

	Duration of Test (60 Sec.) with all switching devices closed
L1 – L2 to N3 – N (earth)	
L2 – L3 to L1 – N (earth)	
L1 – L2 – L3 - N3(earth)	



INSULATION RESISTANCE AFTER H.V. INJECTION TEST

	with all switch in devices closed (Mohm)
L1 to earth	
L2 to earth	
L3 to earth	
L1 to L2	
L2 to L3	
L3 to L1	
L1 to N	
L2 to N	
L3 to N	
N to earth	

Remarks :

Witnessed by : _____

Testing Engineer : _____

Date : _____

Date : _____



PRIMARY INJECTION TEST CHECK SHEET PROTECTON CURRENT TRANSFORMERS

Board _____

Panel _____ Circuit _____

Duty _____

Ratio _____ VA _____ Class _____

Serial No. L1 _____ L2 _____ L3 _____ N _____

Injection	Primary Current (A)	Secondary Current (A)			
		L1	L2	L3	SPILL
L1 – L2					
L2 - L3					
L3 – L1					

Duty _____

Ratio _____ VA _____ Class _____

Serial No. L1 _____ L2 _____ L3 _____ N _____

Injection	Primary Current (A)	Secondary Current (A)			
		L1	L2	L3	SPILL
L1 – L2					
L2 - L3					
L3 – L1					
L1 - N					

Witnessed by : _____ Testing Engineer : _____

Date : _____ Date : _____



PRIMARY INJECTION TEST CHECK SHEET METERING CURRENT TRANSFORMERS

Board _____

Panel _____ Circuit _____

Duty _____

Ratio _____ VA _____ Class _____

Serial No. L1 _____ L2 _____ L3 _____ N _____

Injection	Primary Current (A)	Secondary Current (A)			Ammeter Reading (A)			
		L1	L2	L3	L1	L2	L3	N
L1 – L2								
L2 - L3								
L3 – L1								
L1 - N								

Board									
Panel					Circuit				
Duty									
Ratio			VA			Class			
Serial No.	L1		L2		L3		N		
Injection	Primary Current (A)	Secondary Current (A)			Ammeter Reading (A)				
L1 – L2									
L2 - L3									
L3 – L1									
L1 - N									

Witnessed by : _____

Testing Engineer : _____

Date : _____

Date : _____



SECONDARY INJECTION TEST CHECK SHEET EARTH FAULT PROTECTION

Board _____

Panel _____ Circuit _____

I.D.M.T.L. UNIT		Propose	Type	Serial No.	Rating	Setting Range
	Neutral					

Nominal F.L. Current _____ C.T. Ratio _____

Mechanical Checks :

Check that all packing etc. are removed

Check that all screws & nuts are tight

Check that all relays are free from dust

Check that all shorting switches, isolating switches operate satisfactorily when the relays are withdrawn from their cases

Check that the disc units are free to operate

Check that the auxiliary units are free to operate

Check that the mechanical indicators operate & reset satisfactorily

Check that all contact surfaces are free of dirt & tamishing

Operation of Disc Units :

Current Setting		Starting Current	Operating Current	Resetting Current
Earth Fault	1A			



標準工作程序

第一版：2A 日期：2025.07 機電安裝管理工作程序

第 28 頁

Form IFEE003/8

I.D.M.T. Unit Characteristic

Phase Injection	Relay Settings		Injected Current (Amp)		Operating Time (Sec)	
	Plug Setting	Time Setting	Primary	Secondary	Nominal	Actual
E/F						

The relays are left at the following settings :

		L1-Phase	L2-Phase	L3-Phase	Earth Fault
I.D.M.T.	Plug Setting				
	Time Multiplier				
Instantaneous Setting					

Operation of the relay result in correct operation of appropriate trip relay/trip coil

Witnessed by : _____

Testing Engineer : _____

Date : _____

Date : _____



SECONDARY INJECTION CHECK SHEET OVERCURRENT / EARTH FAULT PROTECTION

Board _____

Panel _____ Circuit _____

Equipment	Phase	Purpose	Type	Serial No.	Rating	Setting Range
I.D.M.T. Unit	L1-Phase	O/C				
	L2-Phase	O/C				
	L3-Phase	O/C				
	Neutral	E/F				

Nominal F.L. Current _____ C.T. Ratio _____

Mechanical Checks :

Check that all packing etc. are removed _____

Check that all screws & nuts are tight _____

Check that all relays are free from dust _____

Check that all shorting switches, isolating switches operate satisfactorily when the relays are withdrawn from their cases _____

Check that the disc units are free to operate _____

Check that the auxiliary units are free to operate _____

Check that the mechanical indicators operate & reset satisfactorily _____

Check that all contact surfaces are free of dirt & tarnishing _____

Operation of Disc Units :

Current Setting		Starting Current	Operating Current	Resetting Current
L1-Phase				
L2-Phase				
L3-Phase				
Earth Fault				



標準工作程序

第一版：2A 日期：2025.07

機電安裝管理工作程序

第 30 頁

Form IFEE003/10

I.D.M.T. Units Characteristic

Phase Injection	Relay Settings		Injected Current (Amp)		Operating Time (Sec)	
	Plug Setting	Time Setting	Primary	Secondary	Nominal	Actual
L1						
L2						
L3						
E/F						

Remarks :

The relays are left at the following settings :

		L1-Phase	L2-Phase	L3-Phase	Earth Fault
I.D.M.T.	Plug Setting				
	Time Multiplier				
Instantaneous Setting					


Operation of the relay result in correct operation of appropriate trip relay / trip coil

Witnessed by : _____

Testing Engineer : _____

Date : _____

Date : _____

[illegible]



標準工作程序

第一版： 2A 日期： 2025.07

機電安裝管理工作程序

第 33 頁

Form IFEE004

INSPECTION REPORT FOR PUMP INSTALLATION

Project Title : _____

Date : _____

Location : _____

Drawing No. : _____

Project Code : _____

Item*	Result*	Remarks
Preliminary Check :-		
Pump Ref. No.:		
Mounting slab in position		
Water line connection in order		
No visible water leakage		
Machine Levelled		
Bearings Clean		
Anti-Vibration Mountings Fitted Correctly		
Pump Lubricated		
Motor Lubricated		
Glands Packed and Adjusted		
No Pipe Stress on Connections		
Rotates Freely by Hand		
Suction Valve Open		
Pump Flooded and Vented		
Coupling or Belt Guards Fitted		
Alignment Check		
PUMP RUNNING CHECKS:		
Pump Discharge Pressure (KPa)		
Rotation Correct		
Gland Adjustment		
Vibration		
Valves Open Running Current (amps)		

Note : *1. Delete As appropriate

2. Use the following code for results or otherwise please specify in Remark column

S – Satisfactory

N.C. – Not complete

U – Unsatisfactory

N.A.- Not applicable

Checked By :	(CSMEEL)
Witness By :	(CSMEEL)
Certified By :	
Comments :	



INSPECTION REPORT FOR EARTHING / LIGHTNING PROTECTION INSTALLATION

Project Title : _____ Date : _____
Location : _____ Tested By : _____ (CSMEEL)
Project Code : _____ Witnessed By : _____ (CSMEEL)

Item	Check List	Result	Remarks
1	Material		
2	Installation of works		
3	Installation comply with approval drawings		
4	Warning label are properly		
5	All exposed metal parts are properly bonded & connected to earthing terminal		
6	No visible damage to impair safety		

Earth Electrode Resistance Test

Electrode Type Size	Location	X - Y	X - Z	X - Z	Resistance Of X (Ω)	Copper Earth Tap Size	Ground Condition

X - Earth Electrode Under Test

Y - Auxiliary Earth Electrode

Z - Auxiliary Earth Electrode installed midway between X & Y with a distance of 15mx2
mid way from X & Y
Second auxiliary electrode installed 6 meters nearer to X.
"Ditto" but 6 meters further to X.

Acceptance Value:

The mean value of the three test results obtained in points X-Y, X-Z₁&X-Z₂.



INSULATION RESISTANCE & EARTH LOOP IMPEDANCE TEST

Project Title : _____ Project Code : _____

Client : _____ Date : _____

Location : _____ Ref/Drg No : _____

Instrument Used : _____ Serial No : _____ Testing Voltage : _____

Circuit Ref.	Phasing RYBN	Insulation Resistance (Megohms)								Earth Loop Impedance (Ω)		
		Phase to Earth				Between Phase				From	To	(Ω)
		L1-E	L2-E	L3-E	N-E	L1-L2	L2-L3	L1-L3	L1-L3- L2/N			
Incoming												
Outgoing Circuits												

Acceptance Value :

1) Not less than 1 Megohms For :

- Insulation to earth with all fuses in place, switch closed (including mains switch if practicable) and all phases or poles conductors connected together (Not applicable to TN-C System)
- Insulation between any two-poles or phase conductors, with all lamps removed and apparatus disconnected, but all switches closed

2) Not less than 0.5 Megohms For :

- Insulation of fixed apparatus that is practicable to disconnect for test, between case of framework and all normally live parts (tested separately) and between poles or phase

Inspected By : _____ (CSMEEL)

Checked by : _____ (CSMEEL)

Witnessed by : _____ ()



TESTS ON EMERGENCY GENERATOR INSTALLATION

Project Title	:			
Client	:			
Generator No.	:		Ref	:
Date Test Started	:		Time	:
Date Tested Completed	:		Time	:
Hour Meter	:		From	:
			To	:
Test Instruments Used		Model	Serial No.	
(1) Equipment Details :				
a.	Generator Set			
1.	Manufacturer			
2.	Model			
3.	Net Prime Rating (MCR) (KW)			
	Diesel Engine			
1.	Make			
2.	Model No.			
3.	Serial No.			
4.	Rated Power (KW)			
5.	Speed (RPM)			
6.	Governor			
7.	Turbocharger (Type/ Model)			
b.	Alternator			
1.	Make			
2.	Model No.			
3.	Serial No.			
4.	Rated KVA			
5.	Voltage (V)/ Full Load Current (A)			
6.	Phase/ Rated P.F.			
7.	Insulation Class			
	Authorized Representative From	Name	Signature	Date
1.	Genset Contractor			
2.	CSMEEL			
3.	Main Contractor			
4.	Owner / Client			



TESTS ON EMERGENCY GENERATOR INSTALLATION

c.	Starting Battery		
1.	Manufacturer		
2.	Make / Model No.		
3.	No. of Battery / Voltage (V)		
4.	Ampere Hour		
5.	Starting Time (Sec)		
d	Lifting Hoist		
1.	Manufacturer		
2.	Make / Model No.		
3.	Safe Working Load (Kg)		
4.	Lifting Height (m)		
5.	Test Certificate		
.			
e	Other Accessories		
1.	Nameplate of Manual by Pass Switch		
2.	Nameplate of Auto changeover Switch		
.(II) Type Control			
1.	Starting		
2.	Loading Transfer Generator		
3.	Stopping		
4.	Load Transfer for Mains		
(III) Insulation Resistance Test (Temporarily Open Alternator Star Point)			
1.	L1 Phase to Earth	Megaohm	
2.	L2 Phase to Earth	Megaohm	
3.	L3 Phase to Earth	Megaohm	
4.	L1 Phase to L2 Phase	Megaohm	
5.	L2 Phase to L3 Phase	Megaohm	
6.	L3 Phase to L1 Phase	Megaohm	
	Authorized Representative From	Name	Signature
1.	Genset Contractor		
2.	CSMEEL		
3.	Main Contractor		
4.	Owner / Client		



TESTS ON EMERGENCY GENERATOR INSTALLATION

(IV) Visual Inspection				
a	Pre-starting Check List			Remarks
1.	Fuel Oil Tank Level			
2.	Battery Charge			
3.	Frequency Meter			
4.	Frequency Meter			
5.	Silencer			
6.	Radiator Exhaust			
7.	Discharge Flute			
8.	Vibration Mounting			
9.	Belt Tension			
10.	Coolant Level			
11.	Lub. Oil Level			
b	Initial Manual Starting No. Load Test Check List			
1.	Time Duration			
2.	Battery Charge			
3.	Frequency Meter			
4.	Hour Recorder			
5.	Ammeter			
6.	Voltmeter c/w Phase Selecting Switch			
7.	Oil Pressure Gauge			
8.	Water Temperature Gauge			
9.	Tachometer			
10.	Output Voltage of Dynamo			
	Authorized Representative From	Name	Signature	Date
1.	Genset Contractor			
2.	CSMEEL			
3.	Main Contractor			
4.	Owner / Client			



TESTS ON EMERGENCY GENERATOR INSTALLATION

(V) Control Function Test					
			Function Test	Setting	Remarks
1. Starting	Manual				
	Simulate	Test 1*			
	Main Failure	Test 2**			
	Delay Start Timer				
	Delay Repeat Timer				
2. Stopping	Manual				
	Resumption of Mains**				
	Delay Stop Timer**				
3. Engine Protection	Overload Trip (MCC)	HL			
	Engine Overspeed/ Speed	LL			
	Low Lub-Oil Pressure (kpa)	HL			
	High Water Temperature	LL			
	Under Voltage Trip	HL			
	Over Voltage Trip	LL			
	Engine Failure to Start				
4. Others	Response Time From Mains				
	Failure to Changeover(sec.)				
	Battery 3 Attempt Start				
	Quick Closing Mechanism				
	Governor Function				
	Voltage Regulator (346-380V)				
	Auto-starting of Vent. Fan				
	Manual Override Facilities				
	Phase Sequence of Alternator Output				
	Frequency Setting				
	Authorized Representative From	Name	Signature	Date	
1.	Genset Contractor				
2.	CSMEEL				
3.	Main Contractor				
4.	Owner / Client				



TESTS ON EMERGENCY GENERATOR INSTALLATION

Legend	
*	Refer to function test on capability to start & transfer load to generator automatically.
**	Refer to function test on capability to start but w/o load transfer if mains resumes during engine starting.
***	Refer to function test on capability to automatic transfer load back to mains automatically after a preset time delay and immediately back to generator if mains fail within the above time delay period.
****	Refer to function test on capability to cool engine for a preset period after load is transferred to mains.
(√)	Denotes satisfactory remarks.
(x)	Denotes unsatisfactory remarks.
(NC)	Denotes not complete remarks.
(NA)	Denotes not applicable remarks.

	Authorized Representative From	Name	Signature	Date
1.	Genset Contractor			
2.	CSMEEL			
3.	Main Contractor			
4.	Owner / Client			



TESTS ON EMERGENCY GENERATOR INSTALLATION

VI. Dummy Load Test							
Time From Start		1/	/2	1	1	1	1/2
Duration (HR) (minimum)							
Duration (HR) (actual)							
(Frequency (Hz)							
Current (Amp)	L1						
	L2						
	L3						
Voltage (Volt)	L3-L2 / L1-N						
	L2-L3 / L2-N						
	L3-L1 / L3-N						
Dummy Load	KW						
	% Full Load	0	25%	50%	75%	100%	110%
Engine Speed (RPM)							
Cooling Water Temperature							
Engine Oil Temperature (°C)							
Engine Oil Pressure (kPa)							
Fuel Oil Consumption (L)							
Engine Room Temperature (°C)							
Noise (dB)							
Duration							
VII. Earthing Protection Test							
Measured Earthing Resistance							
Earthing Relay :				Current Setting			
Make				Time Setting			
Model				Function Test			
Serial No.							
Rated Current							
VIII Phase Sequence Test :							
Phase Sequence :				Remarks			
	Authorized Representative From	Name	Signature	Date			
1.	Genset Contractor						
2.	CSMEEL						
3.	Main Contractor						
4.	Owner / Client						



標準工作程序

第一版： 2A 日期：2025.07 機電安裝管理工作程序

第 42 頁

Form IFEE007-7

IX Diesel Generator Test Report																		
Project :		Hour Meter								Plant Serial No.								
Genset Mode :		From :				Function :				Job :			Phase :					
Diesel Engine :		To :				Rating :				Voltage :			Frequency :					
Alternator :						Rating :				Date :			AMP/PH :					
Time	Minute	Engine Temperature(°C)				Oil Press. (PBSI)	Batt. Amps	Speed Rpm	Freq Hz	Volts			Ampers			Load		
		Amb	Out/Eng	In	Oil					L1/L2	L2/L3	L2/L3	L1	L2	L3	KW	KVA	FL %
Authorized Representative From		Genset Contractor				CSMEEL				Main Contractor			Owner / Client					
Name																		
Signature																		
Date																		



GENERAL INSPECTION, TESTING AND COMMISSIONING OF BURGLAR ALARM AND SECURITY SYSTEM

Project Title	:	
Client	:	
Location	:	
Project	:	
Date	:	

A.General

A.1 Detection Devices

Item	Check (where applicable)	(√) Satisfactory (x) Unsatisfactory (NC) Not Completed (NA) Not Applicable	Remarks
1.	Carry out operational test on all devices to confirm that sensitivity is adequate for intended purpose		
2.	Devices have not been obstructed by the room contents		
3.	Protected items/ areas are properly covered by detection devices		
4.	Operation of each device is confirmed, with correct alarm signal indicated in the monitoring panel		
5.	Each device is securely fixed and not subject to vibration		
6.	Each device is secured with protection cover, if specified		
7.	Outdoor devices are protection by weatherproof housing and the sealing gaskets are intact and effective		
8.	Each door / window protected are properly erected and fixed		
9.	For infra-red device, and acclimatization period of up to 24 hours has been allowed		
10.	Magnetically operation devices are not interfered by the external magnetic field applied		
11.	Vibration devices have been checked for correct sensitivity with the extant background vibration		



GENERAL INSPECTION, TESTING AND COMMISSIONING OF BURGLAR ALARM AND SECURITY SYSTEM

A.2 Interconnecting Wiring

Item	Check (where applicable)	(√) Satisfactory (x) Unsatisfactory (NC) Not Completed (NA) Not Applicable	Remarks
1.	Detection circuit and associated wiring are installed within protected area in steel conduit system		
2.	All junction boxes are protected by anti-tamper micro switches		
3.	Insulation resistance of cables or wiring with all detection devices and alarm panels disconnected have been measured		
4.	Insulation resistance between wire to earth not less than 1 megaohm		
5.	Insulation resistance between wire to wire not less than 1 megaohm		
6.	Deletion devices loop resistance to each circuit measured and confirmed to be acceptable for the system		
7	Testing of any alarm signal in the remote control center (connection of telephone link) has been carried out		

A.3 Central Control Unit

Item	Check (where applicable)	(√) Satisfactory (x) Unsatisfactory (NC) Not Completed (NA) Not Applicable	Remarks
1.	All lamps have been checked and in proper working order		
2.	Each detection device had been checked to correspond to the correct alarm zone		
3.	The correct function of reset switch of each zone has been checked		
4.	The central control unit is installed within the protective area		
5.	Detailed site plan with zone indication has been provided		
6.	Fault attendance telephone no. and the log book have been provided		
7	The correct function of the isolation switch of the control unit to disconnect all detection device, if provided, has been check		
8	The housings of the control unit are firmly secured in position and are fitted with tamper detection		



GENERAL INSPECTION, TESTING AND COMMISSIONING OF BURGLAR ALARM AND SECURITY SYSTEM

A.4 Standby Power System

Item	Check (where applicable)	(√) Satisfactory (x) Unsatisfactory (NC) Not Completed (NA) Not Applicable	Remarks
1.	The charger is connected to the mains supply through an unswitched fused spur unit		
2.	The battery connections have been connected properly		
3.	Visual inspection of instruments, indicating lamps, fuses and relays on battery charger has been carried out		
4.	For initial set up, charge the batteries at the highest rate until the charging current has remained constant		
5.	Measure charger output with batteries (but not load) disconnected. This should be between 110% to 115% of the normal batteries voltage		
6.	Measure charger current with battery (but not load) disconnected. This should be less than the maximum recommended continuous charge current for the batteries		
7.	Interrupt mains input to the charger and check that proper operation of detection equipment continues on standby batteries		
8.	Confirm correct function of charge fail/ mains fail indication where provided		
9.	Restore mains supply and check that charge fail/ main fail indications are off and that "Mains On" indication is restored		

	Authorized Representative From	Name	Signature	Date
1.	Genset Contractor			
2.	CSMEEL			
3.	Main Contractor			
4.	Owner / Client			



標準工作程序

第一版： 2A 日期： 2025.07 機電安裝管理工作程序

第 46 頁

Form IFAC001/1

INSPECTION & TEST FOR PIPEWORK / DUCTWORK INSTALLATION*

Project : _____ Date : _____
Project Code : _____ Drawing No. : _____
Location : _____

A. Visual Inspection

Item	Check List	Result	Remarks
1	Material / Equipment		
2	Installation of Work		
3	Installation Comply with approved drawings		
4	Fittings, Elbows, Joints etc. are properly connected		
5	Pipework supported are property placed at distance in accordance to specification and drawing requirements.		
6	Ductworks sizes are made in accordance to approved shop drawings		
7	Ductworks are constructed in accordance to approved detailed drawings		
8	No visible damage to Impair Safety.		

B. Hydraulic Test for Pipeworks

Type of system : _____
Test Medium : _____
Design pressure : _____ Bar
Testing pressure _____ Bar
1st reading _____ (Bar) date _____ Time _____
2nd reading _____ (Bar) date _____ Time _____
Results/Remarks : _____



INSPECTION & TEST FOR PIPEWORK / DUCTWORK INSTALLATION*

C. Air Leakage Test for Duct Work

Measuring Equipment	:	_____	
Test Static Pressure	:	_____	(Pascals)
Leakage Factor	:	_____	(L/S/m ³)
Surface area of of Duct Under test	:	_____	(m ³)
Maximum Permitted Leakage	:	_____	(L/S)
Duct Static Pressure	:	_____	(Pascals)
Measured air Leakage	:	_____	(L/S)
Duration of Test	:	_____	(Minutes)
Results / Remarks	:	_____	

Note : * Delete items or section as appropriate

1. Section B for pipeworks and Section C for Ductwork
2. S – Satisfactory N.C. – Not complete
U - Unsatisfactory N.A. - Not applicable
Result will be satisfactory when measure air leakage is less than maximum permitted leakage.
- 3.

Inspected by : _____ (CSMEEL)

Checked by : _____ (CSMEEL)

Witnessed by : _____ ()



標準工作程序

第一版： 2A 日期： 2025.07 機電安裝管理工作程序

第 48 頁

Form IFAC002

TESTING AND BALANCING OF AIR DISTRIBUTION SYSTEM

Project : _____

Date : _____

Project Code : _____

Drawing No. : _____

Location : _____

Area	Duct Size	Trial No	T.P. No	Measured Value CuM/S				(A) Average Value (CuM/S) 1-4	(B) Design Value (CuM/S)	(A) -x 100% (B)	Remarks
				1	2	3	4				

Attach Balancing Sketch Necessary

Prepared by: _____

(CSMEEL) Witnessed by: _____

Certified by: _____

Witnessed by: _____

Date: _____

Date: _____



TESTING AND BALANCING OF CHILLED WATER SYSTEM

Project : _____

Date : _____

Project Code : _____

Drawing No. : _____

Location : _____

Water	Pumps Operating	Design Flow Rate (L/S)	Pressure Drop (KPa)	Valve Setting	Flow Rate (L/S)	Pressure Drop (KPa)	Valve Setting	Remarks

Prepared by: _____

(CSMEEL) Witnessed by: _____

Certified by: _____

Witnessed by: _____

Date: _____

Date: _____



INSPECTION & TEST OF FIRE SERVICES INSTAALLATION

Project : _____

Date : _____

Project Code : _____

Tested By. : _____

Location : _____

Witnessed By: _____

A.Pump Test

Use Form IFEE004 for fixed pump intermediate Booster pump, tester pump and sprinkler pump.

B.Pipeworks hydraulic test for Fire Hydrant and Hosereel

Date	Location / Section	Start		End		Duration (min)
		Time	Pressure (KPa)	Time	Pressure (KPa)	

C.Flow capacity and range of hosereel

Location of Highest Hosereel of a branch	Floor Level	Riser No.	Range (m)	Flow rate (l/min)

INSPECTION & TEST OF FIRE SERVICES INSTALLATION

D.Flow capacity & pressure of fire hydrant

[illegible]

* Static pressure with the pump off at the topmost outlet are recorded.

E Hydraulic tests for sprinkler installation.

[illegible]



INSPECTION & TEST OF FIRE SERVICES INSTAALLATION

F. Test for fire alarm detection and control installation

		Control Panel			Remarks
Location of call point	Location of alarm bell sound	Zone no. & identification #/on/off	Buzzar on/off	Fire pump on/off	


G. Test for street hydrant installation.

		Pressure					Flow Rate	
Date	Location of street hydrant	Start		End		Duration (min)	Flow rate* (l/s)	Remarks
		Time	Pressure (KPa)	Time	Pressure (KPa)			

* Flow rate of two farthest outlet discharging simultaneously.

H. Test for Automatic Gas Flooding System

Testing Format to be specified in Project Management Plan.



Form: PMP-01

[illegible]



標準工作程序

第一版： 2A 日期：2025.07 機電安裝管理工作程序

第 54 頁

Form: PMP-02

INSPECTION & USAGE RECORD FOR EQUIPMENT/ MATERIALS DELIVERED ON SITE

Project :
Services :
Supplier/Subcontractor :

Ref No :
Date :
Page : of

Item	Description	Make/O rigin	Qty	Rec'd by Date	P.O./D.O. (Ref No)	Issuance to worker/subcontractor					Remarks*	Prepared by Site Rep	
						Date	Qty		Issued to	Storage Location			Authorized Signature
							Out	Bal					

Remarks: _____

*LEGEND: AA- Accepted All
IP- Inspection Pending
AC- Accepted with Condition
RR- Rejected and hold for Removal
✓- Approved material
x- Non-approved material

1. Inspected by: _____ Date: _____
CSMEEL's site representative
2 Inspected by: _____ Date: _____
Client Representative

Copy to : Head Office / Site Office

* Approved relevant equipment/material submission must be attached with this Inspection Sheet



EQUIPMENT / MATERIAL STORAGE PLAN

Project Site: _____

Installation: _____

Item No.	Material / Equipment	Storage Requirement	Stored Location	Responsible Person

Prepared By: _____ Approved By: _____

Date: _____ Date: _____



Project :					Date :				
Services :					Rev :				
					Page :				
<u>Drawing Submission Schedule</u>									
Drawing No	Drawing Title	Rev	Expected Submission Date	Expected Approval Date	Actual Submission Date			Actual Approval Date	Drawing Status
					Comment Returned Date				
					1 st	2 nd	3 rd		

Legend: Drawing Status indicated the current stamp on the drawing, i.e.


1 - For Approval

2 - For Reference/information

3 - For Construction

4 - Superseded

**) “ against each Revision of drawing verify the relevant Project Manager/ Engineering Manager has checked & signed on the drawing.



Re :

[illegible]

Project Manager / Site Representative

Copy To							H.O.
w/ encl.							
W/o encl.							



To	:	Ref.	:	CSME/
Attn.	:	Date	:	
Project	:			
Services	:	Installation		

☐ Drawings ☐ Letters ☐ Reports
☐ Catalogues ☐ Samples ☐ Others ()

[illegible]

For and on behalf of CSMEEL

Project Manager / Site Representative

Copy To							H.O./ S.O.
w/ encl.							
W/o encl.							



標準工作程序

第一版： 2A 日期：2025.07 機電安裝管理工作程序

第 60 頁
Form: PMP-08

QUERY SHEET					Ref No :			
Contract No :								
To :					Attn :			
Query :		Architectural / Structural / Building Services			* delete as appropriate			
Kindly let us have your reply before :								
Date :					Raised by:			
Initialed by					Project Manager/Site Representative for Chain State Mechanical & Electrical Engineering Ltd.			
REPLY :								
Date :					Signed : ()			
Copy to:								H.O./S.O.
w/encl.								
Answer to:								



標準工作程序

第一版： 2A 日期： 2025.07 機電安裝管理工作程序

第 61 頁
Form: PMP-09

Project :

Trade: _____	Ref No : _____	To: _____
_____	Drawing No : _____	_____
_____	Date : _____	_____
(sub-contractor)	Time : _____	_____
China State Mechanical & Electrical Engineering Ltd . (contractor)	_____	_____

REQUEST FOR INSPECTION OF WORKS

The following works has been completed to our satisfaction and will be ready for inspection on

Date & Time _____ at _____ a.m./p.m.

Location : _____

Description of Work : _____

Nature of check : _____

Work proposed after inspection : _____ on _____ at _____ a.m./p.m.

Signed (_____) for (sub-contractor)

Signed (_____) for China State Mechanical & Electrical Engineering Ltd.

B.S.I.'s comments: Inspected with Mr. _____ on _____

- ☐ Inspection passed.
- ☐ Inspection waived.
- ☐ Inspection was not passed and re-inspection is required/not required before covered up.
- ☐ Defects/ Findings not complied with contract requirement are listed on attached sheet ref. : _____
- ☐ Defects / Findings not complied with contract requirement are listed below:


Signed	Designation	Date
--------	-------------	------

Return to CSMEEL	on _____	at _____ a.m./p.m.
------------------	----------	--------------------

Received for CSMEEL	on _____	at _____ a.m./p.m.
---------------------	----------	--------------------

Distribution :

☐	☐	☐
☐	☐	☐



Project :
Ref. No. :
Trade :

[illegible]



標準工作程序

第一版： 2A 日期： 2025.07 機電安裝管理工作程序

第 63 頁
Form: PMP-11

DAILY LABOUR REPORT

Project : Ref. :
Contract No. :
To : Attn. :
Service : Date :
Sub-contractor :

WORK TRADE		NO. OF PERSONS										
JOB REF.		1	2	3	4	5	6	7	8	9	10	TOTAL
		TOTAL :										
REF.	JOB DESCRIPTION								FLOOR		LOCATION	
MATERIAL/ EQUIPMENT DELIVERED ON SITES												
REMARKS												
Reported by :						Endorsed by :						
For and on behalf of Sub-contractor						For and on behalf of CSMEEL						



Equipment / Material / Sample Submission Form

Project : Ref. No. :
Date :
Services :
To : (1)
Attn. : (2)

Details of Submission

The material/sample as described below has been checked for compliance with the specifications and drawings, and is herewith submitted for approval.

- (a) Description : _____
(b) Manufacturer/Supplier : _____
(c) Brand/Model No. : _____
(d) Catalogue/Sample : _____
(e) Test Report/Certificate : _____
(f) Location : _____
(g) Expected Approval Date : _____

Submitted By : _____

Project Manager / Site Representative
For and on behalf of CSMEEL

Comment :

On the basis of the information given, the submitted material/sample is:

- (A) Approved
(B) Approved subject to _____

- (C) Not approved for the reason of _____

Architect's / Consultant's Representatives

Project Architect/ Consultants

Date :

Copy to :							H.O./S.O.
w/ encl.							



SUB-LETTING PLAN

Project Site : _____

Installation : _____

Item No.	Description	Target Sub-letting Date	Actual Sub-letting Date	Appointed Supplier/ Subcontractor	LI/ PO/ Subcontract Ref.

Prepared By : _____

Approved By : _____

Date : _____

Date : _____



Method Submission Form

Project Site : _____

Installation : _____

Item No.	Description of Method Statement	Responsible Engineer/ Person	Target Submission Date	Actual Submission Date	Comment Date	Approval Date

Prepared By : _____

Approved By : _____

Date : _____

Date : _____



USE OF NON-INSPECTED MATERIAL/ EQUIPMENT RECORD

Project Site : _____

Installation : _____

Item	Before Inspection Record				After Inspection Record				Responsible Person
	Material/ Equipment	Qty	Location of Use	Date of Use	Inspection Date	Result of Inspection	Inspection Record Ref.	Follow Up Action	

Prepared By : _____

Approved By : _____

Date : _____

Date : _____



STATISTICAL RECORD OF NON-CONFORMITY FOUND IN INSTALLATION & MATERIAL EQUIPMENT INSECTION

Project Site : _____

Installation : _____

Year	Non-conformity Found		Responsible Person
	Material/Equipment	Installation	
Month	Description	Description	

Prepared By : _____ Approved By : _____

Date : _____ Date : _____



NON-CONFORMITY NOTICE - MATERIAL/ EQUIPMENT

Project Site : _____

Ref. No. : _____

Installation : _____

Date : _____

To: _____ (Supplier)

We have found some major defects in your supplied materials/ equipment. Please take immediate rectification as per our instruction detailed in Part 1 below.

Responsible Person : _____

Date : _____

Part 1

Material/ Equipment Description	Major Defects Found	Rectification Required
		Before (date)
Responsible Person : _____ Date : _____		

Part 2

Follow Up Action Report	
* ☐	Rectification work was found completed satisfactorily on _____ (date)
* ☐	Defective material/ equipment was removed from site on _____ (date)
* Tick as appropriate.	
Responsible Person : _____ Date : _____	

c.c. Head Office



NON-CONFORMITY NOTICE – INSTALLATION WORKS

Project Site : _____

Ref. No. : _____

Installation : _____

Date : _____

To: _____ (Sub-contractor)

We have found some major defects in your installation work. Please take immediate rectification as per our instruction detailed in Part 1 below.

Responsible Person : _____

Date : _____

Part 1

Details of Major Defect Found	Location	Rectification Required
		Before _____ (date)
Responsible Person : _____ Date : _____		

Part 2

Follow Up Action Report	
* ☐	Rectification work was found completed satisfactorily on _____ (date)
* ☐	Defective material/ equipment was dismantled and removed from site on _____ (date)
* Tick as appropriate.	
Responsible Person : _____ Date : _____	

c.c. Head Office