

BIA Stakeholder Workshop Summary

Business Process: Customer Outage Management & Restoration

Process Flow: Detect outage > Validate > Dispatch crews > Restore service > Verify restoration > Communicate with customers

Business Owner: Director, Grid Operations

Criticality: Tier 1 — Mission Critical

Key Business Functions

Business Line	Primary Responsibility
Grid Operations	Lead outage response, dispatch crews, restore power safely
IT Infrastructure	Ensure critical systems, including SCADA, OMS, and networks, remain operational and recover quickly
Customer Operations	Manage customer communications, outage updates, call centre operations, and public messaging

The process requires close coordination across Grid Operations, IT Infrastructure, and Customer Operations, with Grid Operations leading the response, IT enabling critical systems, and Customer Operations managing the public response.

Key Business Impacts

If the process is unavailable:

- **Operational:** Restoration delays and increased manual work
- **Customer:** High call volumes, service disruption, and loss of customer confidence
- **Financial:** Increased overtime costs and potential revenue loss
- **Regulatory:** Increased regulatory scrutiny and potential compliance impacts
- **Public Safety:** Delayed restoration affecting critical infrastructure and vulnerable customers

Critical Dependencies

- **People:** Control Centre Operators, Field Crews, IT Support, Customer Operations

- **Systems:** SCADA, OMS, GIS, CRM, telephony, network infrastructure
- **External:** Telecom providers, weather services, contract crews, mutual aid partners

Recovery Requirements

Metric	Target
MTD	2–4 hours
RTO	30 minutes–1 hour
RPO	Near zero for IT systems; ≤15 minutes for Customer Operations
Priority	Priority 1

These consolidated targets reflect the stakeholder inputs gathered during the workshop.

Current Recovery Capability

- Documented Business Continuity and Disaster Recovery procedures
- Manual workarounds available, including radio, phone, paper maps, and manual logging
- Secondary data centre failover and redundant communications
- Regular tabletop exercises and after-action reviews
- Continuity exists but with reduced efficiency

Improvement Opportunities

- Increase automation and predictive maintenance
- Strengthen cyber resilience and system redundancy
- Expand mutual aid agreements and cross-training
- Improve outage maps, customer self-service, and pre-storm communications