APPROVED ASSEMBLIES

Membrane Type: Single Ply, Thermoplastic, TPO, Reinforced, FleeceBACK

Deck Type 6I: Poured Gypsum, Insulated

Deck Description: Poured Gypsum Concrete

System Type C(1): One or more layers of insulation adhered with Carlisle Olybond 500 BA, or Carlisle One-Step; membrane fully adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Note: All layers shall be adhered to the deck in Carlisle OlyBond 500BA at a rate of 1 gal/sq, full coverage or Carlisle Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallong Jug Adhesive, or Flexible FAST Dual Tank Adhesive at a rate of 1 gal/sq, full coverage or Carlisle One-Step at a rate of $^1/_3$ gal/sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment. See Maximum Design Pressures below for the pressures allowed with each adhesive.

Base or Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
InsulBase, StormBase, or H-Shield NB Minimum 1.4" thick	**N/A**	**N/A**

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
Required over the insulations listed in Base Layer or optional over any of the insulations listed as Base or Top Layer:		
Dens Deck, Dens Deck Prime Minimum $^1/_4$" thick	**N/A**	**N/A**

Note: Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Vapor Retarders: (Optional) Any UL or FMRC approved vapor retarder applied to the roof deck or over a base layer of insulation.

Barrier: None.

Membrane Type: Single Ply, Thermoplastic, TPO, Reinforced, FleeceBACK

Deck Type 6: Poured Gypsum, Non-Insulated

Deck Description: Poured Gypsum Concrete

System Type F(1): Membrane fully adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Retarders: None.

Barrier: None.

Membrane: Sure-Weld FleeceBACK membrane fully adhered to the substrate using Flexible FAST Adhesive applied to the substrate at a rate of 1 gal/sq. full coverage.. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2" heat weld.

Maximum Design Pressure: -295 psf (See General Limitation #9)

Membrane Type: Single Ply, Thermoplastic, TPO, Reinforced, FleeceBACK

Deck Type 6: Poured Gypsum

Deck Description: Poured Gypsum Concrete

System Type F(2): Membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Retarders: None.

Barrier: None.

Membrane: Sure-Weld FleeceBACK membrane adhered to the substrate using Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug Adhesive applied to the substrate in ½" to ¾" ribbons spaced 12" o.c. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: -330 psf (See General Limitation #9)