APPROVED ASSEMBLIES

Membrane Type: Single Ply, Thermoplastic, TPO, Reinforced, FleeceBACK

Deck Type 5I: Cementitious Wood Fiber, Insulated

Deck Description: Minimum 2" thick Tectum Panel secured to ¼" thick supports at a maximum spacing of 3ft o.c. secured with two #14 Dekfast fasteners and 2" diameter metal plates per panel per support.

System Type A(1): One or more layers of insulation adhered with Carlisle Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug Adhesive. Membrane fully adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite CG, StormBase, H-Shield NB		
Minimum 1" thick	**N/A**	**N/A**

Note: All insulation shall be adhered to the deck with Carlisle Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug Adhesive at minimum rate 1 gal/sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Vapor Retarder: None.

Barrier: None.

Membrane Fastening Option #1: Sure-Weld FleeceBACK 100, 115, or 135 membrane adhered to the insulation using Flexible FAST, Flexible FAST Dual Cartridge or Flexible FAST 5-Gallon Jug Adhesive (applied to the substrate at a rate of 1 gal/sq., full coverage Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Or

Sure-Weld FleeceBACK 100, 115, or 135 membrane adhered to the insulation using Aqua Base 120 Bonding Adhesive. The adhesive is applied to the substrate only at a rate of 120 ft2/gallon. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Or

Sure-Weld FleeceBACK 100, 115, or 135 membrane adhered to the insulation using HydroBond Water-Based Bonding Adhesive. The adhesive is applied to the substrate only at a rate of 100 ft2/gallon. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: -120 psf. (See General Limitation #9)

Membrane Type: Single Ply, Thermoplastic, TPO, Reinforced, FleeceBACK

Deck Type 5I: Cementitious Wood Fiber, Insulated

Deck Description: Minimum 2" thick Tectum Panel secured to ¼" thick supports at a maximum spacing of 3ft o.c. secured with two #14 Dekfast fasteners and 2" diameter metal plates per panel per support.

System Type A(2): One or more layers of insulation adhered with Carlisle Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug Adhesive. Membrane fully adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite CG, StormBase, H-Shield NB		
Minimum 1" thick	**N/A**	**N/A**

Note: All insulation shall be adhered to the deck with Carlisle Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug Adhesive at minimum rate 1 gal/sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Vapor Retarder: None.

Barrier: None.

Membrane Fastening Option #2: Sure-Weld, Sure-Weld EXTRA or Sure-Weld HS membrane adhered to the insulation using Sure-Weld Bonding Adhesive or Low VOC Bonding Adhesive The adhesive is applied in a contact application and is applied to both the underside of the roofing membrane and the top side of the approved substrate at a rate of 60 ft²/gallon, finished surface area. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.
Or
Sure-Weld, Sure-Weld EXTRA or Sure-Weld HS membrane adhered to the insulation using Aqua Base 120 Bonding Adhesive. The adhesive is applied in a contact application and is applied to both the underside of the roofing membrane and the top side of the approved substrate at a rate of 120 ft²/gallon, finished surface area. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: -90 psf. (See General Limitation #9)

Membrane Type: Single Ply, Thermoplastic, TPO, Reinforced, FleeceBACK

Deck Type 5I: Cementitious Wood Fiber, Insulated

Deck Description: Minimum 2" thick Tectum Panel secured to ¼" thick supports at a maximum spacing of 3ft o.c. secured with two #14 Dekfast fasteners and 2" diameter metal plates per panel per support.

System Type A(3): One or more layers of insulation adhered with Carlisle Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug Adhesive. Membrane fully adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite CG, StormBase, H-Shield NB		
Minimum 1" thick	**N/A**	**N/A**

Note: All insulation shall be adhered to the deck with Carlisle Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug Adhesive at minimum rate 1 gal/sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Vapor Retarder: None.

Barrier: None.

Membrane Fastening: Sure-Weld AFX 120, 135, of 155 membrane adhered to the insulation using SureMB MC Adhesive. The adhesive is applied to the substrate only at a rate of 67 ft²/ Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: -120 psf. (See General Limitation #9)

Membrane Type: Single Ply, Thermoplastic, TPO, Reinforced, FleeceBACK

Deck Type 5I: Cementitious Wood Fiber, Insulated

Deck Description: Minimum 2" thick Tectum Panel secured to ¼" thick supports at a maximum spacing of 3ft o.c. secured with two #14 Dekfast fasteners and 2" diameter metal plates per panel per support.

System Type A(4): One or more layers of insulation adhered with Olybond 500 BA. Membrane fully adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite CG StormBase, H-Shield NB		
Minimum 1" thick	**N/A**	**N/A**

Note: All insulation shall be adhered to the deck with Carlisle Olybond 500 BA in applied in ribbons 12"o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Vapor Retarder: None.

Barrier: None.

Membrane Fastening Option #1: Sure-Weld FleeceBACK 100, 115, or 135 membrane adhered to the insulation using, Flexible FAST, Flexible FAST Dual Cartridge or Flexible FAST 5-Gallon Jug Adhesive applied to the substrate at a rate of 1 gal/sq., full coverage. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld

Or

Sure-Weld FleeceBACK 100, 115, or 135 membrane adhered to the insulation using Aqua Base 120 Bonding Adhesive. The adhesive is applied to the substrate only at a rate of 120 ft2/gallon. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Or

Sure-Weld FleeceBACK 100, 115, or 135 membrane adhered to the insulation using HydroBond Water-Based Bonding Adhesive. The adhesive is applied to the substrate only at a rate of 100 ft2/gallon. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Membrane Type: Single Ply, Thermoplastic, TPO, FleeceBACK

Deck Type 5I: Cementitious Wood Fiber, Insulated

Deck Description: Cementitious Wood Fiber

System Type A(5): One or more layers of insulation adhered with Carlisle Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug Adhesive or Flexible FAST Dual Tank Adhesive.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite CG, or StormBase or H-Shield NB		
Minimum 1" thick	**N/A**	**N/A**

Note: All insulation shall be adhered to the deck with Carlisle Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug Adhesive or Flexible FAST Dual Tank Adhesive applied in ½" to ¾" ribbons spaced 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Sure-Weld FleeceBACK 100, 115, or 135 membrane adhered to the insulation using Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug Adhesive applied to the substrate in ½" to ¾" ribbons spaced 12" o.c. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Or

Sure-Weld FleeceBACK 100, 115, or 135 membrane adhered to the insulation using Aqua Base 120 Bonding Adhesive. The adhesive is applied to the substrate only at a rate of 120 ft^2/gallon. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld

Or

Sure-Weld FleeceBACK 100, 115, or 135 membrane adhered to the insulation using HydroBond Water-Based Bonding Adhesive. The adhesive is applied to the substrate only at a rate of 100 ft^2/gallon. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: -322.5 psf (See General Limitation #9)

Membrane Type: Single Ply, Thermoplastic, TPO, FleeceBACK

Deck Type 5I: Cementitious Wood Fiber, Insulated

Deck Description: Cementitious Wood Fiber

System Type A(6): One or more layers of insulation adhered with, Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug Adhesive or Flexible FAST Dual Tank Adhesive. Membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
Insulfoam SP Minimum 1" thick	**N/A**	**N/A**

Note: All insulation shall be adhered to the deck with Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug Adhesive or Flexible FAST Dual Tank Adhesive applied in ½" to ¾" ribbons spaced 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Sure-Weld FleeceBACK 100, 115, or 135 membrane adhered to the insulation using Flexible FAST, Flexible FAST Dual Cartridge or Flexible FAST 5-Gallon Jug Adhesive applied to the substrate in ½" to ¾" ribbons spaced 12" o.c. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: -202.5 psf (See General Limitation #9)