APPROVED ASSEMBLIES

Membrane Type: Single Ply, Thermoplastic, TPO, Reinforced, FleeceBACK

Deck Type 7I: Recover, Insulated

Deck Description: 2500 psi structural concrete.

System Type A(1): One or more layers of insulation adhered with Carlisle Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug Adhesive, Flexible FAST Dual Tank. Membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Base Insulation Layer	**Insulation Fasteners (Table 3)**	**Fastener Density/ft²**
InsulBase, SecurShield, SecurShield HD Composite, StormBase, H-Shield, H-Shield CG, H-Shield HD Composite		
Minimum 1" thick	**N/A**	**N/A**

Top Insulation Layer (Optional)	**Insulation Fasteners (Table 3)**	**Fastener Density/ft²**
Dens Deck Prime, or SECUROCK Gypsum Fiber Roof Board		
Minimum ½" thick	**N/A**	**N/A**

Note: All insulation shall be adhered to the existing roof with Carlisle Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug , Flexible FAST Dual Tank Adhesive at a rate of 1 gal./sq., full coverage.

Membrane: Sure-Weld FleeceBACK membrane adhered to the insulation using Aqua Base 120 Bonding Adhesive, applied to the substrate only at a rate of 120 ft2/gallon or HydroBond Water-Based Bonding Adhesive applied to the substrate only at a rate of 100 ft2/gallon. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: –232.5 psf. (See General Limitation #9)

Membrane Type: Single Ply, Thermoplastic, TPO, FleeceBACK

Deck Type 7I: Recover, Insulated

Deck Description: 2500 psi Structural Concrete

System Type A(2): Insulation adhered to existing BUR, membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
Insulfoam SP Minimum 1-inch thick	**N/A**	**N/A**

Note: All insulation panels are adhered to the existing asphalt BUR with Flexible FAST Adhesive, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug or Flexible FAST Dual Tank Adhesive. Application rate is 1 gal./sq, full coverage. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Sure-Weld FleeceBACK membrane adhered to the insulation with Flexible FAST Adhesive, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug Application rate is 1 gal./sq, full coverage. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: –395 psf (See General Limitation #9)

Membrane Type: Single Ply, Thermoplastic, TPO, FleeceBACK

Deck Type 7I: Recover, Insulated

Deck Description: 2500 psi Structural Concrete

System Type A(3): Insulation adhered to existing BUR, membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
Insulfoam SP Minimum 1-inch thick	**N/A**	**N/A**

Note: All insulation panels are adhered to the existing asphalt BUR with Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug Adhesive . Application rate is 1 gal./sq, full coverage. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Sure-Weld FleeceBACK membrane adhered to the insulation with Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug Adhesive. Application rate is 1 gal./sq, full coverage. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: –225 psf (See General Limitation #9)

Membrane Type: Single Ply, Thermoplastic, TPO, FleeceBACK

Deck Type 7I: Recover, Insulated

Deck Description: 2500 psi Structural Concrete

System Type A(4): Insulation adhered to existing BUR or modified bitumen roof cover, membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD		
Minimum 1-inch thick	**N/A**	**N/A**

Note: All insulation panels are adhered to the existing asphalt BUR or modified bitumen with Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug Adhesive or Flexible FAST Dual Tank Adhesive applied in ¾ to 1-inch beads spaced 12-inches on center. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Sure-Weld FleeceBACK membrane adhered to the insulation with Flexible FAST, Flexible FAST Dual Cartridge or Flexible FAST 5-Gallon Jug Adhesive applied to the substrate in approximately ¾ to 1-inch wide beads spaced 12-inches on center. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: –45 psf (See General Limitation #9)

Membrane Type: Single Ply, Thermoplastic, TPO

Deck Type 7I: Recover, Insulated

Deck Description: 2500 psi Structural Concrete

System Type A(5): Insulation adhered to existing asphalt BUR, membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
Insulfoam EPS		
Minimum 2-inch thick	**N/A**	**N/A**
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite		
Minimum 1.5-inch thick	**N/A**	**N/A**

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
Dens Deck Prime		
Minimum 1/4-inch thick	**N/A**	**N/A**

Note: All insulation panels are adhered to the existing BUR with Carlisle OlyBond 500 BA. Application rate is ½ to ¾-inch wide beads spaced 12-inches on center. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Sure-Weld, Sure-Weld EXTRA or Sure-Weld HS membrane adhered to the substrate using Sure-Weld Bonding Adhesive or Low VOC Bonding Adhesive. The adhesive is applied in a contact application and is applied to both the underside of the roofing membrane and the top side of the approved substrate at a rate of 60 ft²/gallon, finished surface area. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: –120 psf (See General Limitation #9)

Membrane Type: Single Ply, Thermoplastic, TPO

Deck Type 7I: Recover, Insulated

Deck Description: 2500 psi Structural Concrete

System Type A(6): Insulation adhered to existing asphalt BUR, membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
Dens Deck Prime Minimum 1/4-inch thick	**N/A**	**N/A**

Note: All insulation panels are adhered to the existing BUR with Carlisle OlyBond 500 BA. Application rate is ½ to ¾-inch wide beads spaced 12-inches on center. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Sure-Weld, Sure-Weld EXTRA or Sure-Weld HS membrane adhered to the substrate using Sure-Weld Bonding Adhesive or Low VOC Bonding Adhesive.. The adhesive is applied in a contact application and is applied to both the underside of the roofing membrane and the top side of the approved substrate at a rate of 60 ft²/gallon, finished surface area. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: –120 psf (See General Limitation #9)

Membrane Type: Single Ply, Thermoplastic, TPO

Deck Type 7I: Recover, Insulated

Deck Description: 2500 psi Structural Concrete

System Type A(7): Insulation adhered to existing asphalt BUR, membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
InsulBase, SecurShield, SecurShield HD Composite H-Shield, H-Shield CG, H-Shield HD Composite Minimum 1.5-inch thick	**N/A**	**N/A**

Note: All insulation panels are adhered to the existing BUR with Carlisle OlyBond 500 BA. Application rate is ½ to ¾-inch wide beads spaced 12-inches on center. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Sure-Weld, Sure-Weld EXTRA or Sure-Weld HS membrane adhered to the substrate using Sure-Weld Bonding Adhesive or Low VOC Bonding Adhesive . The adhesive is applied in a contact application and is applied to both the underside of the roofing membrane and the top side of the approved substrate at a rate of 60 ft^2/gallon, finished surface area. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: –120 psf (See General Limitation #9)

Membrane Type: Single Ply, Thermoplastic, TPO

Deck Type 7I: Recover, Inulated

Deck Description: Lightweight Insulating Concrete

System Type A(8): Insulation adhered to existing asphalt BUR, membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Base and/or Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite		
Minimum 1.5-inch thick	**N/A**	**N/A**
Dens Deck Prime		
Minimum 1/4-inch thick	**N/A**	**N/A**

Note: All insulation panels are adhered to the existing BUR with Carlisle OlyBond 500 BA. Application rate is ½ to ¾-inch wide beads spaced 12-inches on center. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Sure-Weld, Sure-Weld EXTRA or Sure-Weld HS membrane adhered to the substrate using Sure-Weld Bonding Adhesive or Low VOC Bonding Adhesive. The adhesive is applied in a contact application and is applied to both the underside of the roofing membrane and the top side of the approved substrate at a rate of 60 ft^2/gallon, finished surface area. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: –120 psf (See General Limitation #9)

Membrane Type: Single Ply, Thermoplastic, TPO, FleeceBACK

Deck Type 7I: Recover, Insulated

Deck Description: Existing Standing Seam Metal

System Type A(9): Insulation adhered to existing standing seam metal roof, membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Base (Flute Fill) Insulation Layer	**Insulation Fasteners (Table 3)**	**Fastener Density/ft^2**
Insulfoam EPS Minimum 2-inch thick	**N/A**	**N/A**

Top Insulation Layer	**Insulation Fasteners (Table 3)**	**Fastener Density/ft^2**
Dens Deck Prime Minimum 1/4-inch thick	**N/A**	**N/A**

Note: All insulation panels are adhered to the existing standing seam metal with Flexible FAST, Flexible FAST Dual Cartridge or Flexible FAST 5-Gallon Jug Adhesive. Application rate is 1/2 to 3/4-inch wide beads spaced 12-inches on center. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Sure-Weld FleeceBACK membrane adhered to the insulation with Flexible FAST, Flexible FAST Dual Cartridge or Flexible FAST 5-Gallon Jug Adhesive applied to the substrate in approximately 1/2 to 3/4-inch wide beads spaced 12-inches on center. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: –120 psf (See General Limitation #9)

Membrane Type: Single Ply, Thermoplastic, TPO, FleeceBACK

Deck Type 7I: Recover, Insulated

Deck Description: Existing Standing Seam Metal

System Type A(10): Insulation adhered to existing standing seam metal roof, membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Base (Flute Fill) Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
Insulfoam EPS Minimum 2-inch thick	**N/A**	**N/A**

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
SECUROCK Gypsum-Fiber Roof Board Minimum 1/4-inch thick	**N/A**	**N/A**

Note: All insulation panels are adhered to the existing standing seam metal with Flexible FAST Dual Tank, Flexible FAST, Flexible FAST Dual Cartridge or Flexible FAST 5-Gallon Jug Adhesive. Application rate is 1/2 to 3/4-inch wide beads spaced 12-inches on center. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Sure-Weld FleeceBACK membrane adhered to the insulation with Flexible FAST, Flexible FAST Dual Cartridge or Flexible FAST 5-Gallon Jug Adhesive applied to the substrate in approximately 1/2 to 3/4-inch wide beads spaced 12-inches on center. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: –135 psf (See General Limitation #9)

Membrane Type: Single Ply, Thermoplastic, TPO, Reinforced, FleeceBACK

Deck Type 7I: Recover, Insulated

Deck Description: 2500 psi concrete /wood / 18-22 ga. 33 ksi steel.

System Type C(1): All layers of insulation simultaneously attached; membrane fully adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite		
Minimum 1.4" thick	**Approved Fastener for Deck Type**	**1:2 ft²**
Minimum 2" thick	**Approved Fastener for Deck Type**	**1:4 ft²**
StormBase		
Minimum 1.4" thick	**Approved Fastener for Deck Type**	**1:2 ft²**
Minimum 2" thick	**Approved Fastener for Deck Type**	**1:4 ft²**

Note: Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Vapor Retarder: (Optional) Any UL of FMRC approved vapor Retarder applied to the roof deck or over a base layer of insulation.

Barrier: None.

Membrane #1: Sure-Weld, Sure-Weld EXTRA or Sure-Weld HS membrane adhered to the insulation using Sure-Weld Bonding Adhesive or Low VOC Bonding Adhesive. The adhesive is applied in a contact application and is applied to both the underside of the roofing membrane and the top side of the approved substrate at a rate of 60 ft²/gallon, finished surface area. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

OR

Sure-Weld, Sure-Weld EXTRA or Sure-Weld HS membrane adhered to the insulation using Aqua Base 120 Bonding Adhesive. The adhesive is applied in a contact application and is applied to both the underside of the roofing membrane and the top side of the approved substrate at a rate of 120 ft²/gallon, finished surface area. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Membrane Type: Single Ply, Thermoplastic, TPO, FleeceBACK

Deck Type 7I: Recover, Insulated

Deck Description: 2500 psi Structural Concrete or Min., 22-gauge Type B, Grade 33 Steel deck fastened to minimum ¼-inch steel structural supports spaced a maximum 6-feet on center with ITW Buildex Traxx/5 spaced at a maximum 6-inches on center. Deck side laps are secured with ITW Buildex Traxx/1 at a maximum 24-inches on center.

System Type C(2): Insulation mechanically fastened, membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite		
Minimum 1-inch thick	**Approved Fastener for Deck Type**	**1:1.6 ft²**

Note: Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Sure-Weld, Sure-Weld EXTRA or Sure-Weld HS membrane adhered to the insulation using Sure-Weld Bonding Adhesive or Low VOC Bonding Adhesive The adhesive is applied in a contact application and is applied to both the underside of the roofing membrane and the top side of the approved substrate at a rate of 60 ft²/gallon, finished surface area. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.
OR

Sure-Weld FleeceBACK membrane adhered to the insulation with Flexible FAST, Flexible FAST Dual Cartridge or Flexible FAST 5-Gallon Jug Adhesive applied to the substrate in approximately 1/2 to 3/4-inch wide beads spaced 12-inches on center or at 1 gal./sq, full coverage. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: –45 psf (See General Limitation #9)

Membrane Type: Single Ply, Thermoplastic, TPO

Deck Type 7I: Recover, Insulated

Deck Description: 2500 psi Structural Concrete or Min., 22-gauge Type B, Grade 33 Steel deck fastened to minimum ¼-inch steel structural supports spaced a maximum 6-feet on center with ITW Buildex Traxx/5 spaced at a maximum 6-inches on center. Deck side laps are secured with ITW Buildex Traxx/1 at a maximum 24-inches on center.

System Type C(3): Insulation mechanically fastened, membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite		
Minimum 2-inch thick	**Approved Fastener for Deck Type**	**1:4 ft²**

Note: Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Sure-Weld, Sure-Weld EXTRA or Sure-Weld HS membrane adhered to the insulation using Sure-Weld Bonding Adhesive or Low VOC Bonding Adhesive. The adhesive is applied in a contact application and is applied to both the underside of the roofing membrane and the top side of the approved substrate at a rate of 60 ft²/gallon, finished surface area. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.
OR

Sure-Weld FleeceBACK membrane adhered to the insulation with Flexible FAST, Flexible FAST Dual Cartridge or Flexible FAST 5-Gallon Jug Adhesive applied to the substrate in approximately 1/2 to 3/4-inch wide beads spaced 12-inches on center or at 1 gal./sq, full coverage. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: –45 psf (See General Limitation #9)

Membrane Type: Single Ply, Thermoplastic, TPO

Deck Type 7I: Recover, Insulated

Deck Description: 2500 psi Structural Concrete or Min., 22-gauge Type B, Grade 33 Steel deck fastened to minimum ¼-inch steel structural supports spaced a maximum 6-feet on center with ITW Buildex Traxx/5 spaced at a maximum 6-inches on center. Deck side laps are secured with ITW Buildex Traxx/1 at a maximum 24-inches on center.

System Type C(4): Insulation mechanically fastened, membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
SecurShield, SecurShield HD Composite, H-Shield CG, H-Shield HD Composite		
Minimum 2-inch thick	**Approved Fastener for Deck Type**	**1:1.6 ft²**

Note: Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Sure-Weld FleeceBACK membrane adhered to the insulation with Flexible FAST, Flexible FAST Dual Cartridge or Flexible FAST 5-Gallon Jug Adhesive applied to the substrate at 1 gal./sq, full coverage. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: –52.5 psf (See General Limitation #9)

Membrane Type: Single Ply, Thermoplastic, TPO

Deck Type 7I: Recover, Insulated

Deck Description: 2500 psi Structural Concrete or Min., 22-gauge Type B, Grade 33 Steel deck fastened to minimum ¼-inch steel structural supports spaced a maximum 6-feet on center with ITW Buildex Traxx/5 spaced at a maximum 6-inches on center. Deck side laps are secured with ITW Buildex Traxx/1 at a maximum 24-inches on center.

System Type C(5): Insulation mechanically fastened, membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
InsulBase, H-Shield **Minimum 2-inch thick**	**Approved Fastener for Deck Type**	**1:1.6 ft²**

Note: Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Sure-Weld, Sure-Weld EXTRA or Sure-Weld HS membrane adhered to the insulation using Sure-Weld Bonding Adhesive or Low VOC Bonding Adhesive. The adhesive is applied in a contact application and is applied to both the underside of the roofing membrane and the top side of the approved substrate at a rate of 60 ft²/gallon, finished surface area. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.
OR

Sure-Weld FleeceBACK membrane adhered to the insulation with Flexible FAST, Flexible FAST Dual Cartridge or Flexible FAST 5-Gallon Jug Adhesive applied to the substrate at 1 gal./sq, full coverage. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: –75 psf (See General Limitation #9)

Membrane Type: Single Ply, Thermoplastic, TPO

Deck Type 7I: Recover, Insulated

Deck Description: 2500 psi Structural Concrete or Min., 22-gauge Type B, Grade 33 Steel deck fastened to minimum ¼-inch steel structural supports spaced a maximum 6-feet on center with ITW Buildex Traxx/5 spaced at a maximum 6-inches on center. Deck side laps are secured with ITW Buildex Traxx/1 at a maximum 12 inches on center.

System Type C(6): Insulation mechanically fastened, membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
SecurShield, SecurShield HD Composite, H-Shield CG, H-Shield HD Composite		
Minimum 2-inch thick	**Approved Fastener for Deck Type**	**1:1 ft²**

Note: Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Sure-Weld, Sure-Weld EXTRA or Sure-Weld HS membrane adhered to the insulation using Sure-Weld Bonding Adhesive or Low VOC Bonding Adhesive. The adhesive is applied in a contact application and is applied to both the underside of the roofing membrane and the top side of the approved substrate at a rate of 60 ft²/gallon, finished surface area. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.
OR

Sure-Weld FleeceBACK membrane adhered to the insulation with Flexible FAST, Flexible FAST Dual Cartridge or Flexible FAST 5-Gallon Jug Adhesive applied to the substrate in approximately 1/2 to 3/4-inch wide beads spaced 4-inches on center or at 1 gal./sq, full coverage. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: –82.5 psf (See General Limitation #7)

Membrane Type: Single Ply, Thermoplastic, TPO

Deck Type 7I: Recover, Insulated

Deck Description: 2500 psi Structural Concrete or Min., 22-gauge Type B, Grade 80 Steel deck fastened to minimum ¼-inch steel structural supports spaced a maximum 6-feet on center with ITW Buildex Traxx/5 spaced at a maximum 6-inches on center. Deck side laps are secured with ITW Buildex Traxx/1 at a maximum 12 inches on center.

System Type C(7): Insulation mechanically fastened, membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
SecurShield, SecurShield HD Composite, H-Shield CG, H-Shield HD Composite		
Minimum 2-inch thick	**Approved Fastener for Deck Type**	**1:1 ft²**

Note: Please refer to Roofing Application Standard RAS 117 for insulation attachment

Membrane: Sure-Weld, Sure-Weld EXTRA or Sure-Weld HS membrane adhered to the insulation using Sure-Weld Bonding Adhesive or Low VOC Bonding Adhesive. The adhesive is applied in a contact application and is applied to both the underside of the roofing membrane and the top side of the approved substrate at a rate of 60 ft²/gallon, finished surface area. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.
OR

Sure-Weld FleeceBACK membrane adhered to the insulation with Flexible FAST, Flexible FAST Dual Cartridge or Flexible FAST 5-Gallon Jug Adhesive applied to the substrate in approximately 1/2 to 3/4-inch wide beads spaced 4-inches on center. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: –135 psf (See General Limitation #7)

Membrane Type: Single Ply, Thermoplastic, TPO

Deck Type 7I: Recover, Insulated

Deck Description: 2500 psi Structural Concrete or Min., 22-gauge Type B, Grade 80 Steel deck fastened to minimum ¼-inch steel structural supports spaced a maximum 6-feet on center with ITW Buildex Traxx/5 spaced at a maximum 6-inches on center. Deck side laps are secured with ITW Buildex Traxx/1 at a maximum 12 inches on center.

System Type C(8): Insulation mechanically fastened, membrane adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite		
Minimum 2-inch thick	**Approved Fastener for Deck Type**	**1:1 ft²**

Note: Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Sure-Weld FleeceBACK membrane adhered to the insulation with Flexible FAST, Flexible FAST Dual Cartridge or Flexible FAST 5-Gallon Jug Adhesive applied to the substrate at 1 gal./sq, full coverage. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: –135 psf (See General Limitation #7)

Membrane Type: Single Ply, Thermoplastic, TPO, Reinforced

Deck Type 7I: Recover, Insulated

Deck Description: Minimum 22 gage Type B, ASTM A 653 Grade 33 Steel deck fastened to steel support at a maximum span of 6 feet o.c. Steel deck shall be fastened with minimum ITW #12 HWH Teks/5 fasteners at a maximum spacing of 6 inches o.c. Side laps shall be fastened with ITW Buildex ITW HWH Teks/1 at a maximum spacing of 24 inches o.c.

System Type D(1): Membrane mechanically attached over preliminarily fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Base and/or Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite		
Minimum 1.2" thick	**N/A**	**N/A**
StormBase		
Minimum 1.4" thick	**N/A**	**N/A**
Dens Deck, DensDeck Prime SECUROCK Gypsum Fiber Roof Board or SECUROCK Glass Mat Roof Board		
Minimum ¼" thick	**N/A**	**N/A**
R-Tech, R-Tech Fan-Fold, SecurShield HD		
Minimum ½" thick	**N/A**	**N/A**

Note Refer to Roofing Application Standard RAS 117 for insulation attachment requirements. Insulation shall have preliminary attachment, prior to the installation of the roofing membrane. At an application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. Single and multiple layers of insulation can be attached to the deck with Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5 Gallon Jug Adhesive or Flexible FAST Dual Tank, or Carlisle Olybond 500BA or Carlisle One-Step Adhesive.

Vapor Retarder: (Optional) Any UL or FMRC approved vapor retarder applied to the roof deck or over a base layer of insulation.

Barrier: None.

Membrane: Sure-Weld, Sure-Weld HS or Sure-Weld EXTRA, Reinforced, secured through the preliminarily attached insulation as specified below.

Note: HP Purlin fastener must be used in place of HP-X Fasteners when securing into minimum 16 gauge structural purlins.

Membrane Type: Single Ply, Thermoplastic, TPO, Reinforced

Deck Type 7I: Recover, Insulated

Deck Description: Minimum 18 gage Type B, ASTM A 653 Grade 33 Steel deck fastened to steel support at a maximum span of 5 feet o.c. Steel deck shall be fastened with minimum ITW #12 HWH Teks/5 fasteners at a maximum spacing of 6 inches o.c. Side laps shall be fastened with ITW Buildex ITW HWH Teks/1 at a maximum spacing of 24 inches o.c.
Or
Minimum 18 gage Type B, ASTM A 653 Grade 80 Steel deck fastened to steel support at a maximum span of 6 feet o.c. Steel deck shall be fastened with minimum ITW #12 HWH Teks/5 fasteners at a maximum spacing of 6 inches o.c. Side laps shall be fastened with ITW Buildex ITW HWH Teks/1 at a maximum spacing of 24 inches o.c.

System Type D(2): Membrane mechanically attached over preliminarily fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Base and/or Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite		
Minimum 1.2" thick	**N/A**	**N/A**
StormBase		
Minimum 1.4" thick	**N/A**	**N/A**
Dens Deck, DensDeck Prime SECUROCK Gypsum Fiber Roof Board or SECUROCK Glass Mat Roof Board		
Minimum ¼" thick	**N/A**	**N/A**
R-Tech, R-Tech Fan-Fold, SecurShield HD		
Minimum ½" thick	**N/A**	**N/A**

Note Refer to Roofing Application Standard RAS 117 for insulation attachment requirements. Insulation shall have preliminary attachment, prior to the installation of the roofing membrane. At an application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. Single and multiple layers of insulation can be attached to the deck with Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5 Gallon Jug Adhesive or Flexible FAST Dual Tank, or Carlisle Olybond 500BA or Carlisle One-Step Adhesive.

Vapor Retarder: (Optional) Any UL or FMRC approved vapor retarder applied to the roof deck or over a base layer of insulation.

Barrier: None.

Membrane Type: Single Ply, Thermoplastic, TPO, Reinforced

Deck Type 7I: Recover, Insulated

Deck Description: 20 or 18 gage Type B, ASTM A 653 Grade 80 Steel deck fastened to steel support at a maximum span of 72-inches o.c. Steel deck shall be fastened with minimum ITW #12 HWH Teks/5 fasteners at a maximum spacing of 6 inches o.c. Side laps shall be fastened with ITW Buildex ITW HWH Teks/1 at a maximum spacing of 24 inches o.c.
Or
Minimum 22 gage Type B, ASTM A 653 Grade 33 Steel deck fastened to steel support at a maximum span of 66-inches o.c. Steel deck shall be fastened with minimum ITW #12 HWH Teks/5 fasteners at a maximum spacing of 6 inches o.c. Side laps shall be fastened with ITW Buildex ITW HWH Teks/1 at a maximum spacing of 24 inches o.c.

System Type D(3): Membrane mechanically attached over preliminarily fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Base and/or Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite		
Minimum 1.2" thick	**N/A**	**N/A**
StormBase		
Minimum 1.4" thick	**N/A**	**N/A**
Dens Deck, DensDeck Prime SECUROCK Gypsum Fiber Roof Board or SECUROCK Glass Mat Roof Board		
Minimum ¼" thick	**N/A**	**N/A**
R-Tech, R-Tech Fan-Fold, SecurShield HD		
Minimum ½" thick	**N/A**	**N/A**

Note Refer to Roofing Application Standard RAS 117 for insulation attachment requirements. Insulation shall have preliminary attachment, prior to the installation of the roofing membrane. At an application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. Single and multiple layers of insulation can be attached to the deck with Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5 Gallon Jug Adhesive or Flexible FAST Dual Tank, or Carlisle Olybond 500BA or Carlisle One-Step Adhesive.

Vapor Retarder: (Optional) Any UL or FMRC approved vapor retarder applied to the roof deck or over a base layer of insulation.

Barrier: None.

Membrane Type: Single Ply, Thermoplastic, TPO, Reinforced

Deck Type 7I: Recover, Insulated

Deck Description: Minimum 20 to18 gage Type B, ASTM A 653 Grade 80 Steel deck fastened to steel support at a maximum span of 6 feet o.c. Steel deck shall be fastened with minimum ITW #12 HWH Teks/5 fasteners at a maximum spacing of 6 inches o.c. Side laps shall be fastened with ITW Buildex ITW HWH Teks/1 at a maximum spacing of 24 inches o.c.
Or
Minimum 22 gage Type B, ASTM A 653 Grade 80 Steel deck fastened to steel support at a maximum span of 66 feet o.c. Steel deck shall be fastened with minimum ITW #12 HWH Teks/5 fasteners at a maximum spacing of 6 inches o.c. Side laps shall be fastened with ITW Buildex ITW HWH Teks/1 at a maximum spacing of 24 inches o.c.

System Type D(4): Membrane mechanically attached over preliminarily fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Base and/or Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite		
Minimum 1.2" thick	**N/A**	**N/A**
StormBase		
Minimum 1.4" thick	**N/A**	**N/A**
Dens Deck, DensDeck Prime SECUROCK Gypsum Fiber Roof Board or SECUROCK Glass Mat Roof Board		
Minimum ¼" thick	**N/A**	**N/A**
R-Tech, R-Tech Fan-Fold, SecurShield HD		
Minimum ½" thick	**N/A**	**N/A**

Note Refer to Roofing Application Standard RAS 117 for insulation attachment requirements. Insulation shall have preliminary attachment, prior to the installation of the roofing membrane. At an application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. Single and multiple layers of insulation can be attached to the deck with Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5 Gallon Jug Adhesive or Flexible FAST Dual Tank, or Carlisle Olybond 500BA or Carlisle One-Step Adhesive.

Vapor Retarder: (Optional) Any UL or FMRC approved vapor retarder applied to the roof deck or over a base layer of insulation.

Barrier: None.

Membrane Type: Single Ply, Thermoplastic, TPO, Reinforced

Deck Type 7I: Recover, Insulated

Deck Description: Minimum 22 gage Type B, ASTM A 653 Grade 33 Steel deck fastened to steel support at a maximum span of 6 feet o.c. Steel deck shall be fastened with minimum ITW #12 HWH Teks/5 fasteners at a maximum spacing of 6 inches o.c. Side laps shall be fastened with ITW Buildex ITW HWH Teks/1 at a maximum spacing of 30 inches o.c.

System Type D(5): Membrane mechanically attached over preliminarily fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Base and/or Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite		
Minimum 1.2" thick	**N/A**	**N/A**
StormBase		
Minimum 1.4" thick	**N/A**	**N/A**
Dens Deck, DensDeck Prime SECUROCK Gypsum Fiber Roof Board or SECUROCK Glass Mat Roof Board		
Minimum ¼" thick	**N/A**	**N/A**
R-Tech, R-Tech Fan-Fold, SecurShield HD		
Minimum ½" thick	**N/A**	**N/A**

Note Refer to Roofing Application Standard RAS 117 for insulation attachment requirements. Insulation shall have preliminary attachment, prior to the installation of the roofing membrane. At an application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. Single and multiple layers of insulation can be attached to the deck with Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5 Gallon Jug Adhesive or Flexible FAST Dual Tank, or Carlisle Olybond 500BA or Carlisle One-Step Adhesive.

Vapor Retarder: (Optional) Any UL or FMRC approved vapor retarder applied to the roof deck or over a base layer of insulation.

Barrier: None.

Membrane: 12-foot wide Sure-Weld or Sure-Weld EXTRA membrane mechanically fastened 6-inches on center through the field seams using HPX Fasteners and Piranha Plates.

Maximum Design Pressure: –52.5 psf (See General Limitation #7)

Membrane Type: Single Ply, Thermoplastic, TPO, Reinforced

Deck Type 7I: Recover, Insulated

Deck Description: Minimum 22 gage Type B, ASTM A 653 Grade 80 Steel deck fastened to steel support at a maximum span of 6 feet o.c. Steel deck shall be fastened with minimum ITW #12 HWH Teks/5 fasteners at a maximum spacing of 6 inches o.c. Side laps shall be fastened with ITW Buildex ITW HWH Teks/1 at a maximum spacing of 30 inches o.c.

System Type D(6): Membrane mechanically attached over preliminarily fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Base and/or Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite		
Minimum 1.2" thick	**N/A**	**N/A**
StormBase		
Minimum 1.4" thick	**N/A**	**N/A**
Dens Deck, DensDeck Prime SECUROCK Gypsum Fiber Roof Board or SECUROCK Glass Mat Roof Board		
Minimum ¼" thick	**N/A**	**N/A**
R-Tech, R-Tech Fan-Fold, SecurShield HD		
Minimum ½" thick	**N/A**	**N/A**

Note Refer to Roofing Application Standard RAS 117 for insulation attachment requirements. Insulation shall have preliminary attachment, prior to the installation of the roofing membrane. At an application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. Single and multiple layers of insulation can be attached to the deck with Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5 Gallon Jug Adhesive or Flexible FAST Dual Tank, or Carlisle Olybond 500BA or Carlisle One-Step Adhesive.

Vapor Retarder: (Optional) Any UL or FMRC approved vapor retarder applied to the roof deck or over a base layer of insulation.

Barrier: None.

Membrane: 12-foot wide Sure-Weld or Sure-Weld EXTRA membrane mechanically fastened 6-inches on center through the field seams using HPX Fasteners and Piranha Plates.

Maximum Design Pressure: –60 psf (See General Limitation #7)

Membrane Type: Single Ply, Thermoplastic, TPO, Reinforced

Deck Type 7I: Recover, Insulated

Deck Description: Minimum 22 gage Type B, ASTM A 653 Grade 33 Steel deck fastened to steel support at a maximum span of 6 feet o.c. Steel deck shall be fastened with minimum ITW #12 HWH Teks/5 fasteners at a maximum spacing of 6 inches o.c. Side laps shall be fastened with ITW Buildex ITW HWH Teks/1 at a maximum spacing of 30 inches o.c.

System Type D(7): Membrane mechanically attached over preliminarily fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Base and/or Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite		
Minimum 1.2" thick	**N/A**	**N/A**
StormBase		
Minimum 1.4" thick	**N/A**	**N/A**
Dens Deck, DensDeck Prime SECUROCK Gypsum Fiber Roof Board or SECUROCK Glass Mat Roof Board		
Minimum ¼" thick	**N/A**	**N/A**
R-Tech, R-Tech Fan-Fold, SecurShield HD		
Minimum ½" thick	**N/A**	**N/A**

Note Refer to Roofing Application Standard RAS 117 for insulation attachment requirements. Insulation shall have preliminary attachment, prior to the installation of the roofing membrane. At an application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. Single and multiple layers of insulation can be attached to the deck with Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5 Gallon Jug Adhesive or Flexible FAST Dual Tank, or Carlisle Olybond 500BA or Carlisle One-Step Adhesive.

Vapor Retarder: (Optional) Any UL or FMRC approved vapor retarder applied to the roof deck or over a base layer of insulation.

Barrier: None.

Membrane: 4-foot wide Sure-Weld or Sure-Weld EXTRA membrane mechanically fastened 6-inches on center through the field seams using HPX Fasteners and Piranha Plates.

Maximum Design Pressure: –82.5 psf (See General Limitation #7)

Membrane Type: Single Ply, Thermoplastic, TPO, Reinforced FleeceBack

Deck Type 7: Recover

Deck Description: Minimum 22 gage Type B, ASTM A 611 Grade E or ASTM A 653 Grade 80 Steel deck fastened to steel support at a maximum span of 6 feet o.c. Steel deck shall be fastened with minimum ITW Buildex Traxx/4 at a maximum spacing of 6 inches o.c. Side laps shall be fastened with ITW Buildex Traxx/1 at a maximum spacing of 12 inches o.c.

This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submittted Table.

System Type D(8): Membrane mechanically attached existing Roof assembly.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Retarder: (Optional) Any UL or FMRC approved vapor retarder applied to the roof deck or over a base layer of insulation.

Barrier: None.

Membrane: 135-mil Sure-Weld FleeceBACK mechanically fastened to the deck using HP-Xtra Fasteners and Piranha Xtra Plates spaced 12-inches on center. Fastener rows are spaced a maximum 91-inches on center.

Maximum Design Pressure: –60 psf (See General Limitation #7)

Membrane Type: Single Ply, Thermoplastic, TPO, Reinforced FleeceBack

Deck Type 7: Recover

Deck Description: 2500 psi Structural Concrete

System Type D(9): Membrane mechanically attached existing Roof assembly.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Retarder: (Optional) Any UL or FMRC approved vapor retarder applied to the roof deck or over a base layer of insulation.

Barrier: None.

Membrane: 135-mil Sure-Weld FleeceBACK mechanically fastened to the deck using HD 14-10 or CD-10 Fasteners and Piranha Xtra Plates spaced 12-inches on center. Fastener rows are spaced a maximum 91-inches on center.

Maximum Design Pressure: –60 psf (See General Limitation #7)

Membrane Type: Single Ply, Thermoplastic, TPO, Reinforced

Deck Type 7I: Recover, Insulated

Deck Description: 2500 psi structural concrete.

System Type D(10): Membrane mechanically attached over preliminarily fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
InsulBase, SecurShield, SecurShield HD Composite H-Shield, H-Shield CG, H-Shield HD Composite		
Minimum 1.2" thick	**N/A**	**N/A**
StormBase		
Minimum 1.4" thick	**N/A**	**N/A**
Dens Deck, SECUROCK Gypsum Fiber Roof Board or SECUROCK Glass Mat Roof Board		
Minimum ¼" thick	**N/A**	**N/A**
R-Tech, R-Tech Fan-Fold, SecurShield HD		
Minimum ½" thick	**N/A**	**N/A**

Note: All layers of insulation and base sheet shall be simultaneously attached. See base sheet below for fasteners and density. Refer to Roofing Application Standard RAS 117 for insulation attachment requirements. Insulation shall have preliminary attachment, prior to the installation of the roofing membrane. At an application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. Single and multiple layers of insulation can be attached to the deck with Flexible FAST, Flexible FAST Dual Cartridge, Flexible FAST 5-Gallon Jug Adhesive, Flexible FAST Dual Tank Adhesive, or Carlisle Olybond 500BA, or Carlisle One-Step Foamable Adhesive.

Vapor Retarder: (Optional) Any UL or FMRC approved vapor retarder applied to the roof deck or over a base layer of insulation.

Barrier: None.

Membrane Type: Single Ply, Thermoplastic, TPO

Deck Type 7I: Recover, Insulated

Deck Description: Minimum 22 gage Type B, ASTM A 653 Grade 33 Steel deck fastened to steel support at a maximum span of 6 feet o.c. Steel deck shall be fastened with minimum ITW Buildex Traxx/4 at a maximum spacing of 6 inches o.c. Side laps shall be fastened with ITW Buildex Traxx/1 at a maximum spacing of 30 inches o.c.

System Type D(11): Membrane induction welded over mechanically fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Base and/or Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite		
Minimum 1.5-inch thick	HPX Fasteners and RhinoBond Plates-TPO	**See Below**
SecurShield HD or H-Shield HD		
Minimum ½-inch thick	HPX Fasteners and RhinoBond Plates-TPO	**See Below**
SECUROCK Gypsum Fiber or Glass Mat Roof Board		
Minimum ¼-inch thick	HPX Fasteners and RhinoBond Plates-TPO	**See Below**
Dens Deck, Dens Deck Prime		
Minimum ¼-inch thick	HPX Fasteners and RhinoBond Plates-TPO	**See Below**

Note: All layers of insulation shall be simultaneously attached. Refer to Roofing Application Standard RAS 117 for insulation attachment requirements.

Fastening #1: Sure-Weld or Sure-Weld EXTRA membrane induction welded to RhinoBond Plates-TPO using RhinoBond induction tool. Attached at the minimum rate of 1:5.33 ft² (6 per 4 ft by 8 ft board). ***Maximum Design Pressure -MDP-45 psf. (See General Limitation #7)***

Fastening #2: Sure-Weld or Sure-Weld EXTRA membrane induction welded to RhinoBond Plates-TPO using RhinoBond induction tool. Attached at the minimum rate of 1:4 ft² (8 per 4 ft by 8 ft board). ***Maximum Design Pressure -MDP-52.5 psf. (See General Limitation #7)***

Fastening #3: Sure-Weld or Sure-Weld EXTRA membrane induction welded to RhinoBond Plates-TPO using RhinoBond induction tool. Attached at the minimum rate of 1:2 ft² (16 per 4 ft by 8 ft board). ***Maximum Design Pressure -MDP-82.5 psf. (See General Limitation #7)***

Membrane Type	Single Ply, Thermoplastic, TPO
Deck Type	Recover Insulated
Deck Description	Minimum 22 gage Type B, ASTM A 611 Grade E or ASTM A 653 Grade 80 Steel deck fastened to steel support at a maximum span of 6 feet o.c. Steel deck shall be fastened with minimum ITW Buildex Traxx/4 at a maximum spacing of 6 inches o.c. Side laps shall be fastened with ITW Buildex Traxx/1 at a maximum spacing of 12 inches o.c.
System Type D(12):	Sure-Weld, Sure-Weld EXTRA Membrane induction welded over fastened insulation

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with the prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Base and/or Top Insulation Layer	**Insulation Fasteners (Table 3)**	**Fastener Density/ft²**
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite		
Minimum 1.5-inch thick	HPX Fasteners and RhinoBond Plates-TPO	**See Below**
SecurShield HD or H-Shield HD		
Minimum ½-inch thick	HPX Fasteners and RhinoBond Plates-TPO	**See Below**
SECUROCK Gypsum Fiber or Glass Mat Roof Board		
Minimum ¼-inch thick	HPX Fasteners and RhinoBond Plates-TPO	**See Below**
Dens Deck, Dens Deck Prime		
Minimum ¼-inch thick		

Note: All layers of insulation shall be simultaneously attached. Refer to Roofing Application Standard RAS 117 for insulation attachment requirements.

Fastening #1: Sure-Weld or Sure-Weld EXTRA membrane induction welded to RhinoBond Plates-TPO using RhinoBond induction tool. Attached at the minimum rate of 1:4 ft² (8 per 4 ft by 8 ft board). ***Maximum Design Pressure MDP-60 psf. (See General Limitation #7)***

Fastening #2 Sure-Weld or Sure-Weld EXTRA membrane induction welded to RhinoBond Plates-TPO using RhinoBond induction tool. Attached at the minimum rate of 1:2 ft² (16 per 4 ft by 8 ft board). ***Maximum Design Pressure MDP -97.5 psf. (See General Limitation #7)***

Membrane Type: Single Ply, Thermoplastic, TPO

Deck Type 7I: Recover, Insulated

Deck Description: Minimum 22 gage Type B, ASTM A 611 Grade E or ASTM A 653 Grade 80 Steel deck fastened to steel support at a maximum span of 6 feet o.c. Steel deck shall be fastened with minimum #12 ITW Buildex Traxx/4 at a maximum spacing of 6 inches o.c. Side laps shall be fastened with #10 ITW Buildex Traxx/1 at a maximum spacing of 12 inches o.c.

System Type D(13): Sure-Weld, Sure-Weld EXTRA Membrane induction welded over mechanically fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Base and/or Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite		
Minimum 1.5-inch thick	**N/A**	**N/A**
SecurShield HD or H-Shield HD		
Minimum ½-inch thick	**N/A**	**N/A**
SECUROCK Gypsum Fiber or Glass Mat Roof Board		
Minimum ¼-inch thick	**N/A**	**N/A**
Dens Deck, Dens Deck Prime		
Minimum ¼-inch thick	**N/A**	**N/A**

Note: All layers of insulation shall be simultaneously attached. Refer to Roofing Application Standard RAS 117 for insulation attachment requirements.

Membrane: RhinoBond Plate and HPX Fasteners are installed 12-inches on center, in rows spaced maximum 5-feet on center. Minimum 60-mil Sure-Weld or Sure-Weld EXTRA membrane induction welded to RhinoBond Plates-TPO using RhinoBond induction tool.

Maximum Design Pressure: –45 psf (See General Limitation #7)

Membrane Type: Single Ply, Thermoplastic, TPO

Deck Type 7I: Recover, Insulated

Deck Description: 20 to18 gage Type B, ASTM A 653 Grade 80 Steel deck Supported 72-inches on Center
Or
22 to 18 gage Type B ASTM A 653 Grade 80 Steel deck Supported 54-inches on Center

Steel deck shall be fastened with minimum #12 ITW Buildex Traxx/4 at a maximum spacing of 6 inches o.c. Side laps shall be fastened with #10 ITW Buildex Traxx/1 at a maximum spacing of 12 inches o.c.

System Type D(14): Sure-Weld, Sure-Weld EXTRA Membrane induction welded over mechanically fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Base and/or Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite		
Minimum 1.5-inch thick	**N/A**	**N/A**
SecurShield HD or H-Shield HD		
Minimum ½-inch thick	**N/A**	**N/A**
SECUROCK Gypsum Fiber or Glass Mat Roof Board		
Minimum ¼-inch thick	**N/A**	**N/A**
Dens Deck, Dens Deck Prime		
Minimum ¼-inch thick	**N/A**	**N/A**

Note: All layers of insulation shall be simultaneously attached. Refer to Roofing Application Standard RAS 117 for insulation attachment requirements.

Membrane: RhinoBond Plate and HPX Fasteners are installed 6-inches on center, in rows spaced maximum 10-feet on center. Minimum 60-mil Sure-Weld or Sure-Weld EXTRA membrane induction welded to RhinoBond Plates-TPO using RhinoBond induction tool.

Maximum Design Pressure: –52.5 psf (See General Limitation #7)

Membrane Type: Single Ply, Thermoplastic, TPO

Deck Type 7I: Recover, Insulated

Deck Description: 20 to18 gage Type B, ASTM A 653 Grade 80 Steel deck Supported 72-inches on Center

Steel deck shall be fastened with minimum #12 ITW Buildex Traxx/4 at a maximum spacing of 6 inches o.c. Side laps shall be fastened with #10 ITW Buildex Traxx/1 at a maximum spacing of 12 inches o.c.

System Type D(15): Sure-Weld, Sure-Weld EXTRA Membrane induction welded over mechanically fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Base and/or Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite		
Minimum 1.5-inch thick	**N/A**	**N/A**
SecurShield HD or H-Shield HD		
Minimum ½-inch thick	**N/A**	**N/A**
SECUROCK Gypsum Fiber or Glass Mat Roof Board		
Minimum ¼-inch thick	**N/A**	**N/A**
Dens Deck, Dens Deck Prime		
Minimum ¼-inch thick	**N/A**	**N/A**

Note: All layers of insulation shall be simultaneously attached. Refer to Roofing Application Standard RAS 117 for insulation attachment requirements.

Membrane: RhinoBond Plate and HPX Fasteners are installed 6-inches on center, in rows spaced maximum 5-feet on center. Minimum 60-mil Sure-Weld or Sure-Weld EXTRA membrane induction welded to RhinoBond Plates-TPO using RhinoBond induction tool.

Maximum Design Pressure: –67.5 psf (See General Limitation #7)

Membrane Type	Single Ply, Thermoplastic, TPO
Deck Type	Recover Insulated
Deck Description	Existing Standing/Lap Seam Roof System over structural purlins, minimum 16 ga., (0.0598 in., 1.5mm) to maximum 3/16 in. (4.8mm).
System Type D(16):	Membrane mechanically attached over preliminarily fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with the prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Base and/or Top Insulation Layer	**Insulation Fasteners (Table 3)**	**Fastener Density/ft^2**
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite		
Minimum 1.2-inch thick	**N/A**	**N/A**

Top Insulation Layer (Optional)	**Insulation Fasteners (Table 3)**	**Fastener Density/ft^2**
SecurShield HD or H-Shield HD		
Minimum ½-inch thick	**N/A**	**N/A**
SECUROCK Gypsum Fiber or Glass Mat Roof Board		
Minimum ¼-inch thick	**N/A**	**N/A**
Dens Deck, Dens Deck Prime		
Minimum ¼-inch thick	**N/A**	**N/A**

Note: Refer to Roofing Application Standard RAS 117 for insulation attachment requirements. Insulation shall have preliminary attachment, prior to the installation of the roofing membrane. At an application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: Sure-Weld, Sure-Weld HS or Sure-Weld EXTRA, Reinforced, secured through the preliminarily attached insulation as specified below

Fastening #1: 6-foot wide Sure-Weld or Sure-Weld EXTRA membrane mechanically fastened 12-inches on center through the field seams into the structural purlins using HP Purlin or HP RetroDriller Fasteners and Piranha Plates.
Maximum Design Pressure -45 psf. (See General Limitation #7)

Fastening #2: 8-foot wide Sure-Weld or Sure-Weld EXTRA membrane mechanically fastened 12-inches on center through the field seams into the structural purlins using HP Purlin or HP RetroDriller Fasteners and Piranha Plates.
Maximum Design Pressure-45 psf. (See General Limitation #7)

Membrane Type:	Single Ply, Thermoplastic, TPO
Deck Type 7I:	Recover, Insulated
Deck Description:	Minimum 22 ga., Type B, Grade 40 steel deck attached to structural steel supports, spaced maximum 72-inches on center, with 5/8-inch diameter puddle welds spaced 6-inches on center. Side laps shall be fastened with attached with Tek/1 screws spaced 12-inch o.c.
System Type D(17):	Membrane induction welded over mechanically fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Base Insulation Layer	**Insulation Fasteners (Table 3)**	**Fastener Density/ft²**
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite		
Minimum 1.5-inch thick	**2 and 8**	**1:4 ft²**

Top Insulation Layer (Optional)	**Insulation Fasteners (Table 3)**	**Fastener Density/ft²**
SecurShield HD or H-Shield HD		
Minimum ½-inch thick	**2 and 8**	**1:4 ft²**
SECUROCK Gypsum Fiber or Glass Mat Roof Board		
Minimum ¼-inch thick	**2 and 8**	**1:4 ft²**
Dens Deck, Dens Deck Prime		
Minimum ¼-inch thick	**2 and 8**	**1:4 ft²**

Note: All layers of insulation shall be simultaneously attached. Refer to Roofing Application Standard RAS 117 for insulation attachment requirements. Insulation shall have preliminary attachment, prior to the installation of the roofing membrane. At an application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Thermal Barrier:	(Optional) Thermal barrier of any approved type or thickness, loose-laid, adhered or mechanically attached.
Membrane Assembly:	Minimum 60-mil Sure-Weld, or Sure-Weld EXTRA membrane induction welded to RhinoBond Plates-TPO using RhinoBond induction tool.
Membrane Splices:	Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld along the outside edge.
Maximum Design Pressure:	-52.5 psf. (See General Limitation #7)

Membrane Type: Single Ply, Thermoplastic, TPO

Deck Type 7I: Recover, Insulated

Deck Description: Minimum 22 ga., Type B, Grade 80 steel deck attached to structural steel supports, spaced maximum 72-inches on center, with 5/8-inch diameter puddle welds spaced 6-inches on center. Side laps shall be fastened with attached with Tek/1 screws spaced 12-inch o.c.

System Type D(18): Membrane mechanically attached over preliminarily fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Base and/or Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
InsulBase, SecurShield, SecurShield HD Composite, H-Shield, H-Shield CG, H-Shield HD Composite		
Minimum 1.5-inch thick	**N/A**	**N/A**
SecurShield HD or H-Shield HD		
Minimum ½-inch thick	**N/A**	**N/A**
SECUROCK Gypsum Fiber or Glass Mat Roof Board		
Minimum ¼-inch thick	**N/A**	**N/A**
Dens Deck, Dens Deck Prime		
Minimum ¼-inch thick	**N/A**	**N/A**

Note: All layers of insulation shall be simultaneously attached. Refer to Roofing Application Standard RAS 117 for insulation attachment requirements. Insulation shall have preliminary attachment, prior to the installation of the roofing membrane. At an application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Thermal Barrier: (Optional) Thermal barrier of any approved type or thickness, loose-laid, adhered or mechanically attached.

Membrane: Minimum 60-mil Sure-Weld or Sure-Weld EXTRA membrane secured through the preliminarily attached insulation as specified below.

Membrane Fastening: 10-foot wide Sure-Weld, or Sure-Weld EXTRA membrane mechanically fastened 6-inches on center through the field seams using HPX Fasteners and Piranha Plates.

Membrane Splices: Overlap membrane splices a minimum of 5-1/2 inches to provide for a minimum 1-1/2 inch heat weld along the outside edge.

Maximum Design Pressure: -52.5 psf. (See General Limitation #7)

Membrane Type: Single Ply, Thermoplastic, TPO

Deck Type 7: Recover

Deck Description: Cementitious Wood Fiber (Tectum)

System Type F(1): Membrane adhered to existing modified bitumen.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Membrane: Sure-Weld FleeceBACK membrane adhered to the substrate with Flexible FAST, Flexible FAST Dual Cartridge or Flexible FAST 5-Gallon Jug Adhesive applied to the substrate in approximately 1/2 to 3/4-inch wide beads spaced 12-inches on center. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: –325 psf (See General Limitation #9)

Membrane Type: Single Ply, Thermoplastic, TPO, FleeceBACK

Deck Type 7: Recover

Deck Description: 2500 psi Structural Concrete

System Type F(2): Membrane adhered to existing modified bitumen.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Membrane: Sure-Weld FleeceBACK membrane adhered to the substrate with, Flexible FAST Dual Cartridge or Flexible FAST 5-Gallon Jug Adhesive applied to the substrate in approximately 1/2 to 3/4-inch wide beads spaced 12-inches on center. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: –410 psf (See General Limitation #9)

Membrane Type: Single Ply, Thermoplastic, TPO FleecBACK

Deck Type 7: Recover

Deck Description: Gypsum

System Type F(3): Membrane adhered to existing modified bitumen.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Membrane: Sure-Weld FleeceBACK membrane adhered to the substrate with Flexible FAST, Flexible FAST Dual Cartridge or Flexible FAST 5-Gallon Jug Adhesive applied to the substrate in approximately 1/2 to 3/4-inch wide beads spaced 12-inches on center. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: –400 psf (See General Limitation #9)

Membrane Type: Single Ply, Thermoplastic, TPO, FleeceBACK

Deck Type 7: Recover

Deck Description: Steel

System Type F(4): Membrane adhered to existing modified bitumen.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Membrane: Sure-Weld FleeceBACK membrane adhered to the substrate with Flexible FAST, Flexible FAST Dual Cartridge or Flexible FAST 5-Gallon Jug Adhesive applied to the substrate in approximately 1/2 to 3/4-inch wide beads spaced 12-inches on center. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.

Maximum Design Pressure: –350 psf (See General Limitation #9)

Membrane Type: Single Ply, Thermoplastic, TPO Reinforced, FleeceBACK

Deck Type 7: Recover

Deck Description: Concrete/Steel

System Type F(5): Membrane adhered direct to existing asphaltic BUR.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Membrane #1: Sure-Weld AFX membrane adhered to the existing asphaltic roof cover with hot asphalt applied at a rate of 20 to 25 lbs/sq. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.
Maximum Design Pressure: -367.5 psf (See General Limitation #9)

Membrane #2: Sure-Weld FleeceBACK membrane adhered to the existing asphaltic roof cover with, Flexible FAST Dual Cartridge or Flexible FAST 5-Gallon Jug Adhesive. The adhesive is applied to the substrate in approximately 1/2 to 3/4-inch wide beads spaced 6-inches on center or at 1 gal./sq, full coverage. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld.
Maximum Design Pressure: -75 psf (See General Limitation #9)

Maximum Design Pressure: **See Fastening Options Above**

Membrane Type: Single Ply, Thermoplastic, TPO

Deck Type 7: Recover

Deck Description: Steel

System Type F(6): Membrane adhered direct to existing Single-Ply EPDM.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Membrane: Sure-Weld FleeceBACK membrane adhered to the existing EPDM roof cover with Flexible FAST Dual Cartridge or Flexible FAST 5-Gallon Jug Adhesive. The adhesive is applied to the substrate in approximately 1/2 to 3/4-inch wide beads spaced 6-inches on center or at 1 gal./sq, full coverage. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld

Maximum Design Pressure: -75 psf (See General Limitation #7)

Membrane Type: Single Ply, Thermoplastic, TPO

Deck Type 7: Recover

Deck Description: 2500 psi Structural Concrete

System Type F(7): Membrane adhered direct to existing Single-Ply EPDM.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Membrane: Sure-Weld FleeceBACK membrane adhered to the existing EPDM roof cover with Flexible FAST, Flexible FAST Dual Cartridge or Flexible FAST 5-Gallon Jug Adhesive. The adhesive is applied to the substrate in approximately 1/2 to 3/4-inch wide beads spaced 6-inches on center or at 1 gal./sq, full coverage. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld

Maximum Design Pressure: -315 psf (See General Limitation #7)

Membrane Type: Single Ply, Thermoplastic, Reinforced, FleeceBACK

Deck Type 7: Recover, Non-Insulated

Deck Description: 2500 psi structural concrete

System Type F(8): Membrane fully adhered with Flexible FAST Adhesive, Asphalt or SureMB MC Adhesive.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Retarder: None.

Barrier: None.

Membrane: Sure-Weld AFX membrane fully adhered to the insulation with SureMB MC Adhesive applied to the substrate at a rate of 1 gal./67ft^2. Outside 1.5" of side laps are heat welded.

Maximum Design Pressure: -60 psf (See General Limitation #9)

Membrane Type: Single Ply, Thermoplastic, TPO

Deck Type 7I: Recover

Deck Description: 2500 psi structural concrete

System Type F(9): Membrane adhered to Elastizell Range II or Celcore Cellular lightweight insulating concrete.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Membrane: Sure-Weld, Sure-Weld EXTRA or Sure-Weld HS membrane adhered to the Elastizell LWIC using Sure-Weld Bonding Adhesive or Low VOC Bonding Adhesive. The adhesive is applied in a contact application and is applied to both the underside of the roofing membrane and the top side of the approved substrate at a rate of 60 ft²/gallon, finished surface area. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld. **Maximum Design Pressure: -90 psf (See General Limitation #9)**

OR

Sure-Weld, Sure-Weld EXTRA or Sure-Weld HS membrane adhered to the Celcore LWIC using Sure-Weld Bonding Adhesive or Low VOC Bonding Adhesive. The adhesive is applied in a contact application and is applied to both the underside of the roofing membrane and the top side of the approved substrate at a rate of 60 ft²/gallon, finished surface area. Overlap membrane splices a minimum of 2 inches to provide for a minimum 1-1/2 inch heat weld. **Maximum Design Pressure: -135 psf (See General Limitation #9)**

Maximum Design Pressure: **See Fastening Options Above**