## APPROVED ASSEMBLIES

**Membrane Type:** Single Ply, Thermoplastic, PVC

**Deck Type 6I**: Poured Gypsum, Insulated

**Deck Description:** Poured Gypsum Concrete

**System Type A(1):** One or more layers of insulation adhered with OMG OlyBond 500 or Fast 100-LV Adhesive; membrane fully adhered.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

| Insulation Layer | Insulation Fasteners (Table 3) | Fastener Density/ft$^2$ |
|---|---|---|
| **Polyisocyanurate HP-H Minimum 1.5" thick** | **N/A** | **N/A** |

**Note: All insulation shall be adhered with OMG OlyBond 500 in ribbons spaced 12" o.c. or Fast 100LV with full coverage application.**

**Barrier:** None.

**Membrane:** Sure-Flex, 50, 60 or 80 mil membrane fully adhered to the insulation using Low VOC PVC Bonding Adhesive applied to the substrate at a rate of 1 gal/60 ft.$^2$ The outside 1.5" of the roof cover lap is heat welded.

**Maximum Design Pressure:** -45 psf (See General Limitation #9)