APPROVED ASSEMBLIES

Membrane Type: Single Ply, Thermoplastic, PVC, Reinforced

Deck Type 1I: Wood, Insulated

Deck Description: $^{19}/_{32}$" or greater plywood, span rating 40/20 Grade CDX, 4 ply, attached to supports spaced 2-ft on center with 8d ring shank nails, 6-in o.c. at all supports.

System Type C(1): All layers of insulation simultaneously attached; membrane fully adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
One of the following covered with the boards listed in Top Layer.		
DensDeck, DensDeck Prime, Securock Minimum ¼" thick	**N/A**	**N/A**

Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
Polyisocyanurate HP-H or InsulBase Minimum 1.5" thick	**1, 2**	**1:2 ft²**

Note: Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Vapor Retarder: (Optional) Any UL or FMRC approved vapor retarder applied to the roof deck or over a base layer of insulation.

Membrane: Sure-Flex, Reinforced, 50, 60 or 80 mil membrane fully adhered to the insulation using Low VOC PVC Bonding Adhesive applied to the substrate at a rate of 1 gal/60 ft.² The outside 1.5" of the roof cover lap is heat welded.

Maximum Design Pressure: –45 psf (See General Limitation #7)

Membrane Type: Single Ply, Thermoplastic, PVC, Reinforced

Deck Type 1I: Wood, Insulated

Deck Description: $^{19}/_{32}$" or greater plywood, Grade CDX, attached to supports spaced 2-ft on center, with #8 ring shank nails at 4" o.c. in the field, and #10 ring shank nails 4-in o.c. at the perimeter.

System Type D(1): Membrane mechanically attached over preliminarily fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft^2
Polyisocyanurate HP-H or InsulBase, Insulfoam SP, R-Tech, R-Tech Fan-Fold Minimum 1.5" thick	**N/A**	**N/A**

Note: All layers of insulation and base sheet shall be simultaneously attached. See base sheet below for fasteners and density. Refer to Roofing Application Standard RAS 117 for insulation attachment requirements. Insulation shall have preliminary attachment, prior to the installation of the roofing membrane. At an application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

Vapor Retarder: (Optional) Any UL or FMRC approved vapor retarder applied to the roof deck or over a base layer of insulation.

Barrier (optional): ¼", $^3/_8$", ½", or $^5/_8$" gypsum, Dens-Deck, Securock, FR Base Sheet, G2 Base Sheet or G3 Cap (flipped)

Membrane: Sure-Flex, Reinforced 50, 60 or 80 mil membrane secured through the preliminarily attached insulation as specified below.

Fastening: HP-X Fasteners with Piranha Plates 6" o.c. through the membrane in the 5½" side lap in rows spaced 81'" o.c. followed by applying a 1½" wide heat weld.

Maximum Design Pressure: -60 psf. (See General Limitation #7)