



Project Status

Project: CAJ

Start date: mardi 2 décembre 2025

Print date: mardi 2 décembre 2025

Print time: 18:51:20

Status: Tested

Topology CAJ

Address Description Serial Number Comments Installation Notes Programming Flags	Manufacturer	Order Number	Product	Application	Status
0	IP	IP backbone area			
4.0.-	Schneider Electric Industries SAS	MTN684016	KNX power supply REG-K/160 mA		
	Garage				
<input type="checkbox"/> Adr	<input type="checkbox"/> Prg	<input type="checkbox"/> Par	<input type="checkbox"/> Grp	<input type="checkbox"/> Cfg	
4.0.-	Schneider Electric Industries SAS	MTN684016	KNX power supply REG-K/160 mA		
	Garage				
<input type="checkbox"/> Adr	<input type="checkbox"/> Prg	<input type="checkbox"/> Par	<input type="checkbox"/> Grp	<input type="checkbox"/> Cfg	
4.0.10	Schneider Electric Industries SAS	MTN644592	Binary input REG-K/ 8x10	Multifunction.Counter 12BA/1.1	
	Garage				
<input type="checkbox"/> Adr	<input type="checkbox"/> Prg	<input type="checkbox"/> Par	<input type="checkbox"/> Grp	<input type="checkbox"/> Cfg	
4.0.11	Schneider Electric Industries SAS	MTN646991	Control unit 0-10 V REG-K/3f with manual mode	Universal dimming 3211/1.1	
Actuators for dimming lights:					
- Corridor dimming light					
- Hall second dimming light					
	Garage				
<input type="checkbox"/> Adr	<input type="checkbox"/> Prg	<input type="checkbox"/> Par	<input type="checkbox"/> Grp	<input type="checkbox"/> Cfg	
4.0.50	Schneider Electric Industries SAS	MTN663990	KNX weather station basic	Weather station 2420/1.2	
The weather station is set up to send an alarm if the wind speed is higher than 5 km/s.					
<input type="checkbox"/> Adr	<input type="checkbox"/> Prg	<input type="checkbox"/> Par	<input type="checkbox"/> Grp	<input type="checkbox"/> Cfg	
4.1.0	Schneider Electric Industries SAS	MTN680204	Coupler REG-K	Coupler 7115/1.0	
Line Coupler					
<input type="checkbox"/> Adr	<input type="checkbox"/> Prg	<input type="checkbox"/> Par	<input type="checkbox"/> Grp	<input type="checkbox"/> Cfg	
4.1.1	Schneider Electric Industries SAS	MTN681829	USB interface REG-K		
USB Interface					
<input type="checkbox"/> Adr	<input type="checkbox"/> Prg	<input type="checkbox"/> Par	<input type="checkbox"/> Grp	<input type="checkbox"/> Cfg	
4.1.10	Schneider Electric Industries SAS	MTN649908	Blind/Switch actuator REG-K/8x/16x/10 manual mode	Blind.Switch 5701/1.0	
Actuator that controls the blinds and lights in Bedroom 3, the Toilet, the Garage, and the Living Room.					
<input type="checkbox"/> Adr	<input type="checkbox"/> Prg	<input type="checkbox"/> Par	<input type="checkbox"/> Grp	<input type="checkbox"/> Cfg	
4.1.11	Schneider Electric Industries SAS	MTN649204	Switch actuator REG-K/4x230/10 with manual mode	Switch.Logic.Timer.Scene. Dis.Prio.Init.4820/1.1	

Topology CAJ

Address Description Serial Number Comments Installation Notes Programming Flags	Manufacturer	Order Number	Product	Application	Status
4.1	TP	TP line			
Switch for lights in: Bedroom 1, Office Room, first Hall light, and Kitchen.					
<input type="checkbox"/> Adr	<input type="checkbox"/> Prg	<input type="checkbox"/> Par	<input type="checkbox"/> Grp	<input type="checkbox"/> Cfg	
4.1.12	Schneider Electric Industries SAS	MTN647595	Switch actuator REG-K/4x230/16	Switch.Logic.Currentdet.P WM 4806/1.1	
Actuator for lights in Bedroom 2 and Dining Room					
<input type="checkbox"/> Adr	<input type="checkbox"/> Prg	<input type="checkbox"/> Par	<input type="checkbox"/> Grp	<input type="checkbox"/> Cfg	
4.1.13	Schneider Electric Industries SAS	MTN645094	KNX Fan coil actuator REG-K	Fan coil actuator 4253/1.0	
Fail-safe for the coil acutator					
<input type="checkbox"/> Adr	<input type="checkbox"/> Prg	<input type="checkbox"/> Par	<input type="checkbox"/> Grp	<input type="checkbox"/> Cfg	
4.1.31	Schneider Electric Industries SAS	MTN6172xx	Push-button 2-gang plus	Universal 1815/1.1	
Push button that controls: 1st - Kitchen Light 2nd - First hall light 3rd - Office Room Light 4th - Bedroom 1 Light					
<input type="checkbox"/> Adr	<input type="checkbox"/> Prg	<input type="checkbox"/> Par	<input type="checkbox"/> Grp	<input type="checkbox"/> Cfg	
4.1.32	Schneider Electric Industries SAS	MTN6172xx	Push-button 2-gang plus	Universal 1815/1.1	
Push button that controls: 1st - Dining Room light 2nd - Hall second dimming light 3rd - Corridor dimming light 4th - Bedroom 2 light					
<input type="checkbox"/> Adr	<input type="checkbox"/> Prg	<input type="checkbox"/> Par	<input type="checkbox"/> Grp	<input type="checkbox"/> Cfg	
4.1.33	Schneider Electric Industries SAS	MTN6172xx	Push-button 2-gang plus	Universal 1815/1.1	
Push button that controls: 1st - Living Room light 3rd - Bathroom light 4th - Bedroom 3 light					
<input type="checkbox"/> Adr	<input type="checkbox"/> Prg	<input type="checkbox"/> Par	<input type="checkbox"/> Grp	<input type="checkbox"/> Cfg	
4.1.34	Schneider Electric Industries SAS	MTN6316xx	KNX ARGUS 180 UP	Movement/monitoring 1305/1.0	
Movement Controller					
<input type="checkbox"/> Adr	<input type="checkbox"/> Prg	<input type="checkbox"/> Par	<input type="checkbox"/> Grp	<input type="checkbox"/> Cfg	
4.1.35	Schneider Electric Industries SAS	MTN6212-03xx	Push-button, 2-gang plus, room temp. control	Multifunction with RTCU and FanCoil 1816/1.0	
mardi 2 décembre 2025		18:51:20	0.0	IP backbone area	3/4

Address	Manufacturer	Order Number	Product	Application	Status
Description					
Serial Number	Room		Trade		
Comments					
Installation Notes					
Programming Flags					

4.1 TP TP line

Temp. Controller

☐ Adr ☐ Prg ☐ Par ☐ Grp ☐ Cfg

4.1.36 Schneider Electric MTN6174xx Push-button 4-gang plus Universal 1815/1.1
Industries SAS

Push button that controls the blinds:

1st - Bedroom 1

2nd - Kitchen

3rd - Bedroom 3

4th - Living room

6th - Bedroom 2

☐ Adr ☐ Prg ☐ Par ☐ Grp ☐ Cfg