

**SAMPLE FORM – NOT VALID FOR SUBMISSION TO BUILDING DEPARTMENTS****CERTIFICATE OF VERIFICATION****Note:** This table completed by **HERSECC** Registry.

Project Name:	Enforcement Agency:
Dwelling Address:	Permit Number:
City and Zip Code:	Permit Application Date:

A. Air Barrier Materials

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met unless otherwise noted in the Verification Status and the Correction Notes.

Note: SPF insulation is an acceptable air barrier and sealant when installed to a minimum thickness of 2 inches for closed cell and 5.5 inches for open cell, except where not allowed by manufacturer (e.g., flues, vents, can lights, etc.).

01	A continuous sealed exterior air barrier is required in all thermal envelope assemblies to limit air movement between unconditioned/outside spaces and conditioned/inside spaces, and must comply using one of the following methods: - Using individual materials that have an air permeance not exceeding 0.004 cfm/ft² under a pressure differential of 0.3 in. w.g. (1.57 pcf) (0.02 L/s.m² at 75 pa) when tested in accordance with ASTM E2178; or - Using assemblies of materials and components that have an average air leakage not to exceed 0.04 cfm/ft² under a pressure differential of 0.3 in. w.g. (1.57 pcf) (0.2 L/s.m² at 75 pa) when tested in accordance with ASTM E2357, ASTM E1677, ASTM E1680, or ASTM E283; or - Testing the complete building and demonstrating that the air leakage rate of the building envelope does not exceed 0.40 cfm/ft² at a pressure differential of 0.3 in. w.g. (1.57 pcf) (2.0 L/s.m² at 75 pa) in accordance with ASTM E779 or an equivalent approved method.	
02	Method of Compliance	
03	Verification Status	☐ Pass - all applicable requirements are met; or ☐ Fail - one or more applicable requirements are not met. Enter reason for failure in corrections notes field below; or ☐ All N/A - This entire table is not applicable.
04	Correction Notes	

B. Raised Floor Adjacent to Unconditioned Space or Separate Dwelling Units

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met unless otherwise noted in the Verification Status and the Correction Notes.

01	All gaps in the raised floor are sealed.	
02	All chases are sealed at floor level using a sealed hard cover.	
03	All holes (e.g., for plumbing and electrical wires) that penetrate the floor or bottom plates of walls are sealed.	
04	Subfloor sheathing is glued or sealed at all panel edges to create a continuous airtight subfloor air barrier.	
05	Verification Status	☐ Pass - all applicable requirements are met; or ☐ Fail - one or more applicable requirements are not met. Enter reason for failure in corrections notes field below; or ☐ All N/A - This entire table is not applicable.
06	Correction Notes	

**SAMPLE FORM – NOT VALID FOR SUBMISSION TO BUILDING DEPARTMENTS****C. Walls Adjacent to Unconditioned Space**

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met unless otherwise noted in the Verification Status and the Correction Notes.

01	All penetrations through the exterior wall air barrier are sealed to provide an airtight envelope to unconditioned spaces such as the outdoors, attic, garage, and crawlspace.	
02	Exterior wall air barrier is sealed to the top plate and bottom plate in each stud bay.	
03	All electrical boxes, including knockouts, that penetrate the air barrier to unconditioned space are sealed.	
04	All openings in the top and bottom plate, including all interior and exterior walls, to unconditioned space are sealed; such as holes drilled for electrical and plumbing.	
05	Exterior bottom plates (all stories) are sealed to the floor.	
06	All gaps around windows and doors are sealed. The sealant used follows manufacturer specifications.	
07	Rim joist gaps and openings are fully sealed.	
08	Fan exhaust duct outlet/damper at the exterior wall are sealed.	
09	Knee walls have solid and sealed blocking at the bottom, top, left, and right sides to prevent air movement into insulation.	
10	Verification Status	☐ Pass - all applicable requirements are met; or ☐ Fail - one or more applicable requirements are not met. Enter reason for failure in corrections notes field below; or ☐ All N/A - This entire table is not applicable.
11	Correction Notes	

D. Ceiling Air Barrier Adjacent to Unconditioned Space

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met unless otherwise noted in the Verification Status and the Correction Notes.

01	There is a continuous air barrier at the ceiling level. All openings into walls, drops, chases or double walls are sealed.	
02	All penetrations through the top plate of interior and exterior walls are sealed.	
03	Fire sprinklers penetrating a ceiling air barrier shall be sealed to prevent air movement according to the manufacturer's instructions.	
04	All fixtures cut into ceiling air barrier (e.g., HVAC registers, electrical boxes, fire alarm boxes, exhaust fan housing, and recessed lighting fixtures) are sealed to the surrounding dry wall. If it is not possible to seal the fixture directly, a secondary air barrier shall be created around the fixture.	
05	All installed recessed lighting fixtures that penetrate the ceiling to unconditioned space are rated to be Insulation Contact and Airtight (IC and AT) which allow direct contact with insulation.	
06	All dropped ceiling areas are covered with hard covers that are sealed to the framing, or else the bottom and sides of dropped ceiling areas are all insulated and sealed as ceilings and walls as required on the Certificate of Compliance.	
07	All vertical chases (e.g., HVAC ducts and plumbing) and soffits are sealed at the ceiling level.	
08	Chimneys and flues require sheet metal flashing at the ceiling level. The flashing shall be sealed to the chimney/flue with fire rated caulk. The flashing shall be sealed to the surrounding framing.	
09	Framing locations where air may move down into the walls from the attic (e.g., double walls, pocket doors, architectural bump-outs, etc.) have a sealed hard cover to prevent air movement.	
10	Attic access forms an airtight seal between the conditioned space and unconditioned space. Vertical attic access requires mechanical compression using screws or latches.	
11	Verification Status	☐ Pass - all applicable requirements are met; or ☐ Fail - one or more applicable requirements are not met. Enter reason for failure in corrections notes field below; or ☐ All N/A - This entire table is not applicable.
12	Correction Notes	

**SAMPLE FORM – NOT VALID FOR SUBMISSION TO BUILDING DEPARTMENTS****E. Roof Air Barrier – Unvented Attics Adjacent to Unconditioned Space**

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met unless otherwise noted in the Verification Status and the Correction Notes.

01	There is a continuous air barrier at the roof deck and gable ends.	
02	Chimneys and flues require sheet metal flashing at the roof deck. The flashing is sealed to the chimney/flue with fire rated caulk. The flashing is sealed to the surrounding framing.	
03	All penetrations in the roof deck and gable ends for plumbing, electrical, etc. are sealed.	
04	Verification Status	☐ Pass - all applicable requirements are met; or ☐ Fail - one or more applicable requirements are not met. Enter reason for failure in corrections notes field below; or ☐ All N/A - This entire table is not applicable.
05	Correction Notes	

F. Conditioned Space Above or Adjacent to Garage Air Barrier

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met unless otherwise noted in the Verification Status and the Correction Notes.

01	All penetrations in the subfloor above the garage into conditioned space must follow the raised floor air barrier requirements.	
02	Infiltration between the space above the garage and the subfloor is prevented by one of the following methods: - Seal all edges of the garage ceiling (typically drywall) at the perimeter of the garage to create a continuous airtight surface between the garage and adjacent conditioned envelope. Seal all plumbing, electrical, and mechanical penetrations between the garage and adjacent conditioned space. For an open-web truss, airtight blocking is added on all four sides of the garage perimeter. Insulation can be placed on the garage ceiling. - Seal the band joist above the wall at the garage to conditioned space transition. Seal all subfloor seams and penetrations between the garage and adjacent conditioned space. Insulation must be placed in contact with the subfloor below the conditioned space.	
03	Verification Status	☐ Pass - all applicable requirements are met; or ☐ Fail - one or more applicable requirements are not met. Enter reason for failure in corrections notes field below; or ☐ All N/A - This entire table is not applicable.
04	Correction Notes	

G. Cantilevered Floor Air Barrier

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met unless otherwise noted in the Verification Status and the Correction Notes.

01	Airtight blocking is installed between joists where the wall rim joist would have been located in the absence of a cantilever.	
02	Exterior sheathing is installed to the bottom of the cantilever so that there is a continuous air and weather barrier for the cantilever. The cantilevered joist must be insulated to the same R-value as would be required for the subfloor prior to closing.	
03	Any gaps, cracks or penetrations in the air barrier of the cantilever are sealed. Recessed can lights in the cantilever are rated to be Insulation Contact and Airtight (IC and AT) and properly sealed to the sheathing.	
04	Verification Status	☐ Pass - all applicable requirements are met; or ☐ Fail - one or more applicable requirements are not met. Enter reason for failure in corrections notes field below; or ☐ All N/A - This entire table is not applicable.
05	Correction Notes	

**SAMPLE FORM – NOT VALID FOR SUBMISSION TO BUILDING DEPARTMENTS****H. Walls for Attached Porch, Attic, Double Wall Air Barrier**

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met unless otherwise noted in the Verification Status and the Correction Notes.

01	An exterior wall air barrier is required at the intersection of the porch and exterior wall when there is conditioned space on the other side. The exterior wall includes an air barrier where the attic attaches to the conditioned space.	
02	Truss framing blocking is used at the top and bottom of each wall/roof section.	
03	Verification Status	☐ Pass - all applicable requirements are met; or ☐ Fail - one or more applicable requirements are not met. Enter reason for failure in corrections notes field below; or ☐ All N/A - This entire table is not applicable.
04	Correction Notes	

I. Air Barriers in Multifamily Dwellings

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met unless otherwise noted in the Verification Status and the Correction Notes.

01	Each dwelling unit must be sealed to stop air movement between dwelling units. Treat adjacent dwelling units as unconditioned space for air sealing.	
02	All penetrations through the floor and ceiling of each dwelling unit are sealed, including electric and gas utilities, water pipes, drain pipes, fire protection service pipes, and communication wiring.	
03	Elevator penthouse, mechanical penthouse, stairwell doors, roof access hatches, and plumbing stacks that separate conditioned and unconditioned space are all sealed.	
04	Vertical chases for garbage chutes, elevator shafts, HVAC ducting and plumbing shall be treated as unconditioned space for sealing.	
05	Common hallways shall be treated as unconditioned space for sealing.	
06	Verification Status	☐ Pass - all applicable requirements are met; or ☐ Fail - one or more applicable requirements are not met. Enter reason for failure in corrections notes field below; or ☐ All N/A - This entire table is not applicable.
07	Correction Notes	

J. Special Requirements for SIPs

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met unless otherwise noted in the Verification Status and the Correction Notes.

01	SIPs are considered an air barrier when properly sealed at top, bottom, sides, and all penetrations.	
02	Air barrier is continuous across all surfaces, including between SIPs and non-SIP sections.	
03	Verification Status	☐ Pass - all applicable requirements are met; or ☐ Fail - one or more applicable requirements are not met. Enter reason for failure in corrections notes field below; or ☐ All N/A - This entire table is not applicable.
04	Correction Notes	

K. Special Requirements for ICF

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met unless otherwise noted in the Verification Status and the Correction Notes.

01	ICF sections are considered an air barrier when properly sealed at top, bottom, sides and all penetrations.	
02	Air barrier is continuous across all surfaces, including between ICF and non-ICF sections.	
03	Verification Status	☐ Pass - all applicable requirements are met; or ☐ Fail - one or more applicable requirements are not met. Enter reason for failure in corrections notes field below; or ☐ All N/A - This entire table is not applicable.
04	Correction Notes	

**SAMPLE FORM – NOT VALID FOR SUBMISSION TO BUILDING DEPARTMENTS****L. Determination of HERSECC Verification Compliance**

All applicable sections of this document shall indicate compliance with the specified verification protocol requirements in order for this Certificate of Verification as a whole to be determined to be in compliance.

01

**SAMPLE FORM – NOT VALID FOR SUBMISSION TO BUILDING DEPARTMENTS****DOCUMENTATION AUTHOR'S DECLARATION STATEMENT**

1. I certify that this Certificate of Installation documentation is accurate and complete.

Documentation Author Name:	Documentation Author Signature:
Company:	Date Signed:
Address:	CEA/AEA/ HERSECC Certification Identification (If applicable):
City/State/Zip:	Phone:

RESPONSIBLE PERSON'S DECLARATION STATEMENT

I certify the following under penalty of perjury, under the laws of the State of California:

1. The information provided on this Certificate of Verification is true and correct.
2. I am the certified **HERSECC** Rater who performed the verification identified and reported on this Certificate of Verification (responsible rater).
3. The installed features, materials, components, manufactured devices, or system performance diagnostic results that require **HERSECC** verification identified on this Certificate of Verification comply with the applicable requirements in Reference Appendices RA2, RA3, and the requirements specified on the Certificate of Compliance for the building approved by the enforcement agency.
4. The information reported on applicable sections of the Certificate(s) of Installation (LMCI) signed and submitted by the person(s) responsible for the construction or installation conforms to the requirements specified on the Certificate(s) of Compliance (LMCC) approved by the enforcement agency.
5. I understand that a registered copy of this Certificate of Verification shall be posted, or made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections, and I will take the necessary steps to ensure this requirement is accomplished.
6. I understand that a registered copy of this Certificate of Verification is required to be included with the documentation the builder provides to the building.

Responsible Builder/Installer Name:	Responsible Builder/Installer Signature:	
Company Name: (Installing Subcontractor or General Contractor or Builder/Owner)	Position With Company (Title):	
Address:	CSLB License:	
City/State/Zip:	Phone:	Date Signed:
Third Party Quality Control Program (TPQCP) Status:	Name of TPQCP (if applicable):	

BUILDER OR INSTALLER INFORMATION AS SHOWN ON THE CERTIFICATE OF INSTALLATION

Company Name (Installing Subcontractor, General Contractor, or Builder/Owner):	
Responsible Builder or Installer Name:	CSLB License:

****HERSECC** PROVIDER DATA REGISTRY INFORMATION**

Sample Group Number (if applicable):	Dwelling Test Status in Sample Group (if applicable):
--------------------------------------	---

****HERSECC** RATER INFORMATION**

HERSECC Rater Company Name:	
Responsible Rater Name:	Responsible Rater Signature:
Responsible Rater Certification Number w/ this HERSECC	Date Signed:

LMCV-ENV-21 User Instructions

Quality Insulation Installation (QII) applies to the entire building (roof/ceiling, walls, and floor) for new construction and requires field verification by a third-party ~~HERS~~ECC Rater. For Alterations to existing buildings, compliance credit can only be taken when the “existing, plus addition, plus alteration” approach is used, but credit will only apply to the new surfaces in the new zone.

A. Air Barrier Materials

2. Method of Compliance: Using the drop down menu, indicate which method is being used to comply with the continuous air barrier requirements [e.g., Method 1 (Individual Materials), Method 2 (Assemblies of Materials), Method 3 (Complete Building)].
3. Verification Status: ~~HERS~~ECC Rater to select from list:
 - a. Pass – all applicable requirements are met.
 - b. Fail – one or more applicable requirements are not met. Rater must enter reason for failure in correction notes field below.
 - c. All N/A – This entire table is not applicable.
4. Correction Notes: Rater must enter the reason for failure.

B. Raised Floor Adjacent to Unconditioned Space or Separate Dwelling Unit

5. Verification Status: ~~HERS~~ECC Rater to select from list:
 - a. Pass – all applicable requirements are met.
 - b. Fail – one or more applicable requirements are not met. Rater must enter reason for failure in correction notes field below.
 - c. All N/A – This entire table is not applicable.
6. Correction Notes: Rater must enter the reason for failure.

C. Walls Adjacent to Unconditioned Space

10. Verification Status: ~~HERS~~ECC Rater to select from list:
 - a. Pass – all applicable requirements are met.
 - b. Fail – one or more applicable requirements are not met. Rater must enter reason for failure in correction notes field below.
 - c. All N/A – This entire table is not applicable.
11. Correction Notes: Rater must enter the reason for failure.

D. Ceiling Air Barrier Adjacent to Unconditioned Space

11. Verification Status: ~~HERS~~ECC Rater to select from list:
 - a. Pass – all applicable requirements are met.
 - b. Fail – one or more applicable requirements are not met. Rater must enter reason for failure in correction notes field below.
 - c. All N/A – This entire table is not applicable.
12. Correction Notes: Rater must enter the reason for failure.

E. Roof Air Barrier – Unvented Attics Adjacent to Unconditioned Space

4. Verification Status: ~~HERS~~ECC Rater to select from list:
 - a. Pass – all applicable requirements are met.
 - b. Fail – one or more applicable requirements are not met. Rater must enter reason for failure in correction notes field below.

- c. All N/A – This entire table is not applicable.
- 5. Correction Notes: Rater must enter the reason for failure.

F. Conditioned Space Above or Adjacent to Garage Air Barrier

- 3. Verification Status: ~~HERS~~ECC Rater to select from list:
 - a. Pass – all applicable requirements are met.
 - b. Fail – one or more applicable requirements are not met. Rater must enter reason for failure in correction notes field below.
 - c. All N/A – This entire table is not applicable.
- 4. Correction Notes: Rater must enter the reason for failure.

G. Cantilevered Floor Air Barrier

- 4. Verification Status: ~~HERS~~ECC Rater to select from list:
 - a. Pass – all applicable requirements are met.
 - b. Fail – one or more applicable requirements are not met. Rater must enter reason for failure in correction notes field below.
 - c. All N/A – This entire table is not applicable.
- 5. Correction Notes: Rater must enter the reason for failure.

H. Walls for Attached Porch, Attic, Double Wall Air Barrier

- 3. Verification Status: ~~HERS~~ECC Rater to select from list:
 - a. Pass – all applicable requirements are met.
 - b. Fail – one or more applicable requirements are not met. Rater must enter reason for failure in correction notes field below.
 - c. All N/A – This entire table is not applicable.
- 4. Correction Notes: Rater must enter the reason for failure.

I. Air Barrier in Multifamily Dwellings

- 6. Verification Status: ~~HERS~~ECC Rater to select from list:
 - a. Pass – all applicable requirements are met.
 - b. Fail – one or more applicable requirements are not met. Rater must enter reason for failure in correction notes field below.
 - c. All N/A – This entire table is not applicable.
- 7. Correction Notes: Rater must enter the reason for failure.

J. Special Requirements for SIPs

- 3. Verification Status: ~~HERS~~ECC Rater to select from list:
 - a. Pass – all applicable requirements are met.
 - b. Fail – one or more applicable requirements are not met. Rater must enter reason for failure in correction notes field below.
 - c. All N/A – This entire table is not applicable.
- 4. Correction Notes: Rater must enter the reason for failure.

K. Special Requirements for ICF

- 3. Verification Status: ~~HERS~~ECC Rater to select from list:
 - a. Pass – all applicable requirements are met.
 - b. Fail – one or more applicable requirements are not met. Rater must enter reason for failure in correction notes field below.

- c. All N/A – This entire table is not applicable.
4. Correction Notes: Rater must enter the reason for failure.

Documentation Declaration Statements

1. The person who prepared the LMCV will sign and complete the fields for their name, company (if applicable), address, phone number, certification information (if applicable), date and signature.
2. The person who is assuming responsibility for the project being built to comply with Title 24, Part 6, will complete the fields (if applicable) for their company, responsible builder or installer name, CSLB license number, sample group number, dwelling test status in sample group, ECC Rater company name, ECC Rater name, ECC Rater signature, ECC Rater certification number and date signed.

A. Air Barrier Materials

01	A continuous sealed exterior air barrier is required in all thermal envelope assemblies to limit air movement between unconditioned/outside spaces and conditioned/inside spaces, and must comply using one of the following methods: - Using individual materials that have an air permeance not exceeding 0.004 cfm/ft² under a pressure differential of 0.3 in. w.g. (1.57 pcf) (0.02 L/s.m² at 75 pa) when tested in accordance with ASTM E2178; or - Using assemblies of materials and components that have an average air leakage not to exceed 0.04 cfm/ft² under a pressure differential of 0.3 in. w.g. (1.57 pcf) (0.2 L/s.m² at 75 pa) when tested in accordance with ASTM E2357, ASTM E1677, ASTM E1680, or ASTM E283; or Testing the complete building and demonstrating that the air leakage rate of the building envelope does not exceed 0.40 cfm/ft² at a pressure differential of 0.3 in. w.g. (1.57 pcf) (2.0 L/s.m² at 75 pa) in accordance with ASTM E779 or an equivalent approved method.	
02	Method of Compliance	<<user select one from list: *Method 1 (Individual Materials); *Method 2 (Assemblies of Materials); or *Method 3 (Complete Building)>>
03	Verification Status	☐ Pass - all applicable requirements are met; or ☐ Fail - one or more applicable requirements are not met. Enter reason for failure in corrections notes field below; or All N/A - This entire table is not applicable.
04	Correction Notes	<<if Verification Status= Fail, then text entry in this Corrections Notes field is required; user input text>>
Note: <<Static Text - see the top>>		
The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met unless otherwise noted in the Verification Status and the Correction Notes.		

B. Raised Floor Adjacent to Unconditioned Space or Separate Dwelling Units

01	All gaps in the raised floor are sealed.	
02	All chases are sealed at floor level using a sealed hard cover.	
03	All holes (e.g., for plumbing and electrical wires) that penetrate the floor or bottom plates of walls are sealed.	
04	Subfloor sheathing is glued or sealed at all panel edges to create a continuous airtight subfloor air barrier.	
05	Verification Status	☐ Pass - all applicable requirements are met; or ☐ Fail - one or more applicable requirements are not met. Enter reason for failure in corrections notes field below; or All N/A - This entire table is not applicable.
06	Correction Notes	<<if Verification Status= Fail, then text entry in this Corrections Notes field is required; user input text>>
The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met unless otherwise noted in the Verification Status and the Correction Notes.		

C. Walls Adjacent to Unconditioned Space

01	All penetrations through the exterior wall air barrier are sealed to provide an airtight envelope to unconditioned spaces such as the outdoors, attic, garage, and crawlspace.	
02	Exterior wall air barrier is sealed to the top plate and bottom plate in each stud bay.	
03	All electrical boxes, including knockouts, that penetrate the air barrier to unconditioned space are sealed.	
04	All openings in the top and bottom plate, including all interior and exterior walls, to unconditioned space are sealed; such as holes drilled for electrical and plumbing.	
05	Exterior bottom plates (all stories) are sealed to the floor.	
06	All gaps around windows and doors are sealed. The sealant used follows manufacturer specifications.	
07	Rim joist gaps and openings are fully sealed.	
08	Fan exhaust duct outlet/damper at the exterior wall are sealed.	
09	Knee walls have solid and sealed blocking at the bottom, top, left, and right sides to prevent air movement into insulation.	
10	Verification Status	☐ Pass - all applicable requirements are met; or ☐ Fail - one or more applicable requirements are not met. Enter reason for failure in corrections notes field below; or ☐ All N/A - This entire table is not applicable.
11	Correction Notes	<<if Verification Status= Fail, then text entry in this Corrections Notes field is required; user input text>>
The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met unless otherwise noted in the Verification Status and the Correction Notes.		

D. Ceiling Air Barrier Adjacent to Unconditioned Space

01	There is a continuous air barrier at the ceiling level. All openings into walls, drops, chases or double walls are sealed.	
02	All penetrations through the top plate of interior and exterior walls are sealed.	
03	Fire sprinklers penetrating a ceiling air barrier shall be sealed to prevent air movement according to the manufacturer's instructions.	
04	All fixtures cut into ceiling air barrier (e.g., HVAC registers, electrical boxes, fire alarm boxes, exhaust fan housing, and recessed lighting fixtures) are sealed to the surrounding dry wall. If it is not possible to seal the fixture directly, a secondary air barrier shall be created around the fixture.	
05	All installed recessed lighting fixtures that penetrate the ceiling to unconditioned space are rated to be Insulation Contact and Airtight (IC and AT) which allow direct contact with insulation.	
06	All dropped ceiling areas are covered with hard covers that are sealed to the framing, or else the bottom and sides of dropped ceiling areas are all insulated and sealed as ceilings and walls as required on the Certificate of Compliance.	
07	All vertical chases (e.g., HVAC ducts and plumbing) and soffits are sealed at the ceiling level.	
08	Chimneys and flues require sheet metal flashing at the ceiling level. The flashing shall be sealed to the chimney/flue with fire rated caulk. The flashing shall be sealed to the surrounding framing.	
09	Framing locations where air may move down into the walls from the attic (e.g., double walls, pocket doors, architectural bump-outs, etc.) have a sealed hard cover to prevent air movement.	
10	Attic access forms an airtight seal between the conditioned space and unconditioned space. Vertical attic access requires mechanical compression using screws or latches.	
11	Verification Status	☐ Pass - all applicable requirements are met; or ☐ Fail - one or more applicable requirements are not met. Enter reason for failure in corrections notes field below; or ☐ All N/A - This entire table is not applicable.
12	Correction Notes	<<if Verification Status= Fail, then text entry in this Corrections Notes field is required; user input text>>

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met unless otherwise noted in the Verification Status and the Correction Notes.

E. Roof Air Barrier – Unvented Attics Adjacent to Unconditioned Space

01	There is a continuous air barrier at the roof deck and gable ends.	
02	Chimneys and flues require sheet metal flashing at the roof deck. The flashing is sealed to the chimney/flue with fire rated caulk. The flashing is sealed to the surrounding framing.	
03	All penetrations in the roof deck and gable ends for plumbing, electrical, etc. are sealed.	
04	Verification Status	☐ Pass - all applicable requirements are met; or ☐ Fail - one or more applicable requirements are not met. Enter reason for failure in corrections notes field below; or ☐ All N/A - This entire table is not applicable.
05	Correction Notes	<<if Verification Status= Fail, then text entry in this Corrections Notes field is required; user input text>>

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met unless otherwise noted in the Verification Status and the Correction Notes.

F. Conditioned Space Above or Adjacent to Garage Air Barrier

01	All penetrations in the subfloor above the garage into conditioned space must follow the raised floor air barrier requirements.	
02	Infiltration between the space above the garage and the subfloor is prevented by one of the following methods: - Seal all edges of the garage ceiling (typically drywall) at the perimeter of the garage to create a continuous airtight surface between the garage and adjacent conditioned envelope. Seal all plumbing, electrical, and mechanical penetrations between the garage and adjacent conditioned space. For an open-web truss, airtight blocking is added on all four sides of the garage perimeter. Insulation can be placed on the garage ceiling. - Seal the band joist above the wall at the garage to conditioned space transition. Seal all subfloor seams and penetrations between the garage and adjacent conditioned space. Insulation must be placed in contact with the subfloor below the conditioned space.	
03	Verification Status	☐ Pass - all applicable requirements are met; or ☐ Fail - one or more applicable requirements are not met. Enter reason for failure in corrections notes field below; or ☐ All N/A - This entire table is not applicable.
04	Correction Notes	<<if Verification Status= Fail, then text entry in this Corrections Notes field is required; user input text>>

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met unless otherwise noted in the Verification Status and the Correction Notes.

G. Cantilevered Floor Air Barrier

01	Airtight blocking is installed between joists where the wall rim joist would have been located in the absence of a cantilever.	
02	Exterior sheathing is installed to the bottom of the cantilever so that there is a continuous air and weather barrier for the cantilever. The cantilevered joist must be insulated to the same R-value as would be required for the subfloor prior to closing.	
03	Any gaps, cracks or penetrations in the air barrier of the cantilever are sealed. Recessed can lights in the cantilever are rated to be Insulation Contact and Airtight (IC and AT) and properly sealed to the sheathing.	
04	Verification Status	☐ Pass - all applicable requirements are met; or ☐ Fail - one or more applicable requirements are not met. Enter reason for failure in corrections notes field below; or ☐ All N/A - This entire table is not applicable.
05	Correction Notes	<<if Verification Status= Fail, then text entry in this Corrections Notes field is required; user input text>>

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met unless otherwise noted in the Verification Status and the Correction Notes.

H. Walls for Attached Porch, Attic, Double Wall Air Barrier

01	An exterior wall air barrier is required at the intersection of the porch and exterior wall when there is conditioned space on the other side. The exterior wall includes an air barrier where the attic attaches to the conditioned space.	
02	Truss framing blocking is used at the top and bottom of each wall/roof section.	
03	Verification Status	☐ Pass - all applicable requirements are met; or ☐ Fail - one or more applicable requirements are not met. Enter reason for failure in corrections notes field below; or ☐ All N/A - This entire table is not applicable.
04	Correction Notes	<<if Verification Status= Fail, then text entry in this Corrections Notes field is required; user input text>>

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met unless otherwise noted in the Verification Status and the Correction Notes.

I. Air Barriers in Multifamily Dwellings

01	Each dwelling unit must be sealed to stop air movement between dwelling units. Treat adjacent dwelling units as unconditioned space for air sealing.	
02	All penetrations through the floor and ceiling of each dwelling unit are sealed, including electric and gas utilities, water pipes, drain pipes, fire protection service pipes, and communication wiring.	
03	Elevator penthouse, mechanical penthouse, stairwell doors, roof access hatches, and plumbing stacks that separate conditioned and unconditioned space are all sealed.	
04	Vertical chases for garbage chutes, elevator shafts, HVAC ducting and plumbing shall be treated as unconditioned space for sealing.	
05	Common hallways shall be treated as unconditioned space for sealing.	
06	Verification Status	☐ Pass - all applicable requirements are met; or ☐ Fail - one or more applicable requirements are not met. Enter reason for failure in corrections notes field below; or ☐ All N/A - This entire table is not applicable.
07	Correction Notes	<<if Verification Status= Fail, then text entry in this Corrections Notes field is required; user input text>>

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met unless otherwise noted in the Verification Status and the Correction Notes.

J. Special Requirements for SIPs

01	SIPs are considered an air barrier when properly sealed at top, bottom, sides, and all penetrations.	
02	Air barrier is continuous across all surfaces, including between SIPs and non-SIP sections.	
03	Verification Status	☐ Pass - all applicable requirements are met; or ☐ Fail - one or more applicable requirements are not met. Enter reason for failure in corrections notes field below; or ☐ All N/A - This entire table is not applicable.
04	Correction Notes	<<if Verification Status= Fail, then text entry in this Corrections Notes field is required; user input text>>

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met unless otherwise noted in the Verification Status and the Correction Notes.

K. Special Requirements for ICF

01	ICF sections are considered an air barrier when properly sealed at top, bottom, sides and all penetrations.	
02	Air barrier is continuous across all surfaces, including between ICF and non-ICF sections.	
03	Verification Status	☐ Pass - all applicable requirements are met; or ☐ Fail - one or more applicable requirements are not met. Enter reason for failure in corrections notes field below; or ☐ All N/A - This entire table is not applicable.
04	Correction Notes	<<if Verification Status= Fail, then text entry in this Corrections Notes field is required; user input text>>
The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met unless otherwise noted in the Verification Status and the Correction Notes.		

L. Determination of HERSECC Verification Compliance

<<Static Text - see the top>>		
01	<<if A03, B05, C10, D11, E04, F03, G04, H03, I06, J03 or K03 = Fail, then display: Does not comply: One or more specified verification protocol requirements on this document are not met; else display: Complies: All specified verification protocol requirements on this document are met>>	