

**SAMPLE FORM – NOT VALID FOR SUBMISSION TO BUILDING DEPARTMENTS****CERTIFICATE OF INSTALLATION****Note:** This table completed by **HERSECC** Registry.

Project Name:	Enforcement Agency:
Dwelling Address:	Permit Number:
City and Zip Code:	Permit Application Date:

Title 24, Part 6, Section 160.2(b)2 **Ventilation and Indoor Air Quality for Attached Dwelling Units**. All dwelling units shall meet the requirements of ANSI/ASHRAE Standard 62.2-~~2019~~-2022 Ventilation and Acceptable Indoor Air Quality in Residential Buildings subject to the amendments specified by Title 24, Part 6, Section 160.2(b)2A

A. Whole-Dwelling Mechanical Ventilation - General Information

01	Dwelling Unit Name	
02	Building Type	
03	Project Scope	
04	Total Conditioned Floor Area of Dwelling Unit (For addition projects the conditioned floor area equals existing area plus addition area)	
05	Number of Bedrooms in Dwelling Unit (For addition projects the number of bedrooms equals the existing bedrooms plus addition bedrooms)	
06	Ventilation System Type	
07	Ventilation Operation Schedule	
08	Fault Indicator Display (FID) Status	
Note:		

MCH-27b – Multifamily Ventilation**B. Ventilation - Total Ventilation Rate**

A mechanical supply system, exhaust system, or combination thereof shall provide whole-dwelling ventilation with outdoor air each hour at no less than the rate in 160.2(b)2Aiv

01	Total Required Ventilation rate, (Q_{tot})	
----	--	--

C. Installed Ventilation - Total Ventilation Rate

A mechanical supply system, exhaust system, or combination thereof shall provide whole-dwelling ventilation with outdoor air each hour at no less than the rate in 160.2(b)2Aiv

01	02	03	04	05
Fan Name	Fan Location	Runtime (Min/Hr)	Installed Mechanical Ventilation Rate (CFM)	Equivalent Continuous Ventilation (CFM)
06	Total Installed Equivalent Continuous Ventilation (CFM)			

**SAMPLE FORM – NOT VALID FOR SUBMISSION TO BUILDING DEPARTMENTS****C2D. HRV or ERV serving Individual Dwelling Unit**

- Heat or Energy Recovery Systems must have a fan efficacy of ≤ 1.0 W/cfm in all climate zones (Section 160.2(b)2Biii).
- Heat or Energy Recovery Systems must prescriptively have a fan efficacy of ≤ 0.6 W/cfm and a minimum sensible heat recovery of 67% in climate zones 1, 2, ~~4~~, and 11-14 and 16 (Section 170.2(c)3Biva).

01	02	03	04
Manufacturer Make	Manufacturer Model Number	Fan Efficacy Performance Rating (W/CFM)	Sensible Recovery Efficiency (%)

D.E. Additional Envelope Requirements

01	Envelope Leakage	
----	------------------	--

E.F. Additional Central Ventilation System Balancing Requirements

01	Maximum Ventilation Flow (CFM)	
----	--------------------------------	--

G. Requirements for balanced and supply only ventilation systems (160.0(b)2Axi)

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.

Balanced and supply ventilation component accessibility. Balanced and supply ventilation systems shall meet the following requirements for accessibility:

01	<u>IAQ filter and HRV/ERV accessibility. System air filters and HRV/ERV heat/energy recovery cores shall be located such that they are accessible for service from within occupiable spaces, basements, garages, balconies, mechanical closets or accessible rooftops. Filters and heat/energy recovery cores behind access panels, access doors, or grilles located no more than 10 feet above a walking surface inside a space specified above comply with this requirement.</u> <u>Exception to Section 160.2(b)2Axi:</u> Systems that require servicing from inside the attic shall have the following: <u>A Fault Indicator Display (FID) meeting the requirements of Reference Appendix JA17; and</u> <u>An attic access door located in a wall or, where attic access is provided through a ceiling, an attic access hatch that includes an integrated ladder; and</u> <u>A walkway from the attic access door to the HRV/ERV.</u>
02	<u>IAQ system component accessibility. Fans, motors, heat exchangers, filters and recovery cores shall meet all applicable requirements of California Mechanical Code 304.0 accessibility of service.</u>

H. Fault Indicator Display

Qualification Requirements Procedures for Ventilation System the Fault Indicator Displays Verification are detailed in in Appendix JA17.

01	<u>FID Manufacturer Name/Make</u>	
02	<u>FID Model Number</u>	
03	<u>The display module is mounted adjacent to the system thermostat.</u>	
04	<u>The manufacturer has certified to the Energy Commission that the FID model meets the requirements of Reference Joint Appendix JA17 (make and model found on CEC list of approved FID devices).</u>	
05	<u>The system has operated for at least 15 minutes and the FID reports that the system is operating within acceptable parameters.</u>	

**SAMPLE FORM – NOT VALID FOR SUBMISSION TO BUILDING DEPARTMENTS****I. Fault Indicator Display – Additional Requirements**

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.

01	Fault Indicator Display devices shall either be factory installed by the space-conditioning system manufacturer, or field installed according to the space-conditioning system manufacturer's requirements and the FID manufacturer's specifications.
02	The installer shall ensure that a copy of the FID manufacturer's user instructions documentation has been made available to the building owner.

FJ. Compliance Statement

01	
----	--

GK. Other Requirements

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.

The items listed below (6.1 through 6.6 and 6.8 ~~through 6.9~~) correspond to the information given in ASHRAE 62.2 Section 6 "Other Requirements". Refer also to Chapter 4.6 of the Residential Compliance Manual (Section 4.6.8) for information describing these "Other Requirements". The signature of the Responsible Person in the declaration statement below certifies that the building complies with these requirements specified in ASHRAE 62.2 Section 6.1 through 6.6 and 6.9 if applicable.

01	Adjacent Spaces and Transfer Air. Measures shall be taken to minimize air movement across envelope components to dwelling units from adjacent spaces such as garages, unconditioned crawlspaces, unconditioned attics, and other dwelling. Supply and balanced <u>mechanical</u> ventilation systems shall be designed and constructed to provide ventilation air directly from the outdoors. 1 Compliance for Attached Dwelling Units. Attached dwelling units, except existing units as described in Normative Appendix A, Section A5, shall demonstrate compliance with Section 6.1 by verifying a leakage rate less than or equal to 0.2 cfm per ft² (100 L/s per 100 m²) of the dwelling-unit boundary area by means of a blower door test at a test pressure of 50 Pa. Testing shall be conducted in accordance with ANSI/RESNET/ICC Standard 380. For horizontally attached dwelling units that are being evaluated for the infiltration credit in Section 4.1.2, the procedure specified in Section 4.1.2 shall be an alternative to the procedure of this section. One method of demonstrating compliance with Section 6.1 shall be to verify a leakage rate below a maximum of 0.3 cfm per ft² (150 L/s per 100 m²) of the dwelling unit envelope area (i.e., the sum of the area of walls between dwelling units, exterior walls, ceiling, and floor) at a test pressure of 50 Pa by a blower door test conducted in accordance with either ANSI/ASTM E779 or ANSI/ASTM E1827. The test shall be conducted with the dwelling unit as if it were exposed to outdoor air on all sides, top, and bottom by opening doors and windows of adjacent dwelling units. 1.2 Garages. When an occupiable space adjoins a garage, the design must prevent migration of contaminants to the adjoining occupiable space. Air seal the walls, ceilings, and floors that separate garages from occupiable space. To be considered air-sealed, all joints, seams, penetrations, openings between door assemblies and their respective jambs and framing, and other sources of air leakage through wall and ceiling assemblies separating the garage from the residence and its attic area shall be caulked, gasketed, weather stripped, wrapped, or otherwise sealed to limit air movement. Doors between garages and occupiable spaces shall be gasketed or made substantially airtight with weather stripping. 1.3 Space-Conditioning System Ducts. All air distribution joints located outside the dwelling-unit boundary shall be sealed. HVAC systems that serve spaces within the dwelling-unit boundary shall not be designed to supply air to or return air from the garage. HVAC systems that include air handlers or ducts located outside the dwelling-unit boundary shall have total air leakage of no more than 6% of total fan airflow when measured at 0.1 in. of water (25 Pa) using California Building Energy Efficiency Standards, Residential Appendix RA3.1 or equivalent. Method D of ASTM E1554 may be used to meet this requirement. If the air handler, ducts, or both are located in the garage, the garage door shall be open to the outside when the duct leakage is tested.
02	2 Instructions and Labeling. Controls shall be labeled as to their function (unless that function is obvious, such as toilet exhaust fan switches). Information on the ventilation design and/or ventilation systems installed, instructions on their proper operation to meet the requirements of this standard, and instructions detailing any required maintenance (similar to that provided for HVAC systems) shall be provided to the owner and the occupant of the dwelling unit. Controls shall be labeled as to their function (unless that function is obvious, such as toilet exhaust fan switches). See Section 13 of ASHRAE Guideline 24⁵ for information on instructions and labeling.
03	6.3 Clothes Dryers. Clothes dryers shall be exhausted directly to the outdoors. Exception to 6.3: Condensing dryers plumbed to a drain.
04	4 Combustion and Solid-Fuel Burning Appliances.

**SAMPLE FORM – NOT VALID FOR SUBMISSION TO BUILDING DEPARTMENTS**

	1 Combustion and solid-fuel-burning appliances must be provided with adequate combustion and ventilation air and installed in accordance with manufacturers' installation instructions, NFPA 31, NFPA 54/ANSI Z223.1, NFPA 211, , or other equivalent code acceptable to the building official. 2 Where atmospherically vented combustion appliances or solid-fuel burning appliances are located inside the <u>pressure dwelling unit</u> boundary, the total net exhaust flow of the two largest exhaust fans (not including a summer cooling fan intended to be operated <u>in conjunction with only when</u> windows or other <u>openings air inlets are open</u>) shall not exceed 15 cfm per 100 ft² (75 L/s per 100 m²) of <u>occupiable space floor area</u> when in operation at full capacity. If the designed total net flow exceeds this limit, the net exhaust <u>air flow</u> must be reduced by reducing the exhaust <u>air flow</u> or providing compensating outdoor air. Gravity or barometric dampers in nonpowered exhaust makeup air systems shall not be used to provide compensating outdoor air. Atmospherically vented combustion appliances do not include direct-vent appliances. Combustion appliances that pass safety testing performed according to ANSI/BPI-1200 shall be deemed as complying with Section 6.4.2.
05	<u>5 Air tightness Requirements</u> 1 Garages. When an occupiable space adjoins a garage, the design must prevent migration of contaminants to the adjoining occupiable space. Air seal the walls, ceilings, and floors that separate garages from occupiable space. To be considered air-sealed, all joints, seams, penetrations, openings between door assemblies and their respective jambs and framing, and other sources of air leakage through wall and ceiling assemblies separating the garage from the residence and its attic area shall be caulked, gasketed, weather stripped, wrapped, or otherwise sealed to limit air movement. Doors between garages and occupiable spaces shall be gasketed or made substantially airtight with weather stripping.
0605	<u>6.5 Ventilation Opening Area.</u> Spaces shall have ventilation openings as listed <u>below in the following subsections</u>. Such openings shall meet the requirements of Section 6.8<u>6</u>. <u>Exception to 6.5:</u> Attached dwelling units and spaces that meet the local ventilation requirements set for bathrooms in Section 5 [of ASHRAE 62.2]. <u>6.5.1 Habitable Spaces.</u> Each habitable space shall be provided with ventilation openings with an openable area not less than 4% of the floor area or less than 5 ft² (0.5 m²). <u>6.5.2 Toilets and Utility Rooms.</u> Toilets and utility rooms shall be provided with <u>natural</u> ventilation openings with an openable area not less than 4% of the room floor area or less than 1.5 ft² (0.15 m²). <u>Exceptions to 6.5.2:</u> - Utility rooms with a dryer exhaust duct. - Toilet compartments in bathrooms.
0706	<u>6.6 Air Inlets.</u> Air inlets that are part of the ventilation design shall be located a minimum of 10 ft (3 m) from known sources of contamination such as a stack, vent, exhaust hood, or vehicle exhaust. The intake shall be placed so that entering air is not obstructed by snow, plantings, or other material. Forced air inlets shall be provided with rodent/insect screens (mesh not larger than <u>1/2 0.5</u> in. [13 mm]). <u>ceptions to 6.6:</u> - Ventilation openings in the wall may be as close as a stretched-string distance of 3 ft (1 m) from sources of contamination exiting through the roof or dryer exhausts. - No minimum separation distance shall be required between windows and local exhaust outlets in kitchens and bathrooms. - Vent terminations covered by and meeting the requirements of the <i>National Fuel Gas Code</i> (NFPA 54/ANSI Z223.1)7 or equivalent. - Where a combined exhaust/intake termination is used to separate intake air from exhaust air originating in a living space other than kitchens, no minimum separation distance between these two openings is required. For these combined terminations, the exhaust air concentration within the intake airflow shall not exceed 10%, as established by the manufacturer.
0807	<u>6.8 Carbon Monoxide Alarms.</u> A carbon monoxide alarm shall be installed in each dwelling unit in accordance with NFPA 72<u>0</u>, Standard for the Installation of Carbon Monoxide (CO) Detection and Warning Equipment <u>National Fire Alarm and Signaling Code</u>, and shall be consistent with requirements of applicable laws, codes, and standards.
0908	<u>Air Filter Efficiency.</u> Supply only ventilation systems, makeup air-systems, and supply side balanced systems including HRV/ERV shall be provided with air filters having a designated efficiency equal to or greater than MERV 13 when tested in accordance with ASHRAE Standard 52.2, or a particle size efficiency rating equal to or greater than 50% in the 0.30-1.0 um range and equal to or greater than 85% in the 1.0-3.0 um range when tested in accordance with AHRI Standard 680.

**SAMPLE FORM – NOT VALID FOR SUBMISSION TO BUILDING DEPARTMENTS****H.L. Air Moving Equipment**

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.

The items listed below (7.1 through **7.47.5**) correspond to the information given in ASHRAE 62.2 Section 7 "Air-Moving Equipment". Refer also to Chapter 11 of the Non-Residential Compliance Manual (Section 11.4) for information describing these requirements in more detail. The signature of the Responsible Person in the declaration statement below certifies that the building complies with these requirements specified in ASHRAE 62.2 Section 7.1 through **7.47.5** if applicable.

01	1. Selection and Installation Ratings. Ventilation devices and equipment serving individual dwelling units shall be tested in accordance with ANSI/ASHRAE Standard 51/AMCA 210, and ANSI/AMCA Standard 300, and rated in accordance with the airflow and sound rating procedures of the Home Ventilating Institute (HVI 915, 916, 920) Installations of systems or equipment shall be carried out in accordance with manufacturers' design requirements and installation instructions. Airflow and sound ratings shall be provided for ventilation devices and equipment serving individual dwelling units. Airflow and sound ratings shall be provided in accordance with HVI 920, or equivalent, by an administration and certification body that is accredited in accordance with ISO/IEC 17065 with respect to application of the standards and test procedures referenced in Section 7.1 and accredited by an accreditation body operating in accordance with ISO/IEC 17011. Laboratory tests of representative units shall be conducted for airflow in accordance with ANSI/ASHRAE Standard 51/AMCA 210, as prescribed by HVI 916, or equivalent, and conducted for sound in accordance with ANSI/AMCA Standard 300, as prescribed by HVI 915, or equivalent. This section does not require certification to HVI 917
02	2. Installation. Installations of systems or equipment shall be carried out in accordance with manufacturer's design requirements and installation instructions.
0203	7.3 Sound Ratings for Fans. Ventilation fans shall be rated for sound at no less than the minimum airflow rate required by this standard as noted below. These sound ratings shall be at a minimum of 0.1 in. of water (25 Pa) static pressure in accordance with the HVI procedures referenced in Section 7.1. Exception to 7.3: HVAC air handlers and remote mounted fans need not meet sound requirements. To be considered for this exception, a remote mounted fan must be mounted outside the habitable spaces, bathrooms, toilets, and hallways, and there must be at least 4 ft (1 m) of ductwork between the fan and the intake grille. 1 Dwelling-Unit Ventilation or Continuous Local Exhaust Fans. These fans shall be rated for sound at a maximum of 1.0 sone. 2 Demand-Controlled Local Exhaust Fans. Bathroom exhaust fans used to comply with Section 5.2 shall be rated for sound at a maximum of 3 sone. Kitchen exhaust fans used to comply with Section 5.2 shall be rated for sound at a maximum of 3 sones at one or more airflow settings greater than or equal to 100 cfm (47 L/s). Exceptions to 7.3.2: 1. Fans with a minimum airflow setting exceeding 400 cfm (189 L/s) need not comply. 2. Kitchen Range hoods may be rated for sound at the static pressure determined at working speed as specified in HVI 916 section 7.
0304	7.3.4 Exhaust Ducts. 1 Multiple Exhaust Fans Using One Duct. Exhaust fans in separate dwelling units shall not share a common exhaust duct. If more than one of the exhaust fans in a single dwelling unit shares a common exhaust duct, each fan shall be equipped with a backdraft damper to prevent the recirculation of exhaust air from one room to another through the exhaust ducting system. 2 Single Exhaust Fan Ducted to Multiple Exhaust Inlets. Where exhaust inlets are commonly ducted across multiple dwelling units, one or more exhaust fans located downstream of the exhaust inlets shall be designed and intended to run continuously, or a system of one or more backdraft dampers shall be installed to isolate each dwelling unit from the common duct when the fan is not running.
0405	5 Supply Ducts. Where supply outlets are commonly ducted across multiple dwelling units, one or more supply fans located upstream of all the supply outlets shall be designed and intended to run continuously, or a system of one or more backdraft dampers shall be installed to isolate each dwelling unit from the common duct when the fan is not running.

**SAMPLE FORM – NOT VALID FOR SUBMISSION TO BUILDING DEPARTMENTS****DOCUMENTATION AUTHOR'S DECLARATION STATEMENT**

1. I certify that this Certificate of Installation documentation is accurate and complete.

Documentation Author Name:	Documentation Author Signature:
Documentation Author Company Name:	Date Signed:
Address:	CEA/ HERS ECC Certification Identification (If applicable):
City/State/Zip:	Phone:

RESPONSIBLE PERSON'S DECLARATION STATEMENT

I certify the following under penalty of perjury, under the laws of the State of California:

1. The information provided on this certificate of installation is true and correct.
2. I am either: a) a responsible person eligible under division 3 of the business and professions code in the applicable classification to accept responsibility for the system design, construction, or installation of features, materials, components, or manufactured devices for the scope of work identified on this certificate of installation, and attest to the declarations in this statement, or b) I am an authorized representative of the responsible person and attest to the declarations in this statement on the responsible person's behalf.
3. The constructed or installed features, materials, components or manufactured devices (the installation) identified on this certificate of installation conforms to all applicable codes and regulations and the installation conforms to the requirements given on the certificate of compliance, plans, and specifications approved by the enforcement agency.
4. I understand that an ~~HERS~~ECC Rater will check the installation to verify compliance and if such checking determines the installation fails to comply, I am required to offer any necessary corrective action at no charge to the building owner.
5. I understand that a registered copy of this certificate of installation shall be posted or made available with the building permit(s) issued for the building and made available to the enforcement agency for all applicable inspections, and I will take the necessary steps to ensure this requirement is accomplished.
6. I understand that a registered copy of this certificate of installation is required to be included with the documentation the builder provides to the building owner at occupancy, and I will take the necessary steps to ensure this requirement is accomplished.

Responsible Builder/Installer Name:	Responsible Builder/Installer Signature:	
Company Name: (Installing Subcontractor or General Contractor or Builder/Owner)	Position With Company (Title):	
Address:	CSLB License:	
City/State/Zip:	Phone:	Date Signed:
Third Party Quality Control Program (TPQCP) Status:	Name of TPQCP (if applicable):	

LMCI-MCH-27-H User Instructions

Section A. General Information

1. Building Unit Name: This field is filled out automatically. It is referenced from the LMCI-MCH-01, which must be completed prior to this document. This is the unique identifier for this dwelling unit. Needed mostly for multifamily dwelling units. Ventilation is calculated and provided for each dwelling unit individually.
2. Building Type: This field is filled out automatically. It is referenced from the LMCC. Values are "Multifamily".
3. Project Scope: This field is filled out automatically. It is referenced from the LMCC.
 - If parent document is the LMCC-PRF-01, values are "Newly Constructed", "Newly Constructed (Addition Alone)" and "Addition and /or Alteration"
 - If parent document is CF1R-NCB-01, values are "Newly Constructed" and "Newly Constructed (Addition Alone)"
 - If parent document is CF1R-ADD-01, values are "ADU Addition < 300 ft²", "ADU Addition > 300 to < 400 ft²", "ADU Addition > 400 to < 700 ft²" and "ADU Addition > 700 to < 1000 ft²".
4. Total Conditioned Floor Area of Dwelling Unit: This field is filled out automatically. It is referenced from the LMCI-MCH-01.
5. Number of Bedrooms in Dwelling Unit: This field is filled out automatically. It is referenced from the LMCI-MCH-01.
6. Ventilation system Type: This may be filled out automatically or be user input.
 - If parent document is the LMCC-PRF-01, the value will be filled out automatically.
 - If parent document is the CF1R-NCB or CF1R-ADD, user selects from list of Supply, Exhaust, Balanced, Balanced – ERV, Balanced – HRV, Central Fan Integrated (CFI), Central Ventilation System – Supply and Central Ventilation System – Exhaust and Central Ventilation System Balanced.
7. Ventilation operation schedule: This may be filled out automatically or be user input.
 - User selects from list of Continuous, Short-Term Average, Scheduled and Real-time Control.
 - Note if "Ventilation System Type" (A11) = Central Fan Integrated & "Ventilation Operation Schedule" (A12) = Continuous; then user will not be allowed to proceed.

Section B. Whole Building Continuous Ventilation – Total Ventilation Rate Method

1. This value is automatically calculated using equation 160.2-B from the Energy Standards.

Section C. Installed Ventilation – Total Ventilation Rate Method

1. User input text identifying the fan name for each installed ventilation fan.
2. User input text identifying the fan location for each installed ventilation fan.
3. Runtime (Min/Hr): This value may be filled out automatically or be user input.
 - If ventilation operation schedule from section A = "continuous", then value of 60 will be automatically entered.
 - If ventilation operation schedule from section A = "short term average", then user enter value of less than or equal to 60 for each installed ventilation fan.
4. User to enter CFM value from test procedures described in RA3.7.4 for each installed ventilation fan.
5. Equivalent continuous ventilation CFM is automatically calculated for each ventilation fan.
6. Total installed equivalent continuous ventilation CFM is automatically calculated based on the installed ventilation fans.

Section C2D. HRV or ERV serving Individual Dwelling Unit

1. User input manufacturer make of the installed equipment from the manufacturer nameplate.
2. User input model number of the installed equipment from the manufacturer nameplate.
3. User input the fan efficacy performance rating (W/CFM) for the installed equipment as determined by RA3.7.4.4.
4. User input the sensible recovery efficiency performance rating (%) for the installed equipment as determined by RA3.7.4.4.

Section DE. Additional Envelope Requirements

1. Envelope Leakage: This field is filled out automatically. It is referenced from the LMCI-MCH-24, which must be completed prior to this document.

Section EF. Additional Central Ventilation System Balancing Requirements

1. Maximum Ventilation Flow (CFM): This field is filled out automatically calculated.

Section G. Requirements for balanced and supply only ventilation systems

1. This statement must be true (or not applicable) for the test to conform to the protocols.
2. This statement must be true (or not applicable) for the test to conform to the protocols.

Section H. Fault Indicator Display

1. Enter the manufacturer name or make of the approved Fault Indicator Display. Must match name shown on the list of approved devices kept by the Commission.
2. Enter the manufacturer model number of the approved Fault Indicator Display. Must match name shown on the list of approved devices kept by the Commission.
3. The installer must confirm that the FID display module is mounted adjacent to thermostat that controls the system being verified. This requirement is detailed in Residential Appendix JA17.
4. The installer must confirm that the installed FID is approved and appears the list of approved devices kept by the Commission. This requirement is detailed in Residential Appendix JA17.
5. The installer must confirm that the system has operated for at least 15 minutes and that they system is operating within acceptable parameters as specified by the FID and equipment manufacturers. This requirement is detailed in Residential Appendix JA17.

Section I. Fault Indicator Display – Additional Requirements

1. This statement must be true (or not applicable) for the test to conform to the protocols.
2. This statement must be true (or not applicable) for the test to conform to the protocols.

Section FJ. Compliance Statement

1. Compliance Statement: This field is filled out automatically

Section GK. Additional Requirements for Compliance

1. This field must be a true statement (or not applicable) for the system to comply.
2. This field must be a true statement (or not applicable) for the system to comply.
3. This field must be a true statement (or not applicable) for the system to comply.
4. This field must be a true statement (or not applicable) for the system to comply.
5. This field must be a true statement (or not applicable) for the system to comply

6. This field must be a true statement (or not applicable) for the system to comply
7. This field must be a true statement (or not applicable) for the system to comply
8. This field must be a true statement (or not applicable) for the system to comply
9. This field must be a true statement (or not applicable) for the system to comply

Section **H** **L** Additional Requirements for Compliance

1. This field must be a true statement (or not applicable) for the system to comply.
2. This field must be a true statement (or not applicable) for the system to comply.
3. This field must be a true statement (or not applicable) for the system to comply.
4. This field must be a true statement (or not applicable) for the system to comply.

Documentation Declaration Statements

1. The person who prepared the LMCI will sign and complete the fields for their name, company (if applicable), address, phone number, certification information (if applicable), date and signature.
2. The person who is assuming responsibility for the project being built to comply with Title 24, Part 6, will complete the fields for their name, company (if applicable), address, phone number, license number (if applicable), date and signature.

Title 24, Part 6, Section 160.2(b)2 **Ventilation and Indoor Air Quality for Attached Dwelling Units.** All dwelling units shall meet the requirements of ANSI/ASHRAE Standard 62.2-2019~~22~~ Ventilation and Acceptable Indoor Air Quality in Residential Buildings subject to the amendments specified by Title 24, Part 6, Section 160.2(b)2A

A. Whole-Dwelling Mechanical Ventilation - General Information

01	Dwelling Unit Name	<<calculated field, referenced data from MCH-01, "Dwelling Unit Name" (A01); else if information not available then allow user input.>>
02	Building Type	<< calculated field, referenced data from LMCC, allowed values = multifamily >>
03	Project Scope	<< calculated field, if parent is LMCC-PRF referenced data from LMCC-PRF; else if parent is LMCC-MCH allow user to select one from list. allowed values = Newly Constructed, Newly Constructed (Addition Alone), and Addition and /or Alteration; >>
04	Total Conditioned Floor Area of Dwelling Unit (For addition projects the conditioned floor area equals existing area plus addition area)	<<calculated field: referenced from MCH-01, "Dwelling Unit Total Conditioned Floor Area (ft²)" (A03); else if information not available then allow user input. >>
05	Number of Bedrooms in Dwelling Unit (For addition projects the number of bedrooms equals the existing bedrooms plus addition bedrooms)	<<calculated field: referenced from MCH-01, "Dwelling Unit Number of Bedrooms" (A09); if value from MCH-01 = 0 replace with 1; else if information not available then allow user input >>
06	Ventilation System Type	<< calculated value if parent is LMCC-PRF, reference data from LMCC-PRF; else if parent is LMCC-MCH allow user to pick one from list: **Supply **Exhaust; or **Balanced; or **Balanced – ERV; or **Balanced – HRV; or **Central Fan Integrated (CFI); or **Central Ventilation System – Supply; or **Central Ventilation System – Exhaust; or **Central Ventilation System – Balanced >>
07	Ventilation Operation Schedule	<<; Allow user to choose from list: **Continuous; or **Short-Term Average; if "Ventilation System Type" (A06) = Central Fan Integrated & "Ventilation Operation Schedule" (A07)= Continuous; then display: "Central Fan Integrated Ventilation System Not Allowed to Operate Continuously - Do Not Proceed ">>
<u>08</u>	<u>Fault Indicator Display (FID) Status</u>	<<user pick one from list: <u>This system has a factory installed FID; or This system has a field installed FID; or This system does not have a FID device installed</u> >>
08	determine compliance method for this document; display applicable tables below; (this row not visible to user)	<<calculated field: "Building Type" (A02) – Multifamily and "Ventilation System Type" (A06) = Supply, Exhaust, Balanced, Balanced – ERV, Balanced – HRV, Central Fan Integrated (CFI), Central Ventilation System – Supply, Central Ventilation System – Exhaust, or Central Ventilation System – Balanced, then display method: **27b – Multifamily >>
09	Climate Zone (this row is not visible to the user)	<<value from LMCC>>

~~MCH-27b – Multifamily Ventilation~~

B. Ventilation - Total Ventilation Rate

A mechanical supply system, exhaust system, or combination thereof shall provide whole-dwelling ventilation with outdoor air each hour at no less than the rate in 160.2(b)2Aiv

01	Total Required Ventilation rate, (Q _{tot})	<<calculated field, numeric: (use equation 160.2-B): $[(0.03 * \text{"Total Conditioned Floor Area of Dwelling Unit"} (A04)) + (7.5 * (\text{"Number of Bedrooms in Dwelling Unit"} (A05) + 1))], (\text{cfm}). >>$
----	--	---

C. Installed Ventilation - Total Ventilation Rate

A mechanical supply system, exhaust system, or combination thereof shall provide whole-dwelling ventilation with outdoor air each hour at no less than the rate in 160.2(b)2Aiv

01	02	03	04	05
Fan Name	Fan Location	Runtime (Min/Hr)	Installed Mechanical Ventilation Rate (CFM)	Equivalent Continuous Ventilation (CFM)
<< user input, text>>	<<user input, text>>	<<calculated field: if value in "Ventilation Operation Schedule" (A07) equals Continuous, then value equals 60; Else if value in "Ventilation Operation Schedule" (A07) equals Short Term Average ,then user input value positive integer ≤ 60>>	<< user input, positive integer>>	<<calculated field, value = ("Runtime (Min/Hr)" (C03) * "Installed Mechanical Ventilation Rate (CFM)" (C04)) / 60 (CFM)>>
06	Total Installed Equivalent Continuous Ventilation (CFM)			<<calculated field, value = sum of values in column "Equivalent Continuous Ventilation (CFM)" (C05)>>

~~C2~~D. HRV or ERV serving Individual Dwelling Unit

- Heat or Energy Recovery Systems must have a fan efficacy of ≤ 1.0 W/cfm in all climate zones (Section 160.2(b)2Biii).
- Heat or Energy Recovery Systems must prescriptively have a fan efficacy of ≤ 0.6 W/cfm and a minimum sensible heat recovery of 67% in climate zones 1, 2, 4, ~~and~~ 11-14 and 16 (Section 170.2(c)3Biva).

01	02	03	04
Manufacturer Make	Manufacturer Model Number	Fan Efficacy Performance Rating (W/CFM)	Sensible Recovery Efficiency (%)
<< user input, text>>	<< user input, text>>	<< user input, text>> Range check: User entered value must be ≤ 0.6 if complying prescriptively in climate zones 1, 2, 4, and 11-14 and 16; else value must be ≤ 1.0>>	<< user input, text>> Range check: User entered value must be ≥ 67% if complying prescriptively in climate zones 1, 2, 4 and 11-14 and 16; else no restriction>>

~~D~~E. Additional Envelope Requirements

<<if Ventilation System Type (A06) equals Supply, Exhaust, Central Fan Integrated (CFI), Central Ventilation System – Supply or Central Ventilation System – Exhaust then display Table D; Else display the section does not apply message>>

01	Envelope Leakage	<< calculated field, referenced data from LMCI-MCH-24>>
----	------------------	---

~~E~~F. Additional Central Ventilation System Balancing Requirements

<<if Ventilation System Type (A06) equals Central Ventilation System – Supply, Central Ventilation System – Exhaust or Central Ventilation System – Balanced then display Table E; Else display the section does not apply message>>

01	Maximum Ventilation Flow (CFM)	<<calculated field, "Total Required Ventilation rate" (B01) * 1.20>>
----	--------------------------------	--

For information and data collection
only. Not valid until registered with an
ECC provider

G. Requirements for balanced and supply only ventilation systems (160.0(b)2Axi)

<<If A06=Balanced HRV or Balanced ERV then display table; Else display the "section does not apply" message>>

<<Balanced and supply ventilation component accessibility. Balanced and supply ventilation systems shall meet the following requirements for accessibility:>>

<<Static Text - see the top>>

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.

H. Fault Indicator Display

<< Qualification Requirements for Ventilation System Fault Indicator Displays are detailed in in Appendix JA17>>

<<If A08 = "This system has a factory installed FID"; or "This system has a field installed FID", then display this section>>

01	FID Manufacturer Name/Make	<<user entry, text field (must be on list of approved devices)>>
02	FID Model Number	<<user entry, text field (must be on list of approved devices)>>
03	The display module is mounted adjacent to the system thermostat.	<<pass if confirmed, else do not proceed>User select from list: Yes or No; if No then do not proceed>>
04	The manufacturer has certified to the Energy Commission that the FID model meets the requirements of Reference Joint Appendix JA17 (make and model found on CEC list of approved FID devices).	<<pass if confirmed, else do not proceed>User select from list: Yes or No; if No then do not proceed>>
05	The system has operated for at least 15 minutes and the FID reports that the system is operating within acceptable parameters.	<<pass if confirmed, else do not proceed>User select from list: Yes or No; if No then do not proceed>>

I. Fault Indicator Display – Additional Requirements

<<If A08 = "This system has a factory installed FID"; or "This system has a field installed FID", then display this section>>

<<Static Text - see the top>>

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.

FJ. Compliance Statement

01	<< if the "Ventilation System Type" (A06) equals Balanced, Balanced – ERV or Balanced – HRV and the "Total Installed Equivalent Continuous Ventilation" (C06) ≥ "Total Required Ventilation Rate" (B01), then display text: "Building Passes Mechanical Ventilation Rate Test" Else if the "Ventilation System Type" (A06) equals Central Ventilation System – Balanced and the "Total Installed Equivalent Continuous Ventilation" (C06) ≥ "Total Required Ventilation Rate" (B01) and the "Total Installed Equivalent Continuous Ventilation" (C06) ≤ "Maximum Ventilation Flow" (E01F01), then display text: "Building Passes Mechanical Ventilation Rate Test" Else if the "Ventilation System Type" (A06) equals Supply, Exhaust, Central Fan Integrated (CFI) and the "Total Installed Equivalent Continuous Ventilation" (C06) ≥ "Total Required Ventilation Rate" (B01), and if "Envelope Leakage" (D01E01) ≤ "Target dwelling unit compartmentalization leakage" (taken from LMCI-MCH-24), then display text: "Building Passes Mechanical Ventilation Rate Test" Else if the "Ventilation System Type" (A06) equals Central Ventilation System – Supply or Central Ventilation System – Exhaust and the "Total Installed Equivalent Continuous Ventilation" (C06) ≥ "Total Required Ventilation Rate" (B01), and if "Envelope Leakage" (D01E01) ≤ "Target dwelling unit compartmentalization leakage" (taken from LMCI-MCH-24), and the "Total Installed Equivalent Continuous Ventilation" (C06) ≤ "Maximum Ventilation Flow" (E01F01), then display text: "Building Passes Mechanical Ventilation Rate Test" Else display text: "Building Fails Mechanical Ventilation Rate Test">>
----	--

JK. Other Requirements

The items listed below (6.1 through 6.6 and 6.8 ~~through 6.9~~) correspond to the information given in ASHRAE 62.2 Section 6 "Other Requirements". Refer also to Chapter 4.6 of the Residential Compliance Manual (Section 4.6.8) for information describing these "Other Requirements". The signature of the Responsible Person in the declaration statement below certifies that the building complies with these requirements specified in ASHRAE 62.2 Section 6.1 through 6.6 and 6.9-8 if applicable.

<<Static Text - see the top>>

01	6.2 – Adjacent Spaces and Transfer Air. Measures shall be taken to minimize air movement across envelope components to dwelling units from adjacent spaces such as garages, unconditioned crawlspaces, unconditioned attics, and other dwelling. Supply and balanced mechanical ventilation systems shall be designed and constructed to provide ventilation air directly from the outdoors. 6.1.1 Compliance for Attached Dwelling Units. Attached dwelling units, except existing units as described in Normative
----	---

	<u>Appendix A, Section A5, shall demonstrate compliance with Section 6.1 by verifying a leakage rate less than or equal to 0.2 cfm per ft² (100 L/s per 100 m²) of the dwelling unit boundary area by means of a blower door test at a test pressure of 50 Pa. Testing shall be conducted in accordance with ANSI/RESNET/ICC Standard 380. For horizontally attached dwelling units that are being evaluated for the infiltration credit in Section 4.1.2, the procedure specified in Section 4.1.2 shall be an alternative to the procedure of this section. One method of demonstrating compliance with Section 6.1 shall be to verify a leakage rate below a maximum of 0.3 cfm per ft² (150 L/s per 100 m²) of the dwelling unit envelope area (i.e., the sum of the area of walls between dwelling units, exterior walls, ceiling, and floor) at a test pressure of 50 Pa by a blower door test conducted in accordance with either ANSI/ASTM E779 or ANSI/ASTM E1827. The test shall be conducted with the dwelling unit as if it were exposed to outdoor air on all sides, top, and bottom by opening doors and windows of adjacent dwelling units.</u> <u>6.1.2 Garages.</u> When an occupiable space adjoins a garage, the design must prevent migration of contaminants to the adjoining occupiable space. Air seal the walls, ceilings, and floors that separate garages from occupiable space. To be considered air-sealed, all joints, seams, penetrations, openings between door assemblies and their respective jambs and framing, and other sources of air leakage through wall and ceiling assemblies separating the garage from the residence and its attic area shall be caulked, gasketed, weather stripped, wrapped, or otherwise sealed to limit air movement. Doors between garages and occupiable spaces shall be gasketed or made substantially airtight with weather stripping. <u>6.1.3 Space Conditioning System Ducts.</u> All air distribution joints located outside the dwelling unit boundary shall be sealed. HVAC systems that serve spaces within the dwelling unit boundary shall not be designed to supply air to or return air from the garage. HVAC systems that include air handlers or ducts located outside the dwelling unit boundary shall have total air leakage of no more than 6% of total fan airflow when measured at 0.1 in. of water (25 Pa) using California Building Energy Efficiency Standards, Residential Appendix RA3.1 or equivalent. Method D of ASTM E1554 may be used to meet this requirement. If the air handler, ducts, or both are located in the garage, the garage door shall be open to the outside when the duct leakage is tested.
02	6.2 Instructions and Labeling. Information on the ventilation design and/or ventilation systems installed, instructions on their proper operation to meet the requirements of this standard, and instructions detailing any required maintenance (similar to that provided for HVAC systems) shall be provided to the owner and the occupant of the dwelling unit. Controls shall be labeled as to their function (unless that function is obvious, such as toilet exhaust fan switches). See Section 13 of ASHRAE Guideline 24⁵ for information on instructions and labeling.
03	6.3 Clothes Dryers. Clothes dryers shall be exhausted directly to the outdoors. Exception: Condensing dryers plumbed to a drain.
04	6.4 Combustion and Solid-Fuel Burning Appliances. 6.4.1 Combustion and solid-fuel burning appliances must be provided with adequate combustion and ventilation air and installed in accordance with manufacturers' installation instructions, NFPA 31, NFPA 54/ANSI Z223.1, NFPA 211, or other equivalent code acceptable to the building official. 6.4.2 Where atmospherically vented combustion appliances or solid-fuel burning appliances are located inside the pressure boundary, the total net exhaust flow of the two largest exhaust fans (not including a summer cooling fan intended to be operated only when windows or other air inlets are open) shall not exceed 15 cfm per 100 ft² (75 L/s per 100 m²) of occupiable space when in operation at full capacity. If the designed total net flow exceeds this limit, the net exhaust flow must be reduced by reducing the exhaust flow or providing compensating outdoor air. Gravity or barometric dampers in nonpowered exhaust makeup air systems shall not be used to provide compensating outdoor air. Atmospherically vented combustion appliances do not include direct-vent appliances. Combustion appliances that pass safety testing performed according to ANSI/BPI 1200 shall be deemed as complying with Section 6.4.2.
05	6.5 Airtightness Requirements 6.5.1 Garages. When an occupiable space adjoins a garage, the design must prevent migration of contaminants to the adjoining occupiable space. Air seal the walls, ceilings, and floors that separate garages from occupiable space. To be considered air-sealed, all joints, seams, penetrations, openings between door assemblies and their respective jambs and framing, and other sources of air leakage through wall and ceiling assemblies separating the garage from the residence and its attic area shall be caulked, gasketed, weather stripped, wrapped, or otherwise sealed to limit air movement. Doors between garages and occupiable spaces shall be gasketed or made substantially airtight with weather stripping.
06	6.6 Ventilation Opening Area. Spaces shall have ventilation openings as listed below in the following subsections. Such openings shall meet the requirements of Section 6.86. Exception to 6.5: Attached dwelling units and spaces that meet the local ventilation requirements set for bathrooms in Section 5 [of ASHRAE 62.2]. 6.6.1 Habitable Spaces. Each habitable space shall be provided with ventilation openings with an openable area not less than 4% of the floor area or less than 5 ft² (0.5 m²). 6.6.2 Toilets and Utility Rooms. Toilets and utility rooms shall be provided with natural ventilation openings with an openable area not less than 4% of the room floor area or less than 1.5 ft² (0.15 m²). Exceptions to 6.5.2: 1. Utility rooms with a dryer exhaust duct. 2. Toilet compartments in bathrooms.

07	6.86.6 Air Inlets. Air inlets that are part of the ventilation design shall be located a minimum of 10 ft (3 m) from known sources of contamination such as a stack, vent, exhaust hood, or vehicle exhaust. The intake shall be placed so that entering air is not obstructed by snow, plantings, or other material. Forced air inlets shall be provided with rodent/insect screens (mesh not larger than 1/20.5 in. [13 mm]). Exceptions to 6.6: 1. Ventilation openings in the wall may be as close as a stretched-string distance of 3 ft (1 m) from sources of contamination exiting through the roof or dryer exhausts. 2. No minimum separation distance shall be required between windows and local exhaust outlets in kitchens and bathrooms. 3. Vent terminations covered by and meeting the requirements of the <i>National Fuel Gas Code (NFPA 54/ANSI Z223.1)</i>7 or equivalent. 4. Where a combined exhaust/intake termination is used to separate intake air from exhaust air originating in a living space other than kitchens, no minimum separation distance between these two openings is required. For these combined terminations, the exhaust air concentration within the intake airflow shall not exceed 10%, as established by the manufacturer.
08	66.96.8 Carbon Monoxide Alarms. A carbon monoxide alarm shall be installed in each dwelling unit in accordance with NFPA-720, <i>Standard for the Installation of Carbon Monoxide (CO) Detection and Warning Equipment</i>National Fire Alarm and Signaling Code, and shall be consistent with requirements of applicable laws, codes, and standards.
09	Supply only ventilation systems, makeup air systems, and supply side balanced systems including HRV/ERV shall be provided with air filters having a designated efficiency equal to or greater than MERV 13 when tested in accordance with ASHRAE Standard 52.2, or a particle size efficiency rating equal to or greater than 50% in the 0.30-1.0 µm range and equal to or greater than 85% in the 1.0-3.0 µm range when tested in accordance with AHRI Standard 680.

H_L. Air Moving Equipment

The items listed below (7.1 through **7.47.5**) correspond to the information given in ASHRAE 62.2 Section 7 "Air-Moving Equipment". Refer also to Chapter 11 of the Non-Residential Compliance Manual (Section 11.4) for information describing these requirements in more detail. The signature of the Responsible Person in the declaration statement below certifies that the building complies with these requirements specified in ASHRAE 62.2 Section 7.1 through **7.47.5** if applicable.

<<Static Text - see the top>>

01	7.1 Selection and Installation Ratings. Ventilation devices and equipment serving individual dwelling units shall be tested in accordance with ANSI/ASHRAE Standard 51/AMCA 210, and ANSI/AMCA Standard 300, and rated in accordance with the airflow and sound rating procedures of the Home Ventilating Institute (HVI 915, 916, 920). Installations of systems or equipment shall be carried out in accordance with manufacturers' design requirements and installation instructions. Airflow and sound ratings shall be provided for ventilation devices and equipment serving individual dwelling units. Airflow and sound ratings shall be provided in accordance with HVI 920, or equivalent, by an administration and certification body that is accredited in accordance with ISO/IEC 17065 with respect to application of the standards and test procedures referenced in Section 7.1 and accredited by an accreditation body operating in accordance with ISO/IEC 17011. Laboratory tests of representative units shall be conducted for airflow in accordance with ANSI/ASHRAE Standard 51/AMCA 210, as prescribed by HVI 916, or equivalent, and conducted for sound in accordance with ANSI/AMCA Standard 300, as prescribed by HVI 915, or equivalent. This section does not require certification to HVI 917.
02	7.2 Sound Ratings for Fans. Ventilation fans shall be rated for sound at no less than the minimum airflow rate required by this standard as noted below. These sound ratings shall be at a minimum of 0.1 in. of water (25 Pa) static pressure in accordance with the HVI procedures referenced in Section 7.1. Exception: HVAC air handlers and remote mounted fans need not meet sound requirements. To be considered for this exception, a remote mounted fan must be mounted outside the habitable spaces, bathrooms, toilets, and hallways, and there must be at least 4 ft (1.2 m) of ductwork between the fan and the intake grille. 7.2.1 Dwelling Unit Ventilation or Continuous Local Exhaust Fans. These fans shall be rated for sound at a maximum of 1.0 sone. 7.2.2 Demand-Controlled Local Exhaust Fans. Bathroom exhaust fans used to comply with Section 5.2 shall be rated for sound at a maximum of 3 sone. Kitchen exhaust fans used to comply with Section 5.2 shall be rated for sound at a maximum of 3 sones at one or more airflow settings greater than or equal to 100 cfm (47 L/s). Exceptions: 1. Fans with a minimum airflow setting exceeding 400 cfm (189 L/s) need not comply. 2. Kitchen Range hoods may be rated for sound at the static pressure determined at working speed as specified in HVI 916 section 7.
03	7.3 Exhaust Ducts. 7.3.1 Multiple Exhaust Fans Using One Duct. Exhaust fans in separate dwelling units shall not share a common exhaust duct. If more than one of the exhaust fans in a single dwelling unit shares a common exhaust duct, each fan shall be equipped with a backdraft damper to prevent the recirculation of exhaust air from one room to another through the exhaust ducting system. 7.3.2 Single Exhaust Fan Ducted to Multiple Inlets. Where exhaust inlets are commonly ducted across multiple dwelling units, one or more exhaust fans located downstream of the exhaust inlets shall be designed and intended to run continuously, or a system of one or more backdraft dampers shall be installed to isolate each dwelling unit from the common duct when the fan is not running.
04	7.4 Supply Ducts. Where supply outlets are commonly ducted across multiple dwelling units, one or more supply fans located upstream of all the supply outlets shall be designed and intended to run continuously, or a system of one or more backdraft dampers shall be installed to isolate each dwelling unit from the common duct when the fan is not running.