

**SAMPLE FORM – NOT VALID FOR SUBMISSION TO BUILDING DEPARTMENTS****CERTIFICATE OF INSTALLATION****Note:** This table completed by **HERSECC** Registry.

Project Name:	Enforcement Agency:
Dwelling Address:	Permit Number:
City and Zip Code:	Permit Application Date:

A. Installed Lighting and Controls

Select Yes or No according to whether your work on the project includes each of the following types of lighting and controls. See Sections B through J for applicable requirements.

01	High Luminous Efficacy luminaires installed in any interior rooms. (See Section B.)	
0202	JA8 compliant luminaires installed in any interior rooms. (See Section B.) Reserved	
0302	Recessed downlight luminaires in ceilings in any interior rooms. (See Section C.)	
0403	Light Sources in Enclosed or Recessed Luminaires <u>(other than recessed downlights in ceilings)</u> . (See Section D.)	
0504	Lighting controls in bathrooms. (See Section E.)	
0605	Lighting controls in garage laundry rooms. (See Section E.)	
0706	Lighting controls in utility laundry rooms. (See Section E.)	
0807	Lighting controls in garage utility rooms. (See Section E.)	
0908	Lighting controls in walk-in closets. (See Section E.)	
1009	Lighting controls in interior rooms except bathrooms, <u>garages, laundry rooms, utility rooms, and walk-in closets</u> <u>laundry rooms, utility rooms, and garages</u> . (See Section F)	
11	Screw-based luminaires. (See Section G.)	
1210	Internally illuminated address signs. (See Section <u>HG</u> .)	
1311	Outdoor lighting and controls. (See Section <u>HI</u> .)	
1412	Parking Garages for eight or more Vehicles. (See Section <u>JI</u> .)	
1513	Blank Electrical Boxes installed more than 5 feet from finished floor. (See Section <u>KJ</u> .)	

B. High Luminous Efficacy Luminaires

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.

01	150.0(k)1A and Table 150.0-A: All <u>installed</u> luminaires <u>are installed with and light sources shall comply with Reference Joint Appendix JA8 and shall be certified and marked as required by JA8.</u> : Light sources of one of the lighting technologies specified under the "High Luminous Efficacy" column of Table 150.0-A; or JA8 compliant light sources and the light sources are marked with "JA8-20252" or "JA8-20252-E". Exception 1: Integrated device lighting: Lighting integral to exhaust fans, kitchen range hoods, bath vanity mirrors, and garage door openers, <u>and ceiling fan kits that are subject to DOE's Appliance and Equipment Standards Program, and non-removable lighting attached to ceiling fans.</u> Exception 2: Navigation Lighting <u>rated less than five watts, such as night lights, and path lights.</u> Night lights, step lights, path lights less than 5 watts. Exception 3: Cabinet Lighting <u>with an efficacy of 45 lumens per watt or greater and located internal to drawers, cabinetry, or linen closets.</u> Lighting internal to drawers, cabinetry, and linen closets with an efficacy of 45 lumens per watt or greater Exception 4: Light sources as follows: i. <u>LED light sources installed outdoors;</u> ii. <u>inseparable solid state lighting (SSL) luminaires containing colored light sources that are installed to provide decorative lighting;</u> iii. <u>High intensity discharge (HID) light sources including pulse start metal halide and high pressure sodium light sources; and</u> i-iv. <u>Luminaires with hardwired high frequency generator and induction lamp</u>	
02	Lighting shall have readily accessible wall-mounted controls that allow the lighting to be manually turned ON and OFF	

**SAMPLE FORM – NOT VALID FOR SUBMISSION TO BUILDING DEPARTMENTS****C. Recessed Downlight Luminaires in Ceilings**

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.

01	150.0(k)1Ci: Do not contain screw based lamp sockets.
02	The luminaire is marked with "JA8-2025 2 ".
03	150.0(k)1Cii: Has label certifying the luminaires are air-tight with air leakage less than 2.0 cfm at 75 Pascals when tested in accordance with ASTM E283. <u>An exhaust fan housing with integral light shall not be required to be certified airtight.</u> Exception: Recessed luminaires marked for use in fire-rated installations <u>extruded into ceiling space</u> , and recessed luminaires installed in non-insulated ceilings.
04	150.0(k)1Ciii: Sealed with a gasket or caulk between the luminaire housing and ceiling, and all air leakage paths between conditioned and unconditioned spaces are sealed with a gasket or caulk, or be installed per manufacturer's instructions to maintain airtightness between the luminaire housing and ceiling. Exception: Recessed luminaires marked for use in fire-rated installations, and recessed luminaires installed in non-insulated ceilings.
05	150.0(k)1Civ: Meet the following requirements (California Electrical Code Article <u>Section</u> 410.116). —A recessed luminaire that is not identified for contact with insulation shall have all recessed parts spaced not less than 1/2 inch from combustible materials. The points of support and the trim finishing off the openings in the ceiling shall be permitted to be in contact with combustible materials. —A recessed luminaire that is identified for contact with insulation, Type IC, shall be permitted to be in contact with combustible materials at recessed parts, points of support, and portions passing through or finishing off the opening in the building structure. —Thermal insulation shall not be installed above a recessed luminaire or within 3 inches of the recessed luminaire's enclosure, wiring compartment, ballast, transformer, LED driver, or power supply unless the luminaire is identified as Type IC for insulation contact.

D. Light sources in enclosed or recessed luminaires (other than recessed downlight luminaires in ceilings)

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.

01	150.0(k)1D: Light Sources in Enclosed or Recessed Luminaires. <u>Lamps and other separable light sources in enclosed or recessed luminaires shall be in compliance with the JA8 elevated temperature requirements (in Section JA8.5), including marking requirements (marked with "JA8-2025-E").</u> that are not marked with "JA8-2022-E", should not be installed in enclosed or recessed luminaires.

E. Lighting Controls in bathrooms, garages, laundry rooms, utility rooms, and walk-in closets

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.

01	150.0(k)2Ei: In bathrooms, garages, laundry rooms, utility rooms, and walk-in closets , at least one installed luminaire -is controlled by an occupancy or vacancy sensor providing automatic-off functionality.
----	---

**SAMPLE FORM – NOT VALID FOR SUBMISSION TO BUILDING DEPARTMENTS****F. Lighting Controls in any interior rooms**

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.

01	150.0(k)2Eii: For lighting internal to drawers and cabinetry with opaque fronts or doors, the lighting has controls to turn light off when the drawer or door is closed are provided.
02	150.0(k)2F: Lighting in habitable spaces, including but not limited to living rooms, dining rooms, kitchens, and bedrooms, have readily accessible wall-mounted dimming controls that allow the lighting to be manually adjusted up and down. Forward phase cut dimmers controlling LED light sources in these spaces comply with NEMA SSL 7A. EXCEPTION 1: Ceiling fans may provide control of integrated lighting via a remote control. <u>Lighting integral to kitchen range hoods and bathroom exhaust fans</u> EXCEPTION 2: Luminaires connected to a circuit with controlled lighting power less than 20 watts or controlled by an occupancy or vacancy sensor providing automatic-off functionality. EXCEPTION 3: Navigation lighting <u>rated less than 5 watts</u> , such as night lights, step lights, and path lights. <u>Lighting controlled by automatic-off controls and located less than 5 watts, and lighting internal to drawers, and cabinetry with opaque fronts, or cabinetry with doors, or with automatic-off controls.</u>
03	150.0(k)2A: Lighting has readily accessible wall-mounted controls that allow the lighting to be manually turned ON and OFF.
04	150.0(k)2B: Reserved. No controls bypasses a dimmer, occupant sensor or vacancy sensor function where that dimmer or sensor is installed to comply with Section 150.0(k)
0504	150.0(k)2C: All lighting controls. Lighting controls comply with the applicable requirements in Section 110.9.
0605	150.0(k)2D: Controls permitted. An Energy Management Control Systems (EMCS) or a multi-scene programmable control can be used to comply with dimming, occupancy, and lighting control requirements in Section 150.0(k)2 if it provides the functionality of the specified controls in accordance with Section 110.9, and the physical controls specified in Section 150.0(k)2A. No controls shall bypass control functions of a dimmer, occupant sensor, or vacancy sensor where the dimmer or sensor has been installed to comply with Section 150.0(k)2. (readily accessible wall mounted controls that allow the lighting to be manually turned ON and OFF).
0706	150.0(k)2G: Independent controls <u>Lighting integral to integrated lighting of exhaust fans is controlled independently from the fans.</u> - Undercabinet lighting, undershelf lighting, interior lighting of display cabinets, and switched outlets are controlled separately from ceiling installed lighting.

G. Screw-Based luminaires

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.

01	150.0(k)1B: Screw-based luminaires shall contain lamps that are marked with "JA8-2022" or "JA8-2022-E". Reserved
---------------	---

HG. Address Signs

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.

01	150.0(k)4: Internally illuminated address signs. Internally illuminated address signs shall either: - Comply with Section 140.8. Applicable nonresidential sign lighting compliance forms shall also be submitted; or - Consume no more than five5 Watts of power.
----	--

**SAMPLE FORM – NOT VALID FOR SUBMISSION TO BUILDING DEPARTMENTS****H. Outdoor Lighting and Controls**

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.

01	150.0(k)1A and Table 150.0 A: High efficacy outdoor lighting or LED light sources are installed.
02	1. 150.0(k)3A: Outdoor lighting <u>permanently mounted to a residential building or to the other buildings on the same lot shall meet the following requirements:</u> is e Controlled by a manual ON and OFF <u>control</u> switch that permits <u>the automatic actions of items ii below; and</u> <u>Controlled by one of the following controls:</u> a. a photocell and a motion sensor; or one of the following automatic actions: a-b. <u>a photocell and an automatic time switch control; or</u> Controlled by a photocell and either a motion sensor or an automatic time switch control; or c. Controlled by an astronomical time clock control. 1-2. B-150.0(k)3B: Controls that override to ON shall not be allowed unless the override automatically returns the automatic control to its normal operation within six <u>6</u> hours. 2-3. C-150.0(k)3C: An energy management control <u>system (EMCS) or other controls</u> that provides the specified lighting control functionality and complies with all requirements applicable to the specified controls may be used to meet the above requirements.

J. Lighting for Residential Garages for Eight or More Vehicles

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.

01	150.0(k)5: Lighting complies with the applicable requirements for nonresidential garages in Sections 110.9, 130.0, 130.1, 130.4, 140.6, and 141.0. Applicable LTG forms shall also be submitted.
----	--

K. Blank Electrical Boxes

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.

01	150.0(k)1E: The number of electrical boxes that are more than <u>five</u> feet above the finished floor and do not contain a luminaire or other device shall be no greater than the number of bedrooms. These electrical boxes must <u>shall</u> be served by a dimmer, vacancy sensor control, low voltage wiring, or fan speed control.
----	--

**SAMPLE FORM – NOT VALID FOR SUBMISSION TO BUILDING DEPARTMENTS****Documentation Author's Declaration Statement**

1. I certify that this Certificate of Installation documentation is accurate and complete.

Documentation Author Name:	Documentation Author Signature:
Documentation Author Company Name:	Date Signed:
Address:	CEA/ HERSECC Certification Identification (If applicable):
City/State/Zip:	Phone:

Responsible Person's Declaration statement

I certify the following under penalty of perjury, under the laws of the State of California:

1. The information provided on this Certificate of Installation is true and correct.
2. I am either: a) a responsible person eligible under Division 3 of the Business and Professions Code in the applicable classification to accept responsibility for the system design, construction, or installation of features, materials, components, or manufactured devices for the scope of work identified on this Certificate of Installation, and attest to the declarations in this statement, or b) I am an authorized representative of the responsible person and attest to the declarations in this statement on the responsible person's behalf.
3. The constructed or installed features, materials, components or manufactured devices (the installation) identified on this Certificate of Installation conforms to all applicable codes and regulations and the installation conforms to the requirements given on the Certificate of Compliance, plans, and specifications approved by the enforcement agency.
4. I understand that a registered copy of this Certificate of Installation shall be posted or made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections, and I will take the necessary steps to ensure this requirement is accomplished.
5. I understand that a registered copy of this Certificate of Installation is required to be included with the documentation the builder provides to the building owner at occupancy, and I will take the necessary steps to ensure this requirement is accomplished.

Responsible Builder/Installer Name:	Responsible Builder/Installer Signature:	
Company Name: (Installing Subcontractor or General Contractor or Builder/Owner)	Position With Company (Title):	
Address:	CSLB License:	
City/State/Zip:	Phone:	Date Signed:

CF2R-LTG-01-E User Instructions

~~There are two version of the residential lighting Certificate of Installation. This version, the The~~ CF2R-LTG-01-E, is primarily used for demonstrating compliance with the residential lighting Standards for single-family dwellings.

Do not use this form to demonstrate compliance with lighting in high rise residential dwelling units and multi-family dwelling units.

~~The LTG-01 shall also be used to demonstrate compliance with the residential lighting requirements for high-rise residential dwelling units; outdoor lighting that is attached to a high-rise residential or hotel/motel building, and is separately controlled from the inside of a dwelling unit or guest room; fire station dwelling accommodations; hotel and motel guest rooms; and, dormitory and senior housing dwelling accommodations. When using the CF2R-LTG-01-E to demonstrate compliance with the lighting in the dwelling units, compliance with lighting that is not in the dwelling units, such as lighting in common areas, shall be demonstrated using the nonresidential lighting compliance documentation.~~

~~The other version of the residential lighting Certificate of Compliance, the CF2R-LTG-02-E, is used for demonstrating compliance with the residential lighting Standards for low-rise multi-family dwellings. The primary difference between the LTG-02 and LTG-01 is that the LTG-02 includes additional requirements for demonstrating compliance with residential outdoor lighting, and common areas associated with low-rise multi-family dwelling units.~~

Section A. Installed Lighting and Controls

This table is used to identify the scope of the work being covered by the responsible person signing this document. One person may be responsible for all of the measures in this table, or several people may each be responsible for only a portion of the measures. If several people are responsible, each person must separately fill out this Certificate of Installation for those measures for which they are responsible. In some situations, such as for alterations and additions, only some of the measures may be included in the total scope of work.

For rows 1 through 15 – insert ‘Y’ for each measure that is included in the scope of work, and insert ‘N’ for each measure that is not included in the scope of work.

Section B. High Luminous Efficacy Luminaires

This table is a list of mandatory requirements for high Luminous efficacy luminaires.

Section C. Recessed Downlight Luminaires in Ceilings

This table is a list of mandatory requirements for recessed downlight luminaires in ceilings.

Section D. Light sources in enclosed or recessed luminaires (other than recessed downlight luminaires in ceilings). This table is a list of Light sources in enclosed or recessed luminaires.

Section E. Lighting Controls in bathrooms, garages, laundry rooms, and utility rooms, and walk-in closets.

This table is a list of mandatory requirements for LED luminaires.

Section F. Lighting Controls in any interior rooms

This table is a list of mandatory requirements for Lighting Controls in any interior rooms. .

~~Section G. Screw-Based luminaires~~

~~This table is a list of mandatory requirements for Screw-Based luminaires.~~

Section ~~H~~G. Address Signs.

This table is a list of mandatory requirements for Address Signs.

Section ~~I~~H. Outdoor Lighting and Controls

This table is a list of mandatory requirements for Outdoor Lighting and Controls.

Section ~~J~~I. Lighting for Residential Garages for Eight or More Vehicles

This table is a list of mandatory requirements for Lighting for Residential Garages for Eight or More Vehicles

Section ~~K~~J. Blank Electrical Boxes

This table is a list of mandatory requirements for Blank Electrical Boxes.

A. Installed Lighting and Controls

<<Static Text - see the top>>

Y or N

01	High Luminous Efficacy luminaires installed in any interior rooms. (See Section B.)	<<user selects from list: *Yes; *No>>
02	JA8 compliant luminaires installed in any interior rooms. (See Section B.)	<<user selects from list: *Yes; *No>>
03 02	Recessed downlight luminaires in ceilings in any interior rooms. (See Section C.)	<<user selects from list: *Yes; *No>>
04 03	Light Sources in Enclosed or Recessed Luminaires <u>(other than recessed downlights in ceilings)</u> . (See Section D.)	<<user selects from list: *Yes; *No>>
05 04	Lighting controls in bathrooms. (See Section E.)	<<user selects from list: *Yes; *No>>
06 05	Lighting controls in <u>garage</u> laundry rooms. (See Section E.)	<<user selects from list: *Yes; *No>>
07 06	Lighting controls in <u>utility</u> laundry rooms. (See Section E.)	<<user selects from list: *Yes; *No>>
08 07	Lighting controls in <u>garage</u> utility rooms. (See Section E.)	<<user selects from list: *Yes; *No>>
09 08	Lighting and controls in walk-in closets. (See Section E.)	<<user selects from list: *Yes; *No>>
10 09	Lighting controls in interior rooms <u>except bathrooms, garages, laundry rooms, utility rooms, and walk-in closets</u> . (See Section F)	
11	Screw-Based luminaires. (See Section G.)	<<user selects from list: *Yes; *No>>
12 10	Address signs.. (See Section HG .)	<<user selects from list: *Yes; *No>>
13 11	Outdoor lighting and controls. (See Section HI .)	<<user selects from list: *Yes; *No>>
14 12	Lighting for Residential Garages for Eight or More Vehicles. (See Section JI .)	<<user selects from list: *Yes; *No>>
15 13	Blank Electrical Boxes installed more than 5 feet from finished floor. (Section KJ .)	<<user selects from list: *Yes; *No>>

B. High Luminous Efficacy Luminaires

<<if High **Luminous** Efficacy luminaires installed in any interior rooms or JA8 compliant luminaires and controls installed in any interior rooms from Table A = 'Y' then display this section; else display standard "This Section Does Not Apply" message>>

<<Static Text - see the top>>

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.

C. Recessed Downlight Luminaires in Ceilings

<<if Recessed downlight luminaire in ceilings in any interior rooms from Table A = 'Y' then display this section; else display standard "This Section Does Not Apply" message>>

<<Static Text - see the top>>

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.

D. Light sources in enclosed or recessed luminaires (other than recessed downlight luminaires in ceilings)

<<if *Light sources in enclosed or recessed luminaires that are not comply with the JA8 from Table A = 'Y'* then display this section; else display standard "This Section Does Not Apply" message>>

<<Static Text - see the top>>

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.

E. lighting Controls in bathrooms, garages, laundry rooms, utility rooms, and walk-in closets

<<if *Lighting controls in bathrooms, Lighting controls in laundry rooms, Lighting controls in utility rooms, Lighting controls in garage or Lighting controls in and walk-in closets from Table A = 'Y'* then display this section; else display standard "This Section Does Not Apply" message>>

<<Static Text - see the top>>

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.

F. Lighting Controls in any interior rooms

<< *Lighting Controls in any interior rooms from Table A = 'Y'* then display this section; else display standard "This Section Does Not Apply" message>>

<<Static Text - see the top>>

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.

~~**G. Screw Based luminaires**<<if *Screw Based luminaires contained lamps that comply with JA8 from Table A = 'Y'* then display this section; else display standard "This Section Does Not Apply" message>>~~

~~<<Static Text - see the top>>~~

~~**The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.**~~

HG. Address Signs

<<if *Internally illuminated address signs from Table A = 'Y'* then display this section; else display standard "This Section Does Not Apply" message>>

<<Static Text - see the top>>

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.

HI. Outdoor Lighting and Controls

<<if *Outdoor lighting and controls from Table A = 'Y'* then display this section; else display standard "This Section Does Not Apply" message>>

<<Static Text - see the top>>

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.

JI. Lighting for Residential Garages for Eight or More Vehicles

<<if *Lighting for Residential Garages for Eight or More Vehicles from Table A = 'Y'* then display this section; else display standard "This Section Does Not Apply" message>>

<<Static Text - see the top>>

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.

~~**KJ. Blank Electrical Boxes**<<if *Blank electrical boxes installed more than 5 feet from the- finished floor from Table A = 'Y'* then display this section; else display standard "This Section Does Not Apply" message>>~~

~~<<Static Text - see the top>>~~

~~**The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.**~~