

**SAMPLE FORM – NOT VALID FOR SUBMISSION TO BUILDING DEPARTMENTS****CERTIFICATE OF INSTALLATION****Note:** This table completed by **HERSECC** Registry.

Project Name:	Enforcement Agency:
Dwelling Address:	Permit Number:
City and Zip Code:	Permit Application Date:

Title 24, Part 6, Section 150.0(o) **Ventilation for Indoor Air Quality**. All dwelling units shall meet the requirements of ASHRAE Standard 62.2, Ventilation and Acceptable Indoor Air Quality in Residential Buildings, subject to the amendments specified in Section 150.0(o)1.

A. Local Mechanical Exhaust - General Information

01	Dwelling Unit Name	
02	Building Type	
03	Total Kitchen Floor Area	
04	Kitchen Average Ceiling Height	
05	Kitchen Total Conditioned Volume	
06	Kitchen Type	
07	Dwelling Unit Total Floor Area	
08	Kitchen Range (Cooking Stove) Fuel Type	

B. Local Mechanical Exhaust System (Section 150.0(o)1G) – Fan Selection and Duct Design Criteria for Compliance

Local mechanical exhaust fans shall be installed in each kitchen and bathroom in accordance with Section 150.0(o)1G. Systems shall be rated for airflow in accordance with ASHRAE 62.2 section 7.1. Delivered local ventilation rates:

- All local ventilation rates have been measured using a flow hood, flow grid, or other airflow measuring device and meet the requirements of Tables 150.0-E, 150.0-F, or 150.0-G; OR

The airflow rating at a pressure of 0.25 in. w.c. of a certified fan is assumed because the local ventilation system duct sizing meets the prescriptive requirements of -Table 150.0-H.

Table 150.0-E
Demand-Controlled Local Ventilation Exhaust Airflow Rates and Capture Efficiency

Application	Airflow
Enclosed Kitchen or Nonenclosed Kitchen	Vented range hood, including appliance-range hood combinations shall meet either the capture efficiency (CE) or the airflow rate specified in Table 150.0-G as applicable.
Enclosed Kitchen <u>or</u> <u>Nonenclosed Kitchen</u>	Other kitchen exhaust fans, including downdraft: 300 cfm or a capacity of 5 ACH <u>Other kitchen exhaust fans, including downdraft: 300 cfm (150 L/s)</u>
Nonenclosed Kitchen	Other kitchen exhaust fans, including downdraft: 300 cfm
Bathroom	50 cfm <u>(25 L/s)</u>

Table 150.0-F
Continuous Local Ventilation Exhaust Airflow Rates

Application	Airflow
Enclosed kitchen	5 ach, based on kitchen volume
Bathroom	20 cfm <u>(10 L/s)</u>

**SAMPLE FORM – NOT VALID FOR SUBMISSION TO BUILDING DEPARTMENTS****Table 150.0-G****Kitchen Range Hood Airflow Rates (cfm) and ASTM E3087 Capture Efficiency (CE) Ratings According to Dwelling Unit Floor Area and Kitchen Range Fuel Type**

Dwelling Unit Floor Area (ft ²)	Hood Over Electric Range	Hood Over Natural Gas Range
>1500	50% CE or 110 cfm	70% CE or 180 cfm
>1000 - 1500	50% CE or 110 cfm	80% CE or 250 cfm
750 - 1000	55% CE or 130 cfm	85% CE or 280 cfm
<750	65% CE or 160 cfm	85% CE or 280 cfm

Table 150.0-H**Prescriptive Ventilation System Duct Sizing**

Fan Airflow Rating, CFM at minimum static pressure of 0.25 in. water	≤50 (25)	≤80 (40)	≤100 (50)	≤125 (60)	≤150 (70)	≤175 (85)	≤200 (95)	≤250 (120)	≤350 (165)	≤400 (190)	≤450 (210)	≤700 (330)	≤800 (380)
Duct Type	Minimum Duct Diameter, in. (mm) ^{a,b}												
Rigid duct	4 ^e (100)	5 (125)	5 (125)	6 (150)	6 (150)	7 (180)	7 (180)	8 (205)	9 (230)	10 (255)	10 (255)	12 (305)	12 ^d (305)
Flex duct ^c	4 (100)	5 (125)	6 (150)	6 (150)	7 (150)	7 (180)	8 (205)	8 (205)	9 (230)	10 (255)	NP	NP	NP

a. For noncircular ducts, calculate the diameter as four times the cross-sectional area divided by the perimeter.

b. NP = application of the prescriptive table is not permitted for this scenario.

c. Use of this table for verification of flex duct systems requires flex duct to be fully extended and any flex duct elbows to have a minimum bend radius to duct diameter ratio of 1.0.

d. For this scenario, use of elbows is not permitted.

e. For this scenario, 4 in. (100 mm) oval duct shall be permitted, provided the minor axis of the oval is greater than or equal to 3 in. (75 mm)

f. When a vented range hood utilizes a capture efficiency rating to demonstrate compliance with 150.0(o)1Giiib, a static pressure greater than or equal to 0.25 in. of water at the rating point shall not be required, and the airflow listed in the approved directory corresponding to the compliant capture efficiency rating point shall be applied to Table 150.0-H for determining compliance.

C. Kitchen Exhaust Systems

01	02	03	04	05	06	07	08	09a	09	10a	10	11	12
System Name	Manufacturer Name	System Type	HVI or AHAM Directory Listed Model Number	HVI or AHAM Directory Listed Rated Airflow	HVI or AHAM Directory Listed Sound Rating	Minimum Airflow (defaults to rated airflow)	Operation Schedule	Method of Compliance	Required Minimum Ventilation Rate	Exception to Maximum Sound Rating	Maximum Sound Rating	Compliance Statement for Airflow	Compliance Statement for Sound

D. Continuous Kitchen Exhaust

01	Total Continuous Ventilation Airflow	
02	Required Minimum Continuous Ventilation Airflow	
03	Compliance Statement	

**D2E. Kitchen Range Hood Capture Efficiency Option**

01	Manufacturer Name	
02	CEC-Approved Directory Listed Model Number	
03	CEC-Approved Directory Listed Rated Capture Efficiency	
04	Required Minimum Capture Efficiency (<i>Table 150.0-G</i>)	
05	Compliance Statement	

E. Other Requirements

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.

The items listed below correspond to the information given in Section 150.0(o)1G. Refer also to Chapter 4.6 of the Residential Compliance Manual for information describing these requirements in more detail. The signature of the Responsible Person in the declaration statement below certifies that the building complies with these requirements if applicable.

01	Demand control exhaust systems shall be provided with at least one of the following: 1. A readily accessible occupant-controlled on-off control. 2. An automatic control that does not impede occupant on control.
02	Nonenclosed kitchens shall be provided with a demand-controlled mechanical exhaust system.
03	Each continuous mechanical exhaust system shall be provided with a readily accessible manual on-off control. (Multifamily dwellings are exempt from readily accessible requirement.)
04	Continuous mechanical exhaust systems shall be designed to operate during all occupiable hours.
05	Exhaust fans in separate dwelling units shall not share a common exhaust duct. Exhaust inlets from more than one dwelling unit may be served by a single exhaust fan downstream of all the exhaust inlets if the fan is designated and intended to run continuously or if each inlet is equipped with a back-draft damper to prevent cross-contamination when the fan is not running.

**SAMPLE FORM – NOT VALID FOR SUBMISSION TO BUILDING DEPARTMENTS****DOCUMENTATION AUTHOR'S DECLARATION STATEMENT**

1. I certify that this Certificate of Installation documentation is accurate and complete.

Documentation Author Name:	Documentation Author Signature:
Documentation Author Company Name:	Date Signed:
Address:	CEA/ <u>HERSECC</u> Certification Identification (If applicable):
City/State/Zip:	Phone:

RESPONSIBLE PERSON'S DECLARATION STATEMENT

I certify the following under penalty of perjury, under the laws of the State of California:

1. The information provided on this certificate of installation is true and correct.
2. I am either: a) a responsible person eligible under division 3 of the business and professions code in the applicable classification to accept responsibility for the system design, construction, or installation of features, materials, components, or manufactured devices for the scope of work identified on this certificate of installation, and attest to the declarations in this statement, or b) I am an authorized representative of the responsible person and attest to the declarations in this statement on the responsible person's behalf.
3. The constructed or installed features, materials, components or manufactured devices (the installation) identified on this certificate of installation conforms to all applicable codes and regulations and the installation conforms to the requirements given on the certificate of compliance, plans, and specifications approved by the enforcement agency.
4. I understand that a HERSECC rater will check the installation to verify compliance and if such checking determines the installation fails to comply, I am required to offer any necessary corrective action at no charge to the building owner.
5. I understand that a registered copy of this certificate of installation shall be posted or made available with the building permit(s) issued for the building and made available to the enforcement agency for all applicable inspections, and I will take the necessary steps to ensure this requirement is accomplished.
6. I understand that a registered copy of this certificate of installation is required to be included with the documentation the builder provides to the building owner at occupancy, and I will take the necessary steps to ensure this requirement is accomplished.

Responsible Builder/Installer Name:	Responsible Builder/Installer Signature:	
Company Name: (Installing Subcontractor or General Contractor or Builder/Owner)	Position With Company (Title):	
Address:	CSLB License:	
City/State/Zip:	Phone:	Date Signed:

CF2R-MCH-32-H User Instructions

Section A. Local Mechanical Exhaust - General Information

1. Dwelling Unit Name: This field is filled out automatically and referenced from the MCH-01
2. Building Type: This field is filled out automatically and referenced from the CF1R.
3. Total Kitchen Floor Area: Enter the total floor area for an enclosed kitchen or N/A for a non-enclosed kitchen.
4. Kitchen Average Ceiling Height: Enter the kitchen ceiling height for an enclosed kitchen or N/A for a non-enclosed kitchen.
5. Kitchen Total Conditioned Volume: This field is filled out automatically and calculated based on the kitchen area and ceiling height.
6. Kitchen Type: Enter the type of kitchen (enclosed or non-enclosed).
7. Dwelling Unit Total Floor Area: This field is filled out automatically and referenced from the MCH-01.
8. Kitchen Range Fuel Type: Select the fuel type of the kitchen range.

Section C. Kitchen Exhaust System

1. System Name: Enter a unique name for the kitchen exhaust system
2. Manufacturer Name: Enter manufacturer name for the kitchen exhaust system.
3. System Type: Select the type of kitchen exhaust system. Options are vented range hood, downdraft, and other.
4. HVI or AHAM Directory Listed Model Number: Enter the kitchen exhaust system model number matching the installed equipment and HVI or AHAM directory.
5. HVI or AHAM Directory Listed Rated Airflow: Enter the rated airflow listed in the HVI or AHAM directory for the above model number.
6. HVI or AHAM Directory Listed Sound Rating: Enter the sound rating listed in the HVI or AHAM directory for the above model number.
7. Minimum Airflow (defaults to rated airflow): Defaults to rated airflow from HVI directory, but editable if exhaust system minimum airflow rate is less than HVI listed value.
8. Operation Schedule: Select the kitchen exhaust system operation schedule. Options are demand control and continuous.
- 9a. Method of Compliance: Select the method of compliance. Options are airflow and capture efficiency.
9. Required Minimum Ventilation Rate (if demand controlled): This field is filled out automatically and is calculated based on the system operation schedule and type, and kitchen type and volume, and Table 150.0-E and Table 150.0-G. This field is only used for demand control exhaust systems. Continuous exhaust required minimum ventilation rate is determined in Section D.
- 10a. Exception to Maximum Sound Rating: User select: No Exception or Remote mounted fan with min. 4-ft of duct between fan and intake grille.
10. Maximum Sound Rating: This field is filled out automatically and is calculated based the system operation schedule and minimum airflow.
11. Compliance Statement for Airflow: This field is filled out automatically based on the installed system listed airflow rate and minimum required ventilation rate. This field only determines compliance using airflow ratings for demand-controlled kitchen exhaust systems. Continuous system ventilation rate compliance is determined in Section D. Vented range hoods utilizing the capture efficiency rating for compliance is determined in Section E.

12. Compliance Statement for Sound. This field is filled out automatically based on the installed system listed sound rating and maximum sound rating allowed.

Section D. Continuous Kitchen Exhaust

1. Total Continuous Ventilation Airflow: This field is filled out automatically and is equal to the sum of the listed airflow for all continuously operated kitchen exhaust systems.
2. Required Minimum Continuous Ventilation Airflow: This field is filled out automatically and is equal to five times the enclosed kitchen volume.
3. Compliance Statement: This field is filled out automatically and is based on the total installed continuous ventilation airflow and the required minimum continuous ventilation airflow.

Section ~~D2E~~ E. Kitchen Range Hood Capture Efficiency Option

Note: This table is used only when complying with local exhaust requirements by utilizing the capture efficiency rating instead of the airflow rating.

1. Manufacturer Name: Enter manufacturer name for the kitchen range hood.
2. CEC-Approved Directory Listed Model Number: Enter the kitchen range hood model number matching the installed equipment and a CEC-approved directory listing.
3. CEC-Approved Directory Listed Rated Capture Efficiency: Enter the rated capture efficiency in the CEC-approved directory for the above model number.
4. Required Minimum Capture Efficiency: This field is filled out automatically and is determined by the dwelling unit square footage, kitchen range fuel type, and Table 150.0-G.
5. Compliance Statement. This field is filled out automatically based on the installed system listed capture efficiency rating and required minimum capture efficiency.

Section ~~EE~~ F. Other Requirements

1. This field must be a true statement (or not applicable) for the system to comply.
2. This field must be a true statement (or not applicable) for the system to comply.
3. This field must be a true statement (or not applicable) for the system to comply.
4. This field must be a true statement (or not applicable) for the system to comply.
5. This field must be a true statement (or not applicable) for the system to comply.

<<Static Text - see the top>>

A. Local Mechanical Exhaust - General Information

01	Dwelling Unit Name	<<Calculated field, referenced data from MCH-01, "Dwelling Unit Name" (A01) or Prescriptive CF1R; else if information is not available then allow user input >>
02	Building Type	<< reference data from CF1R, else if information is not available then allow user input. Allowed values = single family detached, or single family attached>>
03	Total Kitchen Floor Area	<<User Entered Value (XX.XX), if A06 = Non-Enclosed and [C03 = VentedRangeHood & C08 = Demand Control for ALL systems], then allow N/A>>
04	Kitchen Average Ceiling Height	<<User Entered Value (XX.XX), if A06 = Non-Enclosed and [C03 = VentedRangeHood & C08 = Demand Control for ALL systems], then allow N/A>>
05	Kitchen Total Conditioned Volume	<<calculated value, "Kitchen Floor Area (A03)" * "Kitchen Average Ceiling Height" (A04) (XX.XX); else if A03 or A04 = N/A, then value = N/A>>
06	Kitchen Type	User Entry, selections (Enclosed or Non-Enclosed)
07	Dwelling Unit Total Floor Area	<<Calculated field, referenced data from MCH-01, "Dwelling Unit Total Conditioned Floor Area" (field A03) or Prescriptive CF1R; else if information is not available then allow user input>>
08	Kitchen Range (Cooking Stove) Fuel Type	<<User Entered Value; Selections = (Electric , Natural Gas)>>

B. Local Mechanical Exhaust System (Section 150.0(o)1G) – Fan Selection and Duct Design Criteria for Compliance

<<Static Text - see the top>>

C. Kitchen Exhaust Systems

01	02	03	04	05	06	07	08	09a	09	10a	10	11	12
System Name	Manufacturer Name	System Type	HVI or AHAM Directory Listed Model Number	HVI or AHAM Directory Listed Rated Airflow	HVI or AHAM Directory Listed Sound Rating	Minimum Airflow (defaults to rated airflow)	Operation Schedule	Method of Compliance	Required Minimum Ventilation Rate	Exception to Maximum Sound Rating	Maximum Sound Rating	Compliance Statement for Airflow	Compliance Statement for Sound
<<User Entered Value up to 50 characters>>	<<User Entered Value up to 50 characters>>	<<User Entered Value; Selections = (Vented Range Hood, Down draft, Other) >>	<<User Entered Value up to 50 characters>>	<<User Entered Value; (XXXX.XX)>>	<<User Entered Value; (XX.XX) >>	<<Defaults to C05 otherwise, User Entered Value; (XXXX.XX); Not to exceed C05 (rated airflow) >>	<<User Entry; Selections = (Demand Control , Continuous) >>	<<If C08=Continuous, then report N/A; Else User select from list: *Airflow; or *Capture Efficiency >>	<<if C09a = Capture Efficiency, then result = "NA – See Table D2E."; Elseif C09a = Airflow, then calculate the following as default : If the following	<<default value = No Exception, but allow user to override and select: *Remounted fan with min. 4-ft of duct between fan and intake grille>>	<<If C10a ≠ No Exception, then value = N/A; Elseif Continuous, then value = "1 sone"; Elseif Demand Control and C07 ≤ 400 cfm, then value =	<<If C09a = Capture Efficiency, then result = N/A; Elseif C08 = 'Demand Control', and C05 (HVI Directory Listed Rated Airflow	<<If C06 ≤ C10 or C10 = N/A, then display text: "Complies"; else display text: "Does Not Comply" >>

								three conditions are met: (1) C08=Demand Control , (2) C03=Vent Range Hood, and (3) A08=Electric, AND If A07 > 1500, then result = 110; Elseif A07 = 1,000-1,500, then result = 110; Elseif A07 = 750-1,000, then result = 130; Elseif A07 = < 750, then result = 160; End if;		"3 sone"; Else value = "N/A">>	) ≥ C09 (Required Minimum Ventilation Rate), then display text: "Complies"; Elseif C08 = Continuous, then display text: "N/A"; else display text: "Does Not Comply" >>	
--	--	--	--	--	--	--	--	---	--	-----------------------------------	---	--

									and (3) A08 = Natural Gas, AND If A07 > 1,500, then result = 180; Elseif A07=1, 000- 1,500, then result = 250; Elseif A07 = 750- 1,000, then result = 280; Elseif A07 = <750, then result = 280; End if; Elseif the followi ng three conditi ons are met: (1) C08=D emand Control , (2) A06 = Enclose d, and C03 = Other or Downd raft, then result is the lesser of 300 cfm or				
--	--	--	--	--	--	--	--	--	--	--	--	--	--

									(5*(A05/60));				
									Elseif the following three conditions are met: (1) C08=Demand Control, (2) A06 = Nonen closed, and (3) C03 = Other or Downdraft, then result = 300; Else result = "N/A – See Table D."				

D. Continuous Kitchen Exhaust			
01	Total Continuous Ventilation Airflow		<<Result = Sum(C05 for all C08 = Continuous) {sum 'listed rated airflow' for all continuously operated fans}; Else result = "N/A">> {want this entry to be N/A if there are no continuously operated fans}
02	Required Minimum Continuous Ventilation Airflow		<<If D01 = N/A, then result = "N/A", Else result = 5*A05/60>>
03	Compliance Statement		<<If D01 = N/A, then result = "N/A"; Else if D01 ≥ D02 then result = "Complies", else result = "Does Not Comply"

~~D2E~~. Kitchen Range Hood Capture Efficiency Option

<< if C09a = Capture Efficiency, then display table; else display section header and standard "this section does not apply" message>>

01	Manufacturer Name	<<User Entered Value up to 50 characters>>	*
02	CEC-Approved Directory Listed Model Number	<<User Entered Value up to 50 characters>>	
03	CEC-Approved Directory Listed Rated Capture Efficiency (%)	<<User Entered Value; (XX.XX)>>	

04	Required Minimum Capture Efficiency (%)	<<Result = "50" for A08 = Electric and A07 > 1500; "50" for A08 = Electric and A07 is 1000 – 1500; "55" for A08 = Electric and A07 is 750 – 1000; "65" for A08 = Electric and A07 < 750; "70" for A08 = Natural Gas and A07 > 1500; "80" for A08 = Natural Gas and A07 is 1000 – 1500; "85" for A08 = Natural Gas and A07 is 750 – 1000; "85" for A08 = Natural Gas and A07 < 750>>	
05	Compliance Statement	<<If E03 ≥ E04, then display text: "Complies"; else display text: "Does Not Comply" >>	

EF. Other Requirements

<<Static Text - see the top>>

The responsible person's signature on this compliance document affirms that all applicable requirements in this table have been met.