



220002349162



中国认可
国际互认
检测
TESTING
CNAS L0690

Report No.: XJ2025B03A01822

Client: Taishi Energy Saving Materials Co., Ltd.

Sample Name: Rock wool board for building curtain wall

Test Category: Type Test



National Center for Quality Supervision and Test of Building Materials



XJ2025B03A01822



1. This report is invalid without the "Special Stamp for Testing" and the paging seal.
2. This report is invalid without the signatures of "Prepared, Reviewed, Approved".
3. This report is invalid if altered or partially copied.
4. This report is invalid if the test results are altered.
5. The entrusted test sample and information are provided by the client, and the institution is not responsible for their authenticity. The test results are only responsible for the received sample.
6. This report uses anti-counterfeiting paper. After photocopying, it should have a grid background pattern. The numbers on the back of the data pages are random numbers and have nothing to do with the report content.



Contact Information of the Institution:

Address: No.1 Guanzhuang Dongli, Chaoyang District, Beijing Postcode: 100024

Website: www.ctc.ac.cn

Customer Online Service Platform: <http://www.ctc-online.cn>

Business Reception Tel: 400-010-0010, 010-51167681

Business Reception Email: ywjd@ctc.ac.cn

Verification & Complaint Tel: 400-010-0010, 010-51167679

集
★
二
101

Sample Name	Rock wool board for building curtain wall	Test Category	Type Test
Client	Taishi Energy Saving Materials Co., Ltd.		Entrusted sampling
Inspected Unit	Taishi Energy Saving Materials Co., Ltd.	Trademark	Yueru
Manufacturer	Taishi Energy Saving Materials Co., Ltd.		
Sampling Unit	China Building Material Test Certification Group Co., Ltd.		1200mm×600mm×100mm-100kg/m3
Date of Mfg.	May 31, 2025		1500 m2
Sampling Date	June 10, 2025		6 pieces
Receipt Date	June 13, 2025	Sampler	He Xiaoqiang, Liu Deyu
Sampling Method	Random sampling		Tang Jun'an, Mao Wei
Sampling Location	Taishi Materials Warehouse		Seal intact
	See data pages for details of testing basis.		June 17, 2025 - July 30, 2025
Evaluation Basis	GB/T 19686-2015 "Rock wool thermal insulation products for buildings" GB 8624-2012 "Classification for burning behavior of building materials and products"		
Testing Items	Appearance, average fiber diameter, etc. (13 items in total). See data pages for details.		
Test Conclusion	Based on testing, the test results of the sampled items of the inspected sample comply with the technical requirements for curtain wall rock wool boards in GB/T 19686-2015; the test results of combustion performance comply with the technical requirements for flat-shaped building materials Class A (A1) non-combustible materials (products) in GB 8624-2012. See data pages for test results.		
Notes	(Blank here)		



Approved by: Mu Xiujun (Signed) 徐修军 Reviewed by: Xu Shenghua (Signed) 徐圣华 Prepared by: Lu Chengxin, Sun Chao (Signed) 卢成鑫 孙朝

No.	Testing Item		Standard Requirement (Rock Wool Board for Curtain Wall)	Test Result	Item Conclusi on	Test Basis
1	Appearance		The resin shall be distributed evenly, the surface shall be flat, and there shall be no scars, stains or damage that hinder use; if there is an outer cladding, the bonding between the outer cladding and the substrate shall be flat and firm.	The resin is distributed evenly, the surface is flat, and there are no scars, stains or damage that hinder use; no cladding.	Comply	GB/T 19686-2015 6.1
2	Average fiber diameter		≤6.0μm	5.2μm	Comply	GB/T 19686-2015 6.3 GB/T 5480-2017 8
3	Shot content (particle size > 0.25mm)		≤7.0%	3.7%	Comply	GB/T 5480-2017 9
4	Acidity coefficient		≥1.6	2.0	Comply	GB/T 5480-2017 10
5	Thermal conductivity (average temp. 25 deg. C)		≤0.040 W/(m•K)	0.037 W/(m•K)	Comply	GB/T 19686-2015 6.6 GB/T 10295-2008
6	Combustion performance Class A (A1)	Avg. furnace temp rise	≤30°C	4°C	Comply	GB/T 5464-2010
		Sustained flaming time	0s	0s	Comply	
		Mass loss rate	≤50%	5%	Comply	
		Gross heat of combustion	2.0MJ/kg	0.9MJ/kg		GB/T 14402-2007

No.	Testing Item	Standard Requirement (Rock Wool Board for Curtain Wall)	Test Result	Item Conclusi on	Test Basis
7	Mass moisture absorption rate	≤0.5%	0.2%	Comply	GB/T 5480-2017 11
8	Hydrophobicity rate	≥98.0%	99.9%	Comply	GB/T 10299-2011
9	Radionuclides	Internal exposure index IRa	≤1.0	Comply	GB 6566-2010
		External exposure index Ir	≤1.0	Comply	
10	Dimensional tolerance	Length	+10mm -3mm	Comply	GB/T 19686-2015 6.2 GB/T 5480-2017 7
		Width	+5mm -3mm	Comply	
		Thickness	+3mm -3mm	Comply	
		Average value	/	Comply	
11	Density (100kg/m3)	Density tolerance	±10%	Comply	+2%, 0%, +4%
12	Short-term water absorption	≤0.5kg/m²	0.1kg/m²	Comply	GB/T 19686-2015 6.19 GB/T 30805-2024
13	pH value of water extract	7.0~9.5	8.8	Comply	GB/T 19686-2015 附录 A.1

1. Testing location: Guanzhuang;
2. The results of the combustion performance test relate only to the behavior of the product specimens under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.

能将其

??????? End of Report ???????

China Building Material Test Certification Group Co., Ltd. (referred to as CTC, stock code 603060), through nearly seventy years of unremitting efforts and persistent pursuit, has developed into a large-scale, comprehensive, third-party inspection and certification service institution in the field of building materials and construction engineering in China. As the first A-share listed company with the prefix of "China" integrating inspection and certification, its branches are spread across the country, and it has more than thirty national and industry-level testing laboratories. It can provide comprehensive solutions for quality, safety, environmental protection, green development, and energy conservation for various clients, including building material manufacturers, construction engineering, decoration engineering, railway and rail transit engineering, municipal engineering, power engineering, industrial kilns, renewable resources, new energy, and home life.

China Building Material Test Certification Group Co., Ltd. always drives enterprise development with "scientific and technological innovation", adhering to the core philosophy of "impartiality-oriented, serving the society". It safeguards the enhancement of brand value for customers and the sustainable development of the industry, and contributes to the realization of national initiatives such as "Quality-based Nation" and "The Belt and Road"!

For more details, please visit the company's official website: <http://www.ctc.ac.cn/>

