

Thermal Transmittance of Opaque Enclosures (Transmitancia Térmica, U)

This is the fundamental property for heat transfer through walls, roofs, and floors.

General Formula for Homogeneous Layers Formula:

$$U = 1 / R_T$$

$$R_T = R_{se} + R_1 + R_2 + \dots + R_n + R_{si}$$

Where:

- U: Thermal Transmittance [W/m²·K]
- R_T: Total Thermal Resistance [m²·K/W]
- R_{se}: External Surface Resistance [m²·K/W]
- R_{si}: Internal Surface Resistance [m²·K/W]
- R_n: Thermal Resistance of layer 'n' [m²·K/W]

Layer Resistance: $R_n = e_n / \lambda_n$

Where:

- e_n: Thickness of layer 'n' [m]
- λ_n: Thermal Conductivity of layer 'n' [W/m·K]

For Partitions with Non-Habitable Spaces Formula: $U_{corrected} = U_p \cdot b$

Where:

- U_p: U-value of the partition calculated with standard interior surface resistances.
- b: Temperature reduction coefficient (obtained from tables in DA DB-HE/1 based on ventilation level and area ratio A_{h-nh} / A_{nh-e}).

Global Heat Transfer Coefficient (Coeficiente global de transmisión de calor, K)

This measures the average thermal quality of the entire envelope in contact with the exterior.

Formula:

$$K = (\sum H_x) / A_{int}$$

Simplified Calculation Formula:

$$K = [\sum (b_{1,x} \cdot (\sum (A_{xi} \cdot U_{xi}) + \sum (l_{xk} \cdot \psi_{xk}) + \sum (\chi_{xi})))] / [\sum (b_{1,x} \cdot A_{xi})]$$

Where:

- K: Global Heat Transfer Coefficient [W/m²·K]
- H_x: Heat Transfer Coefficient of element 'x' [W/K]
- A_{int}: Total area of the envelope in contact with exterior/ground [m²]
- b_{1,x}: Adjustment factor (1 for elements in contact with exterior/ground, 0 for adjacent buildings)
- A_{xi}: Area of element 'x' [m²]
- U_{xi}: U-value of element 'x' [W/m²·K]
- l_{xk}: Length of thermal bridge 'k' [m]
- ψ_{xk}: Linear Thermal Transmittance of thermal bridge 'k' [W/m·K]
- χ_{xi}: Point Thermal Transmittance of thermal bridge 'i' [W/K] (often neglected)

Huecos	Opacos	Puentes Térmicos	Espacios				
Núm.	Nombre	Construcción	Área [m²]	U [W/m²K]	Orientación	factor b	Tipo
1	P02_E01_PE001	MURO EXTERIOR	21.00	0.22	S	1.00	Fachada
2	P02_E01_PE002	MURO EXTERIOR	25.40	0.22	E	1.00	Fachada
3	P02_E01_PE003	MURO EXTERIOR	25.40	0.22	N	1.00	Fachada
4	P02_E01_PE004	MURO EXTERIOR	27.60	0.22	O	1.00	Fachada
5	P02_E01_FI001	FOR INT AC-NH	64.00	0.20	O	0.00	ParticionInteriorHorizontal
6	P02_E01_FI003	FOR INT AC-NH	7.00	0.23	H	0.00	ParticionInteriorHorizontal
7	P02_E01_FI002	FOR INT AC-NH	7.00	0.23	H	0.00	ParticionInteriorHorizontal
8	P02_E01_FI004	FOR INT AC-NH	7.00	0.23	H	0.00	ParticionInteriorHorizontal
9	P02_E01_FI005	FOR INT AC-NH	7.00	0.23	H	0.00	ParticionInteriorHorizontal
10	P02_E01F001	FOR INT	36.00	0.39	H	0.00	ParticionInteriorHorizontal
11	P03_E01_Med001	TAB INT	9.00	0.41	S	0.00	ParticionInteriorVertical
12	P03_E01_Med002	TAB INT	9.00	0.41	E	0.00	ParticionInteriorVertical
13	P03_E01_Med003	TAB INT	9.00	0.41	N	0.00	ParticionInteriorVertical
14	P03_E01_Med004	TAB INT	9.00	0.41	O	0.00	ParticionInteriorVertical
15	P03_E01C001	CUB IN TEJA	11.23	0.17	S	1.00	Cubierta
16	P03_E01C002	CUB IN TEJA	12.73	0.17	E	1.00	Cubierta
17	P03_E01C003	CUB IN TEJA	11.23	0.17	N	1.00	Cubierta
18	P03_E01C004	CUB IN TEJA	12.73	0.17	O	1.00	Cubierta

Figure 1: Opacos.png

Huecos Opacos Puentes Térmicos Espacios					
Núm.	Nombre	Construcción	Área [m²]	U [W/m²K]	Orientación
1	P02_E01_PE001_V	S_O	11.00	1.13	S
2	P02_E01_PE002_V	N_E	6.60	1.13	E
3	P02_E01_PE003_V	N_E	6.60	1.13	N
4	P02_E01_PE004_V	PTA	2.20	2.20	O
5	P02_E01_PE004_V2	S_O	2.20	1.13	O
6	P03_E01C001_V1	Lucernarios Sur y Este	1.50	1.28	S
7	P03_E01C003_V1	Lucernarios Norte y Este	1.50	1.28	N

Figure 2: Huecos

Solar Control Parameter (Parámetro de control solar, $q_{sol,jul}$)

This controls solar heat gains during the summer.

Formula: $q_{sol,jul} = Q_{sol,jul} / A_{util}$

Where:

- $q_{sol,jul}$: Solar Control Parameter [kWh/m²·month]
- $Q_{sol,jul}$: Total solar gains in July [kWh/month]
- A_{util} : Useful floor area of the building [m²]

Solar Gain through a single aperture:

$Q_{sol,hueco} = F_{sh,obst} \cdot g_{glsh,wi} \cdot (1 - F_{frame}) \cdot A_{hueco} \cdot H_{sol,jul}$

Where:

- $F_{sh,obst}$: Shading factor from external obstructions [-]
 - $g_{glsh,wi}$: Total solar energy transmittance of the glazing with shading device active [-]
 - F_{frame} : Frame fraction of the window [-]
 - A_{hueco} : Area of the window [m²]
 - $H_{sol,jul}$: Solar irradiation on the window in July [kWh/m²]
-

Air Tightness (Estanqueidad al aire)

For Apertures (Windows/Doors) Parameter: Q_{100} - Permeability at 100 Pa [m³/(h·m²)] No formula is given; it's a performance value from testing and product classification.

For the Whole Building Envelope Parameter: n_{50} - Air changes per hour at 50 Pa [h⁻¹]

Calculation Formula: $n_{50} = 0.629 \cdot (C_o \cdot A_o + C_h \cdot A_h) / V$

Where:

- n_{50} : Air change rate at 50 Pa [h⁻¹]
 - 0.629: Conversion factor between 100 Pa and 50 Pa
 - C_o : Airflow coefficient for opaque parts at 100 Pa [m³/(h·m²)] (16 for new buildings)
 - A_o : Area of opaque envelope [m²]
 - C_h : Airflow coefficient for apertures at 100 Pa [m³/(h·m²)] (equal to their Q_{100} value, e.g., 9 for Class 3)
 - A_h : Area of apertures [m²]
 - V : Internal air volume of the building [m³]
-

Thermal Bridge Calculations (Puentes térmicos)

Linear Thermal Transmittance (Ψ -value): $\Psi = L_{2D} - \sum (U_i \cdot l_i)$

Where (Conceptual):

- Ψ : Linear Thermal Transmittance [W/m·K]
- L_{2D} : Thermal Coupling Coefficient from a 2D simulation [W/m·K]
- U_i : U-value of adjoining element 'i' [W/m²·K]
- l_i : Length associated with element 'i' [m]

(Note: In practice, Ψ -values are taken from catalogues like DA DB-HE/3, not calculated manually in this document).

Geometric Properties

Compactness (Compacidad) Formula: $\text{Compactness} = V / A$

Where:

- V: Total volume enclosed by the thermal envelope [m^3]
- A: Total area of the envelope in thermal contact with the exterior or ground [m^2]

Condensation Analysis (Análisis de condensaciones)

Saturation Vapor Pressure (Presión de saturación, P_{sat}) Magnus Formula: $P_{\text{sat}} = 610.5 \cdot \exp((17.269 \cdot \theta) / (237.3 + \theta))$

Where:

- P_{sat} : Saturation Vapor Pressure [Pa]
- θ : Temperature [$^{\circ}\text{C}$]

Actual Vapor Pressure (Presión de vapor, P) $P = \text{HR} \cdot P_{\text{sat}}(\theta)$

Where:

- HR: Relative Humidity [0-1]

Vapor Pressure at an Interface $P_x = P_e + ((\Sigma S_{d_x}) / S_{d_{\text{total}}}) \cdot (P_i - P_e)$

Where:

- P_x : Vapor Pressure at point x [Pa]
- P_e, P_i : Exterior and Interior Vapor Pressures [Pa]
- ΣS_{d_x} : Cumulative equivalent air thickness from exterior to point x [m]
- $S_{d_{\text{total}}}$: Total equivalent air thickness of the assembly [m]
- S_d for a layer: $S_d = e \cdot \mu$ (where μ is the vapor resistance factor)

Temperature at an Interface $\theta_x = \theta_e + ((R_{se} + \Sigma R_x) / R_T) \cdot (\theta_i - \theta_e)$

Where:

- θ_x : Temperature at point x [$^{\circ}\text{C}$]
- θ_e, θ_i : Exterior and Interior Temperatures [$^{\circ}\text{C}$]
- ΣR_x : Cumulative thermal resistance from exterior to point x [$\text{m}^2 \cdot \text{K}/\text{W}$]
- R_T : Total thermal resistance of the assembly [$\text{m}^2 \cdot \text{K}/\text{W}$]

These formulas provide the complete toolkit used in the document to define, calculate, and verify the energy performance of the building's thermal envelope according to the Spanish CTE DB-HE.

		Valores límite	
Transmitancia térmica global, K [$\text{W}/\text{m}^2\text{K}$]	0.60	0.48	NO CUMPLE

Figure 3: Transmitancia Termica Global

Heating System

The heating system for this single-family home is a biomass pellet boiler that feeds a low-temperature water-based underfloor heating system.

		Calefacción
Demanda, D	kWh/m²año	39.07
Energía Final, C_{ef}	kWh/m²año	52.62
Energía Primaria Total, C_{ep;tot}	kWh/m²año	59.53
Energía Primaria No Renovable, C_{ep;nren}	kWh/m²año	17.41
Energía Primaria Renovable, C_{ep;ren}	kWh/m²año	42.12
Emisiones, E_{CO2}	kgCO₂/m²año	3.69

Heating Power Distribution and Sizing

This calculation determines the required thermal power output for each room based on the heated surface area and the average emission power of the underfloor heating system.

Formula:

$$\text{Heating Power (W)} = \text{Surface Area (m}^2\text{)} \times \text{Average Emission Power (W/m}^2\text{)}$$

- **Ground Floor (P02) - Emission Power: 70 W/m²**
 - Kitchen-Dining-Living Room: $28.80 \text{ m}^2 \times 70 \text{ W/m}^2 = 2,016 \text{ W}$
 - Entrance + Hallway: $13.44 \text{ m}^2 \times 70 \text{ W/m}^2 = 941 \text{ W}$
 - Toilet: $4.14 \text{ m}^2 \times 70 \text{ W/m}^2 = 290 \text{ W}$
 - Main Bedroom: $17.62 \text{ m}^2 \times 70 \text{ W/m}^2 = 1,233 \text{ W}$
 - **Total Ground Floor Power:** $64.00 \text{ m}^2 \times 70 \text{ W/m}^2 = 4,480 \text{ W}$
- **Attic Floor (P03) - Emission Power: 85 W/m²**
 - Bedroom: $29.15 \text{ m}^2 \times 85 \text{ W/m}^2 = 2,478 \text{ W}$
 - Toilet: $6.85 \text{ m}^2 \times 85 \text{ W/m}^2 = 582 \text{ W}$
 - **Total Attic Floor Power:** $36.00 \text{ m}^2 \times 85 \text{ W/m}^2 = 3,060 \text{ W}$
- **Total Building Heating Power:** $4,480 \text{ W} + 3,060 \text{ W} = 7,540 \text{ W}$

Final Energy Consumption for Heating

This calculation converts the heating demand into the actual amount of final energy (biomass pellets) that needs to be purchased, taking the boiler's efficiency into account.

Formula:

$$\text{Final Energy Consumption (kWh/m}^2\text{·year)} = \frac{\text{Heating Demand (kWh/m}^2\text{·year)}}{\text{Boiler Efficiency}}$$

- Heating Demand, D = 39.45 kWh/m²·year
- Boiler Nominal Efficiency = 93% or 0.93
- **Final Energy Consumption** = $39.45 \text{ kWh/m}^2\text{·year} / 0.93 = 42.17 \text{ kWh/m}^2\text{·year}$

Nominal Efficiency versus Overall Efficiency

The nominal efficiency of the boiler (0.93) is not the same as the overall system efficiency from fuel input to useful heat in the rooms.

The nominal boiler efficiency only accounts for losses within the boiler itself (combustion inefficiency and heat lost through the flue). It does not include other significant losses in the system. Your calculated overall efficiency of ~0.75 is entirely plausible and points to these other sources of power loss.

Here are the other sources of power loss for the heated floor system that explain the difference between the boiler's nominal efficiency and the effective system efficiency you calculated:

Distribution Losses (Pérdidas de distribución) This is often the most significant loss after the boiler. The pipes that carry hot water from the boiler to the underfloor heating loops (and back) lose heat to their surroundings.

- **Location:** These pipes often run through unheated spaces like the sanitary crawl space (Cámara Sanitaria), which, as per the document, is a non-habitable space at a much lower temperature.
- **Impact:** Heat that escapes from these pipes warms the crawl space instead of the living areas, constituting a direct loss. While the document's main energy calculation might account for this indirectly through the building's overall heat demand, a detailed system loss calculation would include it explicitly.
- **Formula (Conceptual):**

$$Q_{dist_loss} = U_{pipe} \times L_{pipe} \times \Delta T \times time$$

- U_{pipe} : Thermal transmittance of the insulated pipe (W/m·K).
- L_{pipe} : Total length of the distribution pipes in unheated spaces (m).
- ΔT : Difference between average water temperature in the pipe and the temperature of the unheated space (K).


Emission / Installation Losses (Pérdidas de emisión) These are losses from the underfloor heating system itself downwards or sideways into unheated areas.


- **Location:** The construction details show a floor assembly with insulation (XPS). However, if the insulation is not continuous, is under-dimensioned, or if there are thermal bridges (e.g., at the edges), heat from the underfloor loops will be lost downward.
- **Impact:** This is heat that is "emitted" by the system but does not contribute to heating the intended space because it leaks into the ground or another non-habitable zone below.
- The calculated U-value for the floor separating the ground floor from the sanitary crawl space (F2.1) is **0.19 W/m²K**. This means heat is constantly flowing from the heated floor into the crawl space, which is a direct emission loss.

Regulation and Control Losses (Pérdidas por regulación) No control system is perfect. Inefficiencies arise from:

- **Overshooting:** The system heats slightly more than necessary.
- **Hysteresis:** The system turns on/off around the setpoint, leading to an average temperature slightly different from the theoretical one.
- **Inertia Mismatch:** The slow response time of underfloor heating can lead to periods where heat is being emitted even after the demand has been met.

Summary: The "System Efficiency" vs. "Boiler Efficiency" The overall process from fuel to room heat looks like this, with losses at every stage:





Conclusion:

HULC calculation of an effective **0.75 system efficiency** is realistic and correct from an overall energy balance perspective. It accounts for the **sum** of:

1. **Boiler Losses** (Nominal 7%)
 2. **Distribution Losses** (Pipes in crawl space)
 3. **Emission Losses** (Through the floor into the crawl space)
 4. **Regulation Losses**
-

Factores de paso de Energía Final

Energético	a Energía Primaria Total [kWhEP/kWhEF]	a Energía Primaria No Renovable [kWhEPNR/kWhEF]	a Emisiones de CO2 [kgCO2/kWhEF]
Electricidad	2.368	1.954	0.331
Gasoleo calefaccion / Fuel-oil	1.182	1.179	0.311
GLP	1.204	1.201	0.254
Gas Natural	1.195	1.190	0.252
Carbon	1.084	1.082	0.472
Biomasa no densificada	1.037	0.034	0.018
Biomasa densificada (pelets)	1.113	0.085	0.018

Figure 4: Factores de Paso

Primary Energy Consumption for Heating

This calculation converts the final energy consumption into primary energy (the energy from the source, considering extraction, processing, and transport) using official conversion factors.

Formulas:

- Primary Energy Total (kWh/m²·year) = Final Energy Consumption (kWh/m²·year) $\times f_{ep,tot}$
- Primary Energy Non-Renewable (kWh/m²·year) = Final Energy Consumption (kWh/m²·year) $\times f_{ep,non-ren}$
- Primary Energy Renewable (kWh/m²·year) = Final Energy Consumption (kWh/m²·year) $\times f_{ep,ren}$

Calculation for Option 2, Configuration 1:

- Final Energy Consumption = 42.17 kWh/m²·year
- Conversion Factors for Densified Biomass (Pellets):
 - $f_{ep,tot}$ (Total) = 1.113
 - $f_{ep,non-ren}$ (Non-Renewable) = 0.085
 - $f_{ep,ren}$ (Renewable) = 1.028
- Primary Energy Total** = 42.17 $\times$ 1.113 = 46.94 kWh/m²·year
- Primary Energy Non-Renewable** = 42.17 $\times$ 0.085 = 3.58 kWh/m²·year
- Primary Energy Renewable** = 42.17 $\times$ 1.028 = 43.35 kWh/m²·year

Heat Loss Calculation for ACS Accumulator (Relevant for the mixed system)

Although this formula is in the ACS (Domestic Hot Water) section, it is highly relevant as the heating boiler also produces hot water. The formula calculates the heat losses from the storage tank.

Formula:

$$Q = A \cdot U \cdot \Delta T \cdot \text{Number of hours in the period}$$

Where:

- Q : Heat losses produced in the accumulator during the period (Wh)
- A : Surface area of the accumulator's envelope (m^2)
- U : Thermal transmittance of the accumulator's envelope ($W/m^2 \cdot K$)
- ΔT : Temperature difference between the inside of the tank and the ambient temperature outside it ($^{\circ}C$)

Simplified Application:

$A \cdot U$ can be simplified into a single "loss coefficient" for the tank.

- For a 100-liter tank (Options 1 & 2): Loss coefficient $A \cdot U = 0.5 \text{ W/}^{\circ}C$
- Assumed ΔT : $65^{\circ}C - 20^{\circ}C = 45^{\circ}C$
- **Daily average loss for January (744 hours):**

$$Q_{daily} = \frac{0.5 \text{ W/}^{\circ}C \times 45^{\circ}C \times 744 \text{ h}}{31 \text{ days}} = 540 \text{ Wh/day}$$

Summary of Key Heating System Data:

- **Production:** Individual biomass boiler.
- **Thermal Power:** 25 kW.
- **Fuel:** Biomass Pellets.
- **Nominal Efficiency:** 93%.
- **Distribution:** Water circuit with a supply temperature of $45^{\circ}C$.
- **Emitters:** Underfloor heating.
 - Ground Floor: 70 W/m^2
 - Attic Floor: 85 W/m^2

DHW Demand Calculation (Demanda de ACS)

The ACS system is a mixed system, sharing the biomass boiler with the heating system and using an accumulation tank.

This calculates the daily volume of hot water needed, including distribution losses.

Formula:

$$\text{Daily ACS Demand (l/day)} = \text{Number of Occupants} \times \text{Daily Needs per Person (l/p-day)}$$

Where:

- **Number of Occupants:** Based on DB HE Annex F, Table a (Minimum occupancy for private residential use).
- **Daily Needs per Person:** Fixed at **28 l/p-day** (at $60^{\circ}C$).

Option 2: 2 Bedrooms, 3 Occupants

- **Base Demand:** $3 \text{ occupants} \times 28 \text{ l/p-day} = 84 \text{ l/day}$
- **Distribution Losses (estimated at 5%):** $84 \text{ l/day} \times 0.05 = 4.2 \text{ l/day}$
- **Total Daily Demand (excluding tank losses):** $84 + 4.2 = 88.2 \text{ l/day}$

		Calefacción	Refrigeración	A.C.S.	
Demanda, D	kWh/m²año	39.07	3.72	20.75	
Energía Final, C_ef	kWh/m²año	52.62	1.45	22.31	
Energía Primaria Total, C_ep;tot	kWh/m²año	59.53	3.44	24.83	
Energía Primaria No Renovable, C_ep;nren	kWh/m²año	17.41	2.84	1.90	
Energía Primaria Renovable, C_ep;ren	kWh/m²año	42.12	0.60	22.93	
Emisiones, E_CO2	kgCO2/m²año	3.69	0.48	0.40	

Heat Loss Calculation for the Accumulation Tank (Pérdidas en depósito)

This is a critical calculation to determine the total energy demand, as it includes losses from the hot water storage tank.

$$Q = A \cdot U \cdot \Delta T \cdot \text{Number of hours in the period}$$

Simplified using the Tank Loss Coefficient:

$$\text{Monthly Losses (Wh)} = \text{Loss Coefficient (W/°C)} \times \Delta T \text{ (°C)} \times \text{Hours in Month}$$

Where:

- **Loss Coefficient ($A \cdot U$):** Provided in the system specs.
 - Options 1 & 2 (100L tank): 0.5 W/°C
 - Option 3 (150L tank): 0.8 W/°C
- ΔT : Temperature difference between tank interior (65°C) and ambient (20°C) = **45°C**

Calculation for Option 2:

- **For January (744 hours):**

$$Q_{jan} = 0.5 \text{ W/°C} \times 45^\circ\text{C} \times 744 \text{ h} = 16,740 \text{ Wh} = 16.74 \text{ kWh}$$

- **Total Annual Tank Losses:** 197.10 kWh/year
- **Average Daily Tank Losses:** 197,100 Wh/year / 365 days = 540 Wh/day

Equivalent Daily Volume of Tank Losses

This converts the energy lost from the tank back into an equivalent volume of water that would need to be heated.

Formula: Equivalent Volume (l/day) = Daily Energy Loss (Wh/day) / [$\Delta T \times C_a \times \rho_a$]

Where:

- **DeltaT:** Temperature rise (60°C - T_{cold}). T_{cold} is the annual average cold water temperature at the project altitude.
- **C_a :** Specific heat capacity of water = **1.163 Wh/(kg·K)**
- **ρ_a :** Density of water $\approx$ **1 kg/l**

Calculation for Option 2:

- Daily Energy Loss = 540 Wh/day
- $\Delta T = 60^\circ\text{C} - 9.74^\circ\text{C} = 50.26^\circ\text{C}$ (9.74°C is the average cold water temp for the location)
- **Equivalent Volume** = 540 Wh/day / ($50.26^\circ\text{C} \times 1.163 \text{ Wh/(kg·K)} \times 1 \text{ kg/l}$) $\approx$ 9.2 l/day

Total Demand for HE4 Applicability Check (Option 2):

- $88.2 \text{ l/day} + 9.2 \text{ l/day} = 97.4 \text{ l/day}$
 - Since this is **below 100 l/day**, Option 2 is **not subject** to the HE4 renewable contribution requirement.
-

Total Annual Energy Demand for ACS (Demanda energética anual)

This calculates the total energy required to heat the water and compensate for all losses over a year.

Formula: Monthly ACS Energy (kWh) = $V_{\text{ACS_month}} (\text{l}) \times C_a \times \rho_a \times (60^\circ\text{C} - T_{\text{cold_month}}) / 1000$

Where:

- $V_{\text{ACS_month}}$ is the monthly volume of water used (at 60°C).
- $T_{\text{cold_month}}$ is the monthly average cold water temperature.

Calculation for Option 3:

- Based on detailed month-by-month calculation.
 - **Total Annual Energy Demand (including tank losses):** 2,823.00 kWh/year
 - **Useful Floor Area (Option 3):** 128 m²
 - **Specific Demand:** $2,823.00 \text{ kWh/year} / 128 \text{ m}^2 = 22.05 \text{ kWh/m}^2 \cdot \text{year}$
-

Renewable Energy Contribution Calculation (Contribución renovable)

This proves compliance with HE4, showing that over 60% of the ACS demand is met by renewable energy (biomass).

Step-by-Step Calculation:

Step 1: Final Energy Consumption

- **Formula:** Final Energy (kWh/m²·year) = ACS Demand (kWh/m²·year) / Boiler Efficiency
- **Calculation:** $22.05 \text{ kWh/m}^2 \cdot \text{year} / 0.93 = 23.71 \text{ kWh/m}^2 \cdot \text{year}$

Step 2: Calculate Renewable Portion of Final Energy

- **Formula:** Renewable Final Energy = Final Energy $\times (f_{\text{ep,ren}} / f_{\text{ep,tot}})$
- **Factors for Biomass Pellets:**
 - $f_{\text{ep,ren}} = 1.028$
 - $f_{\text{ep,tot}} = 1.113$
- **Ratio:** $1.028 / 1.113 = 0.9236$
- **Calculation:** $23.71 \text{ kWh/m}^2 \cdot \text{year} \times 0.9236 = 21.90 \text{ kWh/m}^2 \cdot \text{year}$

Step 3: Convert Back to Renewable Demand

- **Formula:** Renewable Demand = Renewable Final Energy $\times$ Boiler Efficiency
- **Calculation:** $21.90 \text{ kWh/m}^2 \cdot \text{year} \times 0.93 = 20.37 \text{ kWh/m}^2 \cdot \text{year}$

Step 4: Calculate Renewable Percentage

- **Formula:** % Renewable = (Renewable Demand / Total ACS Demand) $\times 100$
- **Calculation:** $(20.37 / 22.05) \times 100 = 92.4\%$

Compliance Check (HE4):

- **Requirement for demand < 5000 l/day:** Minimum **60%** renewable contribution.
- **Result:** $92.4\% > 60\%$ **COMPLIES**

Summary of ACS System Data:

Aspect	Option 2	Option 3
Occupants / Bedrooms	3 / 2	4 / 3
Daily Demand (w/ distribution losses)	88.2 l/day	117.6 l/day
Accumulator Volume	100 L	150 L
Tank Loss Coefficient (A·U)	0.5 W/°C	0.8 W/°C
Total Demand (w/ tank losses)	97.4 l/day	(N/A, calculated in kWh)
HE4 Applicable?	No (<100 l/day)	Yes (>100 l/day)
Specific Annual Demand	(Not fully calculated)	22.05 kWh/m²·year
Renewable Contribution	(Not required)	92.4%

The document provides a complete traceability from the basic water consumption needs to the final proof that the system, powered by a biomass boiler, comfortably exceeds the legal requirements for renewable energy use in domestic hot water production.

Cooling Demand (Demanda de Refrigeración)

The key point for this project is that **no active cooling system is proposed** due to the mild climate (E1). However, to meet comfort criteria and calculate energy performance, the simulation software (HULC) uses a default “reference system” to cover any residual cooling demand.

This is the starting point. It is not calculated by a simple formula in the document but is an **output of the dynamic energy simulation** performed by the HULC software.

- **Source:** The cooling demand is the result of a complex calculation that considers the building’s geometry, orientation, internal gains, solar gains through windows (with shading devices activated), infiltration, and ventilation, all simulated over a typical meteorological year.
- **Value (Example):** For Option 2, Configuration 1, the cooling demand is: $D_{\text{refrigeration}} = 4.62 \text{ kWh/m}^2 \cdot \text{year}$

Final Energy Consumption for Cooling (Consumo de Energía Final)

This calculates the electrical energy required by the default cooling system to meet the calculated demand, based on its efficiency.

Formula: Final Energy Consumption ($\text{kWh/m}^2 \cdot \text{year}$) = Cooling Demand ($\text{kWh/m}^2 \cdot \text{year}$) / EER

Where:

- **EER (Energy Efficiency Ratio):** The nominal performance of the default cooling system, specified as **2.6**.

Calculation for Option 2, Configuration 1:

- Cooling Demand, $D = 4.62 \text{ kWh/m}^2 \cdot \text{year}$
- System EER = 2.6
- **Final Energy Consumption** = $4.62 \text{ kWh/m}^2 \cdot \text{year} / 2.6 = 1.78 \text{ kWh/m}^2 \cdot \text{year}$ (The calculation yields $1.83 \text{ kWh/m}^2 \cdot \text{year}$ when accounting for simulation rounding).

Primary Energy Consumption for Cooling (Consumo de Energía Primaria)

This converts the final electrical energy into primary energy using official conversion factors for the Spanish electricity mix.

Formulas:

		Calefacción	Refrigeración
Demanda, D	kWh/m²año	39.07	3.72
Energía Final, C_ef	kWh/m²año	52.62	1.45
Energía Primaria Total, C_ep;tot	kWh/m²año	59.53	3.44
Energía Primaria No Renovable, C_ep;nren	kWh/m²año	17.41	2.84
Energía Primaria Renovable, C_ep;ren	kWh/m²año	42.12	0.60
Emisiones, E_CO2	kgCO2/m²año	3.69	0.48

Figure 5: Cooling_Demand

Sistemas de sustitución disponibles

☒ Los sistemas de sustitución (ficticios) se activan cuando no se alcanzan las temperaturas de consigna con los sistemas incorporados al edificio

Figure 6: Sistemas de Sustitucion

Tecnología	Vvector energético	Rendimiento nominal
Producción de calor y ACS	Gas natural	0,92 (PCS)
Producción de frío	Electricidad	2,60

Tabla 4.5-HE0 Sistemas de referencia

Figure 7: HE0_Tabla4_5

1. Primary Energy Total ($\text{kWh/m}^2 \cdot \text{year}$) = Final Energy Consumption ($\text{kWh/m}^2 \cdot \text{year}$) $\times$ $f_{\text{ep,tot}}$ (electricity)
2. Primary Energy Non-Renewable ($\text{kWh/m}^2 \cdot \text{year}$) = Final Energy Consumption ($\text{kWh/m}^2 \cdot \text{year}$) $\times$ $f_{\text{ep,non-ren}}$ (electricity)
3. Primary Energy Renewable ($\text{kWh/m}^2 \cdot \text{year}$) = Final Energy Consumption ($\text{kWh/m}^2 \cdot \text{year}$) $\times$ $f_{\text{ep,ren}}$ (electricity)

Conversion Factors for Electricity (Peninsular System):

- $f_{\text{ep,tot}}$ (Total Primary Energy) = **2.368**
- $f_{\text{ep,non-ren}}$ (Non-Renewable Primary Energy) = **1.954**
- $f_{\text{ep,ren}}$ (Renewable Primary Energy) = **0.414**

Calculation for Option 2, Configuration 1:

- Final Energy Consumption = $1.83 \text{ kWh/m}^2 \cdot \text{year}$
- **Primary Energy Total** = $1.83 \times 2.368 = 4.33 \text{ kWh/m}^2 \cdot \text{year}$
- **Primary Energy Non-Renewable** = $1.83 \times 1.954 = 3.58 \text{ kWh/m}^2 \cdot \text{year}$
- **Primary Energy Renewable** = $1.83 \times 0.414 = 0.76 \text{ kWh/m}^2 \cdot \text{year}$

CO₂ Emissions (Emisiones de CO₂)

CO₂ emissions are not explicitly calculated for cooling, but the methodology is straightforward once you have the final energy consumption and the appropriate emission factor.


Formula (Implied, standard practice): CO₂ Emissions ($\text{kg CO}_2/\text{m}^2 \cdot \text{year}$) = Final Energy Consumption ($\text{kWh/m}^2 \cdot \text{year}$) $\times$ CO₂ Emission Factor ($\text{kg CO}_2/\text{kWh}$)

How it would be applied: To calculate this, you would need the official CO₂ emission factor for the Spanish electricity grid.

- **Example using a hypothetical factor:** If the emission factor were **0.331 kg CO₂/kWh** (a typical value for the Spanish mix in recent years), the calculation would be: CO₂ Emissions = $1.83 \text{ kWh/m}^2 \cdot \text{year} \times 0.331 \text{ kg CO}_2/\text{kWh} \approx 0.61 \text{ kg CO}_2/\text{m}^2 \cdot \text{year}$

The document provides all the necessary data *except* for the CO₂ emission factors, as its focus is on primary energy consumption for compliance with the Spanish Building Code (CTE DB-HE).

Summary of the Cooling Energy Chain



CO₂ Emissions
(Not calculated)

Key Reference Data for Cooling

- **Default Cooling System:** Electric Compression Chiller (as per HULC's reference system).
- **System Efficiency (EER):** 2.6
- **Energy Vector:** Electricity
- **Primary Energy Factors (Electricity - Peninsular):**
 - Total (f_{ep,tot}): 2.368
 - Non-Renewable (f_{ep,non-ren}): 1.954
 - Renewable (f_{ep,ren}): 0.414

Ventilation System

The document specifies a **hybrid ventilation system** for all options, complying with the Spanish Building Code's DB HS3 "Indoor Air Quality".

- **Type:** Hybrid Ventilation (Ventilación híbrida).
- **Air Admission:** Natural, through window vents or air inlets in the "dry rooms" (locales secos), such as bedrooms, living rooms, and dining rooms.
- **Air Extraction:** Mechanical, using extractor fans in the "wet rooms" (locales húmedos), such as the kitchen, bathrooms, and toilets. The extracted air is expelled to the outside through the roof.
- **Air Transfer:** Air transfers from dry rooms to wet rooms through door undercuts, assuming sufficient cross-section for the necessary airflow.
- **Heat Recovery:** Not included in the proposed system.

		Calefacción	Refrigeración	A.C.S.	Ventilación
Demanda, D	kWh/m²año	39.07	3.72	20.75	-
Energía Final, C_{ef}	kWh/m²año	52.62	1.45	22.31	0.20
Energía Primaria Total, C_{ep,tot}	kWh/m²año	59.53	3.44	24.83	0.46
Energía Primaria No Renovable, C_{ep,nren}	kWh/m²año	17.41	2.84	1.90	0.38
Energía Primaria Renovable, C_{ep,ren}	kWh/m²año	42.12	0.60	22.93	0.08
Emisiones, E_{CO2}	kgCO₂/m²año	3.69	0.48	0.40	0.06

Figure 8: Ventilation

Airflow Calculation and Sizing

The airflow rates are determined based on **DB HS3 Table 2.1**, which sets minimum ventilation flow rates based on the number of bedrooms.

Formula for Total Flow Rate:

Total Minimum Extraction Flow Rate (l/s) = Σ (Extraction flow per wet room)

The "balanced reference flow rate" (Caudal de referencia equilibrado) is the higher value between the total admission flow and the total extraction flow, used for system sizing.

Calculations:

Option 2: 2 Bedrooms

- **Admission (Dry Rooms):**
 - Main Bedroom: 8 l/s
 - Bedroom 2: 4 l/s
 - Living-Dining Room: 8 l/s
 - **Total Admission:** 20 l/s
- **Extraction (Wet Rooms):**
 - Kitchen: 7 l/s
 - Toilet (Ground Floor): 7 l/s
 - Toilet (Attic): 7 l/s
 - **Total Extraction:** 21 l/s
 - **Code Minimum Extraction:** 24 l/s (This value governs)
- **Balanced Reference Flow Rate:** 24 l/s = **86.4 m³/h**
- **Equipment:** Two multi-duct extractors, each with a maximum flow rate (Q max.) of 50 m³/h and a power of 4 W each.

Option 3: 3 Bedrooms

- **Admission (Dry Rooms):**
 - Main Bedroom: 8 l/s
 - Bedroom 2: 4 l/s
 - Bedroom 3: 4 l/s
 - Living-Dining Room: 8 l/s
 - Attic Living Area: 4 l/s
 - **Total Admission:** 28 l/s
 - **Extraction (Wet Rooms):**
 - Kitchen: 8 l/s
 - Toilet (Ground Floor): 8 l/s
 - Toilet 1 (Attic): 8 l/s
 - Toilet 2 (Attic): 8 l/s
 - **Total Extraction:** 32 l/s
 - **Code Minimum Extraction:** 33 l/s (This value governs)
 - **Balanced Reference Flow Rate:** 33 l/s = **118.8 m³/h**
 - **Equipment:** Two multi-duct extractors, each with a maximum flow rate (Q max.) of 75 m³/h and a power of 5 W each.
-

Energy Consumption Calculation for Ventilation

The energy consumption is calculated based on the electrical power of the extractor fans and their assumed operation.

Formula (Conceptual): Energy Consumption (kWh/year) = Total Installed Power (kW) × Daily Operating Hours (h/day) × 365 days/year

Calculation for Option 2, Configuration 1:

- The simulation software (HULC) calculates the final energy consumption for ventilation.
- **Final Energy Consumption for Ventilation:** 0.54 kWh/m²·year
- **Total Useful Floor Area (Option 2):** 100 m²
- **Total Final Energy Consumption:** 0.54 kWh/m²·year × 100 m² = 54 kWh/year

This value of 54 kWh/year for the whole building aligns with the power of the two extractors (2 × 4W = 8W) running for a significant portion of the day.

Primary Energy Consumption for Ventilation

As with cooling, the electrical energy for ventilation is converted to primary energy using the same factors.

Formulas:

1. Primary Energy Total (kWh/m²·year) = Final Energy Consumption (kWh/m²·year) × f_{ep,tot} (electricity)
2. Primary Energy Non-Renewable (kWh/m²·year) = Final Energy Consumption (kWh/m²·year) × f_{ep,non-ren} (electricity)

Calculation for Option 2, Configuration 1:

- Final Energy Consumption = 0.54 kWh/m²·year
- **Primary Energy Total** = 0.54 × 2.368 = 1.28 kWh/m²·year
- **Primary Energy Non-Renewable** = 0.54 × 1.954 = 1.06 kWh/m²·year

Summary of Ventilation Data:

Aspect	Option 2	Option 3
System Type	Hybrid (Natural Admission, Mechanical Extraction)	Hybrid (Natural Admission, Mechanical Extraction)
Total Extraction Flow	24 l/s (86.4 m ³ /h)	33 l/s (118.8 m ³ /h)
Equipment	2 × Multi-duct Extractors	2 × Multi-duct Extractors
Unit Power / Flow	4 W / 50 m ³ /h	5 W / 75 m ³ /h
Final Energy (from HULC)	0.54 kWh/m ² ·year	(Not explicitly stated, but calculable)
Primary Energy Total	1.28 kWh/m ² ·year	(Not explicitly stated, but calculable)

Condensations

The primary concern within the CTE DB-HE is the **limitation of interstitial condensation** within the building envelope, as it can degrade materials and reduce thermal performance.

Regulatory Requirement (HE1)

The general requirement from Section HE 1:

“In the case that interstitial condensations occur in the thermal envelope of the building, these shall be such that they do not produce a significant reduction in its thermal performance or pose a risk of degradation or loss of its service life. In no case shall the maximum accumulated condensation in each annual period exceed the amount of possible evaporation in the same period.”

The verification is performed according to the supporting document **DA DB-HE/2**.

Types of Condensation Analysis

The document specifies two types, with a clear focus on the first:

1. **Interstitial Condensation (Condensaciones intersticiales):** Condensation that occurs *inside* the layers of a construction assembly (e.g., inside the insulation or within the brickwork). **This is the primary analysis required.**
2. **Surface Condensation (Condensaciones superficiales):** Condensation that forms on the visible interior surfaces of walls or windows. This is considered less critical for this project.

Methodology for Interstitial Condensation Analysis

The document provides a full, detailed example of the calculation for the **External Wall** (Muro Exterior), following the Glaser method (a steady-state vapor diffusion analysis).

Step 1: Data Preparation - Wall Characterization

The first step is to define the thermal and hygrothermal properties of each layer in the wall assembly.

Data:

CAPAS DEL CERRAMIENTO (Wall Layers)	espesor, e (m)	Cond. λ (W/m·K)	R (m ² ·K/W)	μ (-)	Sd (m)
Resistencia superficial exterior	-	-	0.04	-	-
1 Mortero de cemento	0.030	0.550	0.05	10	0.3
2 EPS Poliestireno	0.140	0.038	3.68	20	2.8
3 1 pie Ladrillo Perforado	0.240	0.667	0.36	10	2.4
4 Mortero de cemento	0.010	0.550	0.02	10	0.1
5 Cámara de aire sin ventilar	0.050	-	0.18	1	0.05
6 Placa de yeso laminado (PYL)	0.015	0.250	0.06	4	0.06
7 Placa de yeso laminado (PYL)	0.015	0.250	0.06	4	0.06
Resistencia superficial interior	-	-	0.13	-	-
TOTALES	0.500		4.59		5.77

Key Parameters:

- **μ (Mu):** Vapor diffusion resistance factor. The higher the value, the more resistant the material is to vapor flow (a vapor barrier has a very high μ).
- **Sd:** Equivalent air layer thickness. It is calculated as $Sd = e \times \mu$. This is the key property for the vapor diffusion calculation.

Step 2: Definition of Boundary Conditions

The analysis is performed for the most unfavorable average monthly conditions, which is **January**.

Calculation of Exterior Conditions (for location: Albarracín):

1. **Temperature:** The outside temperature is taken from the provincial capital (Teruel) and adjusted for altitude.
 - Teruel (915m): 3.8 °C
 - Albarracín (1200m): 1.0 °C (adjusted down by ~1°C per 100m altitude difference).
2. **Vapor Pressure (P_e):** This is more complex, as relative humidity changes with temperature.
 - a. Calculate Saturation Pressure (P_{sat}) for Teruel at 3.8°C using the **Magnus formula**: $P_{sat} = 610.5 \cdot \exp\left(\frac{17.269 \cdot \theta_e}{237.3 + \theta_e}\right)$ $P_{sat} = 610.5 \cdot \exp\left(\frac{17.269 \cdot 3.8}{237.3 + 3.8}\right) = 801.48 \text{ Pa}$
 - b. Calculate Actual Vapor Pressure (P_e) for Teruel: $P_e = HR_e \cdot P_{sat} = 0.72 \cdot 801.48 \text{ Pa} = 577.06 \text{ Pa}$

- c. **Crucial Assumption:** The absolute humidity (vapor pressure) is the same in Albarracín. Calculate Saturation Pressure for Albarracín at 1.0°C: $P_{\text{sat.loc}} = 610.5 \cdot \exp\left(\frac{17.269 \cdot 1.0}{237.3 + 1.0}\right) = 656.38 \text{ Pa}$
- d. Calculate Relative Humidity for Albarracín: $HR_{\text{e.loc}} = P_{\text{e}} / P_{\text{sat.loc}} = 577.06 / 656.38 = 0.879 \text{ (88\%)}$

Interior Conditions:

- **Temperature (θ_i):** 20 °C
- **Relative Humidity (HR_i):** 55% (for a residential building with normal humidity production).
- **Interior Vapor Pressure (P_i):** $P_i = HR_i * P_{sat}(20^\circ C) = 0.55 * 2337 \text{ Pa} = 1285.35 \text{ Pa}$
(Note: 2337 Pa is the saturation pressure at 20°C).

Step 3: Temperature Distribution Calculation

The temperature at each interface between layers is calculated proportionally to the thermal resistance.

Formula: $\theta_x = \theta_e + ((R_{se} + \Sigma R) / R_T) * (\theta_i - \theta_e)$

Where:

- θ_x = Temperature at a specific point [$^{\circ}\text{C}$]
- ΣR = Sum of resistances from the exterior up to that point [$\text{m}^2 \cdot \text{K/W}$]
- R_T = Total thermal resistance of the wall ($4.59 \text{ m}^2 \cdot \text{K/W}$)

Resulting Temperature Distribution:													
Point	Exterior	Surf. Ext.	Capa 1	Capa 2	Capa 3	Capa 4	Capa 5	Capa 6	Capa 7	Surf. Int.	Interior		
Temp. (°C)	1.00	1.12	1.34	16.63	18.13	18.20	18.95	19.20	19.45	19.99	20.00		

Step 4: Vapor Pressure Distribution Calculation

The vapor pressure at each interface is calculated proportionally to the vapor resistance (S_d).

Formula (Conceptual): $P_x = P_e + ((\sum S_d) / S_{d_Total}) * (P_i - P_e)$

Where:

- P_x = Vapor pressure at a specific point [Pa]
- $\sum S_d$ = Sum of S_d values from the exterior up to that point [m]
- $S_{d \text{ Total}}$ = Total vapor resistance of the wall (5.77 m)

Step 5: Compliance Check - The Graphical Method

The final and most critical step is to compare the **Saturation Vapor Pressure (P_{sat})** and the **Actual Vapor Pressure (P)** at every point in the wall.

- **Saturation Pressure Line:** Calculated from the temperature distribution (Step 3) using the Magnus formula. This line represents the *maximum* amount of vapor the air can hold at each temperature.
- **Vapor Pressure Line:** Calculated from the vapor diffusion (Step 4). This line represents the *actual* amount of vapor present.

Compliance Criterion: > “If any of the vapor pressure values reaches or exceeds the saturation vapor pressure at that point, condensation will occur.”

Result for the Example Wall: The document presents a graph showing that the two lines (**P_{sat}** and **P**) **do not intersect** at any point through the wall's cross-section.

Conclusion: “For the established exterior (January) and interior conditions, **no interstitial condensation** occurs in any of the layers that form the analyzed enclosure.”

Summary

The document demonstrates a complete, code-compliant check for interstitial condensation:

1. **Defines** the wall's thermal and hygric properties.
2. **Establishes** the worst-case realistic interior and exterior environmental conditions.
3. **Calculates** the temperature and vapor pressure profile through the wall.
4. **Verifies** that the vapor pressure remains below the saturation pressure everywhere, thus proving no risk of harmful interstitial condensation for the analyzed assembly.

Air Permeability of Openings (Permeabilidad al aire de los huecos)

The document addresses air tightness in two key areas: the individual components (windows/doors) and the entire building envelope.

This regulates the maximum allowed air leakage through windows, doors, and skylights under a standardized pressure test.

Standard: UNE-EN 12207:2017 **Test Condition:** Air permeability measured at a pressure differential of **100 Pa**, denoted as **Q₁₀₀**. **Unit:** m³/(h·m²) - (cubic meters per hour, per square meter of opening)

Compliance Table

The following table is used to verify that the proposed window and door classes meet the regulatory limits for the winter climate zone "E".

Component Type	Orientation / Location	Permeability Class	Q ₁₀₀ Value (m ³ /h·m ²)	Limit (Q _{100,lim}) (m ³ /h·m ²)	Compliance
Windows	North & East Facades	Class 3	9	≤ 9	COMPLIES
Windows	South & West Facades	Class 3	9	≤ 9	COMPLIES
Access Door	West Facade	(Wood, no class given)	(Not specified)	≤ 9*	COMPLIES *
Skylights (Lucernarios)	Roof	Class 3	9	≤ 9	COMPLIES

*The door's specific permeability is not given, but it is stated to comply.

Key Requirement: For climate zone E, the permeability of all openings in the thermal envelope must not exceed **9 m³/(h·m²)**. All proposed components with a Class 3 rating meet this requirement.

Building Envelope Air Tightness (Relación del cambio de aire n₅₀)

This is a whole-building test that measures the air tightness of the entire thermal envelope, including leaks through walls, junctions, and installation gaps, not just the windows.

Standard: UNE-EN 13829:2002 (Fan Pressurization Test / Blower Door Test) **Test Condition:** Air changes per hour measured at a pressure differential of **50 Pa**, denoted as **n₅₀**. **Unit:** h⁻¹ (air changes per hour)

Regulatory Limit

The permissible n₅₀ value depends on the building's compactness (V/A).

Table 3.1.3.b-HE1

Compactness (V/A) [m ³ /m ²]	n ₅₀ Limit [h ⁻¹]
V/A ≤ 2.0	6.00

Compactness (V/A) [m ³ /m ²]	n ₅₀ Limit [h ⁻¹]
V/A ≥ 4.0	3.00

For intermediate compactness values ($2 < V/A < 4$), the limit is obtained by linear interpolation.

Applicability: This requirement is only mandatory for new residential buildings with a **useful floor area greater than 120 m²**.

Calculation of Permeability (n₅₀)

The document provides a method for calculating the n₅₀ value without performing a test, using reference values.

Formula: $n_{50} = 0.629 \times (C_o \times A_o + C_h \times A_h) / V$

Where:

- **n₅₀:** The calculated air change rate at 50 Pa [h⁻¹].
- **0.629:** Conversion factor between permeability at 100 Pa (Q₁₀₀) and 50 Pa (n₅₀).
- **C_o:** Airflow coefficient for the **opaque** part of the envelope at 100 Pa. For new buildings, this is **16 m³/(h·m²)**.
- **A_o:** Area of the **opaque** part of the thermal envelope [m²].
- **C_h:** Airflow coefficient for the **openings** (windows, doors) at 100 Pa. This is equal to their Q₁₀₀ value. For Class 3 components, this is **9 m³/(h·m²)**.
- **A_h:** Total area of the **openings** (windows, doors) in the thermal envelope [m²].
- **V:** Internal air volume enclosed by the thermal envelope (Volumen de "aire interior") [m³].

Application and Compliance in the Document

The document states that due to the small size of the building, the n₅₀ requirement only applies to **Option 3**, which has a useful area of 128 m² (>120 m²).

- **For Options 1 & 2:** The useful area is less than 120 m², so justifying the n₅₀ value is **not mandatory**.
- **Compliance Strategy for Option 3:** The document mentions that achieving compliance for small, detached buildings can be challenging. For Option 3, compliance is achieved by specifying even tighter **Class 4 windows** ($Q_{100} \leq 3 \text{ m}^3/(\text{h} \cdot \text{m}^2)$) to compensate for the less favorable compactness.

"...this requirement only applies in option 3 (> 120 m² useful) and compliance is achieved by improving the tightness of the openings by incorporating Class 4 carpentry, which guarantees less than 3 m³/h·m²."

Summary of Air Tightness Data:

Aspect	Requirement / Value	Notes
Openings (Q₁₀₀)	Limit: ≤ 9 m³/(h·m²)	For climate zone E.
Openings Class	Class 3	Standard proposed for most options.
Openings for Compliance	Class 4	Proposed for Option 3 to meet n ₅₀ .
Building (n₅₀)	Limit: Function of Compactness	See table above.
n₅₀ Applicability	Only for > 120 m² useful area	Only mandatory for Option 3.
Calculation Method	$n_{50} = 0.629 \times (16 \cdot A_o + 9 \cdot A_h) / V$	For a standard case with Class 3 windows.
Opaque Coefficient (C_o)	16 m³/(h·m²)	For new buildings.

In conclusion, the document demonstrates a two-tiered approach to air tightness: ensuring all individual components meet a minimum standard (Class 3), and for larger buildings, using higher-performance components (Class 4) to ensure the whole-building envelope meets the more stringent n_{50} requirement.