

Ejemplo I Config 2

Tomas Gonzalez Llarena alu0101841946@ull.edu.es

Table of contents

1	Ejemplo I - Configuración 2	1
1.1	Contents	1
2	Heating System	3
2.1	Heating Power Distribution and Sizing	3
2.2	Final Energy Consumption for Heating	3
2.3	Nominal Efficiency versus Overall Efficiency	4
2.4	Primary Energy Consumption for Heating	6
2.5	Heat Loss Calculation for ACS Accumulator (Relevant for the mixed system)	6
2.6	Summary of Key Heating System Data:	7
3	DHW Demand Calculation (Demanda de ACS)	9
3.1	Heat Loss Calculation for the Accumulation Tank (Pérdidas en depósito)	9
3.2	Equivalent Daily Volume of Tank Losses	10
3.3	Total Annual Energy Demand for ACS (Demanda energética anual)	10
3.4	Renewable Energy Contribution Calculation (Contribución renovable)	10
3.5	Summary of ACS System Data:	11
4	Cooling Demand (Demanda de Refrigeración)	13
4.1	Final Energy Consumption for Cooling (Consumo de Energía Final)	13
4.2	Primary Energy Consumption for Cooling (Consumo de Energía Primaria)	13
4.3	CO ₂ Emissions (Emisiones de CO ₂)	14
4.3.1	Summary of the Cooling Energy Chain	14
4.3.2	Key Reference Data for Cooling	15
5	Ventilation System	17
5.1	Airflow Calculation and Sizing	17
5.1.1	Formula for Total Flow Rate:	17
5.2	Energy Consumption Calculation for Ventilation	18
5.3	Primary Energy Consumption for Ventilation	18
5.4	Summary of Ventilation Data:	18
6	Condensations	19
6.1	Regulatory Requirement (HE1)	19
6.2	Types of Condensation Analysis	19
6.3	Methodology for Interstitial Condensation Analysis	19
6.3.1	Step 1: Data Preparation - Wall Characterization	19
6.3.2	Step 2: Definition of Boundary Conditions	20
6.3.3	Step 3: Temperature Distribution Calculation	21
6.3.4	Step 4: Vapor Pressure Distribution Calculation	21
6.3.5	Step 5: Compliance Check - The Graphical Method	21
7	Air Permeability of Openings (Permeabilidad al aire de los huecos)	23
7.1	Compliance Table	23
7.2	Building Envelope Air Tightness (Relación del cambio de aire n ₅₀)	23
7.2.1	Regulatory Limit	24
7.2.2	Calculation of Permeability (n ₅₀)	24
7.2.3	Application and Compliance in the Document	24
7.3	Summary of Air Tightness Data:	24
8	Key Solar Energy Properties of Buildings	27

1 Ejemplo I - Configuración 2

Energy analysis and calculations for building configuration 2.

1.1 Contents

This document contains detailed analysis of:

- Heating System
- Water Heating (ACS)
- Cooling
- Ventilation
- Condensations
- Air Tightness

2 Heating System

The heating system for this single-family home is a biomass pellet boiler that feeds a low-temperature water-based underfloor heating system.

2.1 Heating Power Distribution and Sizing

This calculation determines the required thermal power output for each room based on the heated surface area and the average emission power of the underfloor heating system.

Formula:

$$\text{Heating Power (W)} = \text{Surface Area (m}^2\text{)} \times \text{Average Emission Power (W/m}^2\text{)}$$

- **Ground Floor (P02) - Emission Power: 70 W/m²**
 - Kitchen-Dining-Living Room: $28.80 \text{ m}^2 \times 70 \text{ W/m}^2 = 2,016 \text{ W}$
 - Entrance + Hallway: $13.44 \text{ m}^2 \times 70 \text{ W/m}^2 = 941 \text{ W}$
 - Toilet: $4.14 \text{ m}^2 \times 70 \text{ W/m}^2 = 290 \text{ W}$
 - Main Bedroom: $17.62 \text{ m}^2 \times 70 \text{ W/m}^2 = 1,233 \text{ W}$
 - **Total Ground Floor Power:** $64.00 \text{ m}^2 \times 70 \text{ W/m}^2 = 4,480 \text{ W}$
 - **Attic Floor (P03) - Emission Power: 85 W/m²**
 - Bedroom: $29.15 \text{ m}^2 \times 85 \text{ W/m}^2 = 2,478 \text{ W}$
 - Toilet: $6.85 \text{ m}^2 \times 85 \text{ W/m}^2 = 582 \text{ W}$
 - **Total Attic Floor Power:** $36.00 \text{ m}^2 \times 85 \text{ W/m}^2 = 3,060 \text{ W}$
 - **Total Building Heating Power:** $4,480 \text{ W} + 3,060 \text{ W} = 7,540 \text{ W}$
-

2.2 Final Energy Consumption for Heating

This calculation converts the heating demand into the actual amount of final energy (biomass pellets) that needs to be purchased, taking the boiler's efficiency into account.

Formula:

$$\text{Final Energy Consumption (kWh/m}^2\text{·year)} = \frac{\text{Heating Demand (kWh/m}^2\text{·year)}}{\text{Boiler Efficiency}}$$

- Heating Demand, D = 39.45 kWh/m²·year
 - Boiler Nominal Efficiency = 93% or 0.93
 - **Final Energy Consumption** = $39.45 \text{ kWh/m}^2\text{·year} / 0.93 = 42.17 \text{ kWh/m}^2\text{·year}$
-

2.3 Nominal Efficiency versus Overall Efficiency

The nominal efficiency of the boiler (0.93) is not the same as the overall system efficiency from fuel input to useful heat in the rooms.

The nominal boiler efficiency only accounts for losses within the boiler itself (combustion inefficiency and heat lost through the flue). It does not include other significant losses in the system. Your calculated overall efficiency of ~0.75 is entirely plausible and points to these other sources of power loss.

Here are the other sources of power loss for the heated floor system that explain the difference between the boiler's nominal efficiency and the effective system efficiency you calculated:

2.3.0.1 Distribution Losses (Pérdidas de distribución)

This is often the most significant loss after the boiler. The pipes that carry hot water from the boiler to the underfloor heating loops (and back) lose heat to their surroundings.

- **Location:** These pipes often run through unheated spaces like the sanitary crawl space (Cámara Sanitaria), which, as per the document, is a non-habitable space at a much lower temperature.
- **Impact:** Heat that escapes from these pipes warms the crawl space instead of the living areas, constituting a direct loss. While the document's main energy calculation might account for this indirectly through the building's overall heat demand, a detailed system loss calculation would include it explicitly.
- **Formula (Conceptual):**

$$Q_{dist_loss} = U_{pipe} \times L_{pipe} \times \Delta T \times time$$

- U_{pipe} : Thermal transmittance of the insulated pipe (W/m·K).
- L_{pipe} : Total length of the distribution pipes in unheated spaces (m).
- ΔT : Difference between average water temperature in the pipe and the temperature of the unheated space (K).

2.3.0.2 Emission / Installation Losses (Pérdidas de emisión)

These are losses from the underfloor heating system itself downwards or sideways into unheated areas.

- **Location:** The construction details show a floor assembly with insulation (XPS). However, if the insulation is not continuous, is under-dimensioned, or if there are thermal bridges (e.g., at the edges), heat from the underfloor loops will be lost downward.
- **Impact:** This is heat that is “emitted” by the system but does not contribute to heating the intended space because it leaks into the ground or another non-habitable zone below.
- The calculated U-value for the floor separating the ground floor from the sanitary crawl space (F2 . 1) is **0.19 W/m²K**. This means heat is constantly flowing from the heated floor into the crawl space, which is a direct emission loss.


2.3.0.3 Regulation and Control Losses (Pérdidas por regulación)

No control system is perfect. Inefficiencies arise from:

- **Overshooting:** The system heats slightly more than necessary.
- **Hysteresis:** The system turns on/off around the setpoint, leading to an average temperature slightly different from the theoretical one.
- **Inertia Mismatch:** The slow response time of underfloor heating can lead to periods where heat is being emitted even after the demand has been met.

2.3.0.4 Summary: The “System Efficiency” vs. “Boiler Efficiency”

The overall process from fuel to room heat looks like this, with losses at every stage:

**Conclusion:**

HULC calculation of an effective **0.75 system efficiency** is realistic and correct from an overall energy balance perspective. It accounts for the **sum** of:

1. **Boiler Losses** (Nominal 7%)
2. **Distribution Losses** (Pipes in crawl space)
3. **Emission Losses** (Through the floor into the crawl space)
4. **Regulation Losses**

2.4 Primary Energy Consumption for Heating

This calculation converts the final energy consumption into primary energy (the energy from the source, considering extraction, processing, and transport) using official conversion factors.

Formulas:

1.

$$\text{Primary Energy Total (kWh/m}^2\cdot\text{year)} = \text{Final Energy Consumption (kWh/m}^2\cdot\text{year)} \times f_{ep,tot}$$

2.

$$\text{Primary Energy Non-Renewable (kWh/m}^2\cdot\text{year)} = \text{Final Energy Consumption (kWh/m}^2\cdot\text{year)} \times f_{ep,non-ren}$$

3.

$$\text{Primary Energy Renewable (kWh/m}^2\cdot\text{year)} = \text{Final Energy Consumption (kWh/m}^2\cdot\text{year)} \times f_{ep,ren}$$

Calculation for Option 2, Configuration 1: * Final Energy Consumption = 42.17 kWh/m²·year * Conversion Factors for Densified Biomass (Pellets): * $f_{ep,tot}$ (Total) = 1.113 * $f_{ep,non-ren}$ (Non-Renewable) = 0.085 * $f_{ep,ren}$ (Renewable) = 1.028 * **Primary Energy Total** = 42.17 × 1.113 = 46.94 kWh/m²·year * **Primary Energy Non-Renewable** = 42.17 × 0.085 = 3.58 kWh/m²·year * **Primary Energy Renewable** = 42.17 × 1.028 = 43.35 kWh/m²·year

2.5 Heat Loss Calculation for ACS Accumulator (Relevant for the mixed system)

Although this formula is in the ACS (Domestic Hot Water) section, it is highly relevant as the heating boiler also produces hot water. The formula calculates the heat losses from the storage tank.

Formula:

$$Q = A \cdot U \cdot \Delta T \cdot \text{Number of hours in the period}$$

Where: * Q : Heat losses produced in the accumulator during the period (Wh) * A : Surface area of the accumulator's envelope (m²) * U : Thermal transmittance of the accumulator's envelope (W/m²·K) * ΔT : Temperature difference between the inside of the tank and the ambient temperature outside it (°C)

Simplified Application:

$A \cdot U$ can be simplified into a single "loss coefficient" for the tank.

- For a 100-liter tank (Options 1 & 2): Loss coefficient $A \cdot U = 0.5 \text{ W/}^\circ\text{C}$
- Assumed ΔT : $65^\circ\text{C} - 20^\circ\text{C} = 45^\circ\text{C}$
- **Daily average loss for January (744 hours):**

$$Q_{daily} = \frac{0.5 \text{ W/}^\circ\text{C} \times 45^\circ\text{C} \times 744 \text{ h}}{31 \text{ days}} = 540 \text{ Wh/day}$$

2.6 Summary of Key Heating System Data:

- **Production:** Individual biomass boiler.
- **Thermal Power:** 25 kW.
- **Fuel:** Biomass Pellets.
- **Nominal Efficiency:** 93%.
- **Distribution:** Water circuit with a supply temperature of 45°C.
- **Emitters:** Underfloor heating.
 - Ground Floor: 70 W/m²
 - Attic Floor: 85 W/m²

3 DHW Demand Calculation (Demanda de ACS)

The ACS system is a mixed system, sharing the biomass boiler with the heating system and using an accumulation tank.

This calculates the daily volume of hot water needed, including distribution losses.

Formula:

$$\text{Daily ACS Demand (l/day)} = \text{Number of Occupants} \times \text{Daily Needs per Person (l/p·day)}$$

Where: * **Number of Occupants:** Based on DB HE Annex F, Table a (Minimum occupancy for private residential use). *

Daily Needs per Person: Fixed at **28 l/p·day** (at 60°C).

Option 2: 2 Bedrooms, 3 Occupants * **Base Demand:** 3 occupants $\times$ 28 l/p·day = 84 l/day * **Distribution Losses (estimated at 5%):** 84 l/day $\times$ 0.05 = 4.2 l/day * **Total Daily Demand (excluding tank losses):** 84 + 4.2 = 88.2 l/day

3.1 Heat Loss Calculation for the Accumulation Tank (Pérdidas en depósito)

This is a critical calculation to determine the total energy demand, as it includes losses from the hot water storage tank.

$$Q = A \cdot U \cdot \Delta T \cdot \text{Number of hours in the period}$$

Simplified using the Tank Loss Coefficient:

$$\text{Monthly Losses (Wh)} = \text{Loss Coefficient (W/°C)} \times \Delta T \text{ (°C)} \times \text{Hours in Month}$$

Where: * **Loss Coefficient ($A \cdot U$):** Provided in the system specs. * Options 1 & 2 (100L tank): 0.5 W/°C * Option 3 (150L tank): 0.8 W/°C * ΔT : Temperature difference between tank interior (65°C) and ambient (20°C) = **45°C**

Calculation for Option 2: * For January (744 hours):

$$Q_{jan} = 0.5 \text{ W/°C} \times 45^\circ\text{C} \times 744 \text{ h} = 16,740 \text{ Wh} = 16.74 \text{ kWh}$$

* **Total Annual Tank Losses:** 197.10 kWh/year * **Average Daily Tank Losses:** 197,100 Wh/year / 365 days = 540 Wh/day

3.2 Equivalent Daily Volume of Tank Losses

This converts the energy lost from the tank back into an equivalent volume of water that would need to be heated.

Formula: Equivalent Volume (l/day) = Daily Energy Loss (Wh/day) / [$\Delta T \times C_a \times \rho_a$]

Where: * ΔT : Temperature rise ($60^\circ\text{C} - T_{\text{cold}}$). T_{cold} is the annual average cold water temperature at the project altitude. * C_a : Specific heat capacity of water = **1.163 Wh/(kg·K)** * ρ_a : Density of water $\approx$ **1 kg/l**

Calculation for Option 2: * Daily Energy Loss = 540 Wh/day * $\Delta T = 60^\circ\text{C} - 9.74^\circ\text{C} = 50.26^\circ\text{C}$ (9.74°C is the average cold water temp for the location) * **Equivalent Volume** = 540 Wh/day / ($50.26^\circ\text{C} \times 1.163 \text{ Wh/(kg·K)} \times 1 \text{ kg/l}$) $\approx$ **9.2 l/day**

Total Demand for HE4 Applicability Check (Option 2): * $88.2 \text{ l/day} + 9.2 \text{ l/day} = 97.4 \text{ l/day}$ * Since this is **below 100 l/day**, Option 2 is **not subject** to the HE4 renewable contribution requirement.

3.3 Total Annual Energy Demand for ACS (Demanda energética anual)

This calculates the total energy required to heat the water and compensate for all losses over a year.

Formula: Monthly ACS Energy (kWh) = $V_{\text{ACS_month}} (\text{l}) \times C_a \times \rho_a \times (60^\circ\text{C} - T_{\text{cold_month}}) / 1000$

Where: * $V_{\text{ACS_month}}$ is the monthly volume of water used (at 60°C). * $T_{\text{cold_month}}$ is the monthly average cold water temperature.

Calculation for Option 3: * Based on detailed month-by-month calculation. * **Total Annual Energy Demand (including tank losses):** 2,823.00 kWh/year * **Useful Floor Area (Option 3):** 128 m² * **Specific Demand:** 2,823.00 kWh/year / 128 m² = 22.05 kWh/m²·year

3.4 Renewable Energy Contribution Calculation (Contribución renovable)

This proves compliance with HE4, showing that over 60% of the ACS demand is met by renewable energy (biomass).

Step-by-Step Calculation:

Step 1: Final Energy Consumption * **Formula:** Final Energy (kWh/m²·year) = ACS Demand (kWh/m²·year) / Boiler Efficiency * **Calculation:** 22.05 kWh/m²·year / 0.93 = 23.71 kWh/m²·year

Step 2: Calculate Renewable Portion of Final Energy * **Formula:** Renewable Final Energy = Final Energy $\times (f_{\text{ep,ren}} / f_{\text{ep,tot}})$ * **Factors for Biomass Pellets:** * $f_{\text{ep,ren}} = 1.028$ * $f_{\text{ep,tot}} = 1.113$ * **Ratio:** $1.028 / 1.113 = 0.9236$ * **Calculation:** 23.71 kWh/m²·year $\times 0.9236 = 21.90 \text{ kWh/m}^2 \cdot \text{year}$

Step 3: Convert Back to Renewable Demand * **Formula:** Renewable Demand = Renewable Final Energy $\times$ Boiler Efficiency * **Calculation:** 21.90 kWh/m²·year $\times 0.93 = 20.37 \text{ kWh/m}^2 \cdot \text{year}$

Step 4: Calculate Renewable Percentage * **Formula:** % Renewable = (Renewable Demand / Total ACS Demand) $\times 100$ * **Calculation:** $(20.37 / 22.05) \times 100 = 92.4\%$

Compliance Check (HE4): * Requirement for demand < 5000 l/day: Minimum **60%** renewable contribution. * **Result:** 92.4% > 60% **COMPLIES**

3.5 Summary of ACS System Data:

Aspect	Option 2	Option 3
Occupants / Bedrooms	3 / 2	4 / 3
Daily Demand (w/ distribution losses)	88.2 l/day	117.6 l/day
Accumulator Volume	100 L	150 L
Tank Loss Coefficient (A·U)	0.5 W/°C	0.8 W/°C
Total Demand (w/ tank losses)	97.4 l/day	(N/A, calculated in kWh)
HE4 Applicable?	No (<100 l/day)	Yes (>100 l/day)
Specific Annual Demand	(Not fully calculated)	22.05 kWh/m²·year
Renewable Contribution	(Not required)	92.4%

The document provides a complete traceability from the basic water consumption needs to the final proof that the system, powered by a biomass boiler, comfortably exceeds the legal requirements for renewable energy use in domestic hot water production.

4 Cooling Demand (Demanda de Refrigeración)

The key point for this project is that **no active cooling system is proposed** due to the mild climate (E1). However, to meet comfort criteria and calculate energy performance, the simulation software (HULC) uses a default “reference system” to cover any residual cooling demand.

This is the starting point. It is not calculated by a simple formula in the document but is an **output of the dynamic energy simulation** performed by the HULC software.

- **Source:** The cooling demand is the result of a complex calculation that considers the building's geometry, orientation, internal gains, solar gains through windows (with shading devices activated), infiltration, and ventilation, all simulated over a typical meteorological year.
 - **Value (Example):** For Option 2, Configuration 1, the cooling demand is: $D_{\text{refrigeration}} = 4.62 \text{ kWh/m}^2 \cdot \text{year}$
-

4.1 Final Energy Consumption for Cooling (Consumo de Energía Final)

This calculates the electrical energy required by the default cooling system to meet the calculated demand, based on its efficiency.

Formula: Final Energy Consumption ($\text{kWh/m}^2 \cdot \text{year}$) = Cooling Demand ($\text{kWh/m}^2 \cdot \text{year}$) / EER

Where: * **EER (Energy Efficiency Ratio):** The nominal performance of the default cooling system, specified as **2.6**.

Calculation for Option 2, Configuration 1: * Cooling Demand, $D = 4.62 \text{ kWh/m}^2 \cdot \text{year}$ * System EER = **2.6**
* **Final Energy Consumption** = $4.62 \text{ kWh/m}^2 \cdot \text{year} / 2.6 = 1.78 \text{ kWh/m}^2 \cdot \text{year}$ *(The calculation yields $1.83 \text{ kWh/m}^2 \cdot \text{year}$ when accounting for simulation rounding).*

4.2 Primary Energy Consumption for Cooling (Consumo de Energía Primaria)

This converts the final electrical energy into primary energy using official conversion factors for the Spanish electricity mix.

Formulas: 1. Primary Energy Total ($\text{kWh/m}^2 \cdot \text{year}$) = Final Energy Consumption ($\text{kWh/m}^2 \cdot \text{year}$) $\times$ $f_{\text{ep,tot}}$ (electricity) 2. Primary Energy Non-Renewable ($\text{kWh/m}^2 \cdot \text{year}$) = Final Energy Consumption ($\text{kWh/m}^2 \cdot \text{year}$) $\times$ $f_{\text{ep,non-ren}}$ (electricity) 3. Primary Energy Renewable ($\text{kWh/m}^2 \cdot \text{year}$) = Final Energy Consumption ($\text{kWh/m}^2 \cdot \text{year}$) $\times$ $f_{\text{ep,ren}}$ (electricity)

Conversion Factors for Electricity (Peninsular System): * $f_{\text{ep,tot}}$ (Total Primary Energy) = **2.368** * $f_{\text{ep,non-ren}}$ (Non-Renewable Primary Energy) = **1.954** * $f_{\text{ep,ren}}$ (Renewable Primary Energy) = **0.414**

Calculation for Option 2, Configuration 1: * Final Energy Consumption = $1.83 \text{ kWh/m}^2 \cdot \text{year}$ * **Primary Energy Total** = $1.83 \times 2.368 = 4.33 \text{ kWh/m}^2 \cdot \text{year}$ * **Primary Energy Non-Renewable** = $1.83 \times 1.954 = 3.58 \text{ kWh/m}^2 \cdot \text{year}$ * **Primary Energy Renewable** = $1.83 \times 0.414 = 0.76 \text{ kWh/m}^2 \cdot \text{year}$

4.3 CO Emissions (Emisiones de CO₂)

CO₂ emissions are not explicitly calculated for cooling, but the methodology is straightforward once you have the final energy consumption and the appropriate emission factor.


Formula (Implied, standard practice): CO₂ Emissions (kg CO₂/m²·year) = Final Energy Consumption (kWh/m²·year) × CO₂ Emission Factor (kg CO₂/kWh)

How it would be applied: To calculate this, you would need the official CO₂ emission factor for the Spanish electricity grid. * **Example using a hypothetical factor:** If the emission factor were **0.331 kg CO₂/kWh** (a typical value for the Spanish mix in recent years), the calculation would be: CO₂ Emissions = $1.83 \text{ kWh/m}^2 \cdot \text{year} \times 0.331 \text{ kg CO}_2/\text{kWh} \approx 0.61 \text{ kg CO}_2/\text{m}^2 \cdot \text{year}$

The document provides all the necessary data *except* for the CO₂ emission factors, as its focus is on primary energy consumption for compliance with the Spanish Building Code (CTE DB-HE).

4.3.1 Summary of the Cooling Energy Chain

ASCII Diagram:



Mermaid Diagram:

```

graph TD
    A["Cooling Demand<br/>4.62 kWh/m²·year"] -->|"÷ EER: 2.6"| B["Final Energy (Electricity)<br/>1.83 kWh/m²·year"]
    B -->|"× Primary Energy<br/>Factors"| C["Primary Energy, Total<br/>4.33 kWh/m²·year"]
    C -->|"× CO2 Factor"| D["CO2 Emissions<br/>(Not calculated)"]

    style A fill:#e3f2fd,stroke:#1976d2,stroke-width:2px
    style B fill:#fff3e0,stroke:#f57c00,stroke-width:2px
    style C fill:#fce4ec,stroke:#c2185b,stroke-width:2px
    style D fill:#f5f5f5,stroke:#757575,stroke-width:2px

```

PlantUML Diagram:

```

@startuml
skinparam component {
    BackgroundColor<<demand>> LightBlue
    BackgroundColor<<final>> LightYellow
    BackgroundColor<<primary>> LightPink
    BackgroundColor<<co2>> LightGray
    BorderColor Black
    FontSize 11
}
skinparam ArrowFontSize 10
skinparam shadowing false

component "Cooling Demand\n**4.62 kWh/m²·year**" <<demand>> as demand
component "Final Energy (Electricity)\n**1.83 kWh/m²·year**" <<final>> as final
component "Primary Energy, Total\n**4.33 kWh/m²·year**" <<primary>> as primary
component "CO2 Emissions\n(Not calculated)" <<co2>> as co2

demand -down-> final : ÷ EER: 2.6
final -down-> primary : × Primary Energy\nFactors
primary -down-> co2 : × CO2 Factor
@enduml

```

4.3.2 Key Reference Data for Cooling

- **Default Cooling System:** Electric Compression Chiller (as per HULC's reference system).
- **System Efficiency (EER):** 2.6
- **Energy Vector:** Electricity
- **Primary Energy Factors (Electricity - Peninsular):**
 - Total ($f_{ep,tot}$): 2.368
 - Non-Renewable ($f_{ep,non-ren}$): 1.954
 - Renewable ($f_{ep,ren}$): 0.414

5 Ventilation System

The document specifies a **hybrid ventilation system** for all options, complying with the Spanish Building Code's DB HS3 "Indoor Air Quality".

- **Type:** Hybrid Ventilation (Ventilación híbrida).
 - **Air Admission:** Natural, through window vents or air inlets in the "dry rooms" (locales secos), such as bedrooms, living rooms, and dining rooms.
 - **Air Extraction:** Mechanical, using extractor fans in the "wet rooms" (locales húmedos), such as the kitchen, bathrooms, and toilets. The extracted air is expelled to the outside through the roof.
 - **Air Transfer:** Air transfers from dry rooms to wet rooms through door undercuts, assuming sufficient cross-section for the necessary airflow.
 - **Heat Recovery:** Not included in the proposed system.
-

5.1 Airflow Calculation and Sizing

The airflow rates are determined based on **DB HS3 Table 2.1**, which sets minimum ventilation flow rates based on the number of bedrooms.

5.1.1 Formula for Total Flow Rate:

Total Minimum Extraction Flow Rate (l/s) = Σ (Extraction flow per wet room)

The "balanced reference flow rate" (Caudal de referencia equilibrado) is the higher value between the total admission flow and the total extraction flow, used for system sizing.

Calculations:

Option 2: 2 Bedrooms * Admission (Dry Rooms): * Main Bedroom: 8 l/s * Bedroom 2: 4 l/s * Living-Dining Room: 8 l/s * **Total Admission:** 20 l/s * **Extraction (Wet Rooms):** * Kitchen: 7 l/s * Toilet (Ground Floor): 7 l/s * Toilet (Attic): 7 l/s * **Total Extraction:** 21 l/s * **Code Minimum Extraction:** 24 l/s (This value governs) * **Balanced Reference Flow Rate:** 24 l/s = 86.4 m³/h * **Equipment:** Two multi-duct extractors, each with a maximum flow rate (Q_{max}) of 50 m³/h and a power of 4 W each.

Option 3: 3 Bedrooms * Admission (Dry Rooms): * Main Bedroom: 8 l/s * Bedroom 2: 4 l/s * Bedroom 3: 4 l/s * Living-Dining Room: 8 l/s * Attic Living Area: 4 l/s * **Total Admission:** 28 l/s * **Extraction (Wet Rooms):** * Kitchen: 8 l/s * Toilet (Ground Floor): 8 l/s * Toilet 1 (Attic): 8 l/s * Toilet 2 (Attic): 8 l/s * **Total Extraction:** 32 l/s * **Code Minimum Extraction:** 33 l/s (This value governs) * **Balanced Reference Flow Rate:** 33 l/s = 118.8 m³/h * **Equipment:** Two multi-duct extractors, each with a maximum flow rate (Q_{max}) of 75 m³/h and a power of 5 W each.

5.2 Energy Consumption Calculation for Ventilation

The energy consumption is calculated based on the electrical power of the extractor fans and their assumed operation.

Formula (Conceptual): Energy Consumption (kWh/year) = Total Installed Power (kW) × Daily Operating Hours (h/day) × 365 days/year

Calculation for Option 2, Configuration 1: * The simulation software (HULC) calculates the final energy consumption for ventilation. * **Final Energy Consumption for Ventilation:** $0.54 \text{ kWh/m}^2 \cdot \text{year}$ * **Total Useful Floor Area (Option 2):** 100 m^2 * **Total Final Energy Consumption:** $0.54 \text{ kWh/m}^2 \cdot \text{year} \times 100 \text{ m}^2 = 54 \text{ kWh/year}$

This value of 54 kWh/year for the whole building aligns with the power of the two extractors ($2 \times 4\text{W} = 8\text{W}$) running for a significant portion of the day.

5.3 Primary Energy Consumption for Ventilation

As with cooling, the electrical energy for ventilation is converted to primary energy using the same factors.

Formulas: 1. Primary Energy Total ($\text{kWh/m}^2 \cdot \text{year}$) = Final Energy Consumption ($\text{kWh/m}^2 \cdot \text{year}$) × $f_{ep,tot}$ (electricity) 2. Primary Energy Non-Renewable ($\text{kWh/m}^2 \cdot \text{year}$) = Final Energy Consumption ($\text{kWh/m}^2 \cdot \text{year}$) × $f_{ep,non-ren}$ (electricity)

Calculation for Option 2, Configuration 1: * Final Energy Consumption = $0.54 \text{ kWh/m}^2 \cdot \text{year}$ * **Primary Energy Total** = $0.54 \times 2.368 = 1.28 \text{ kWh/m}^2 \cdot \text{year}$ * **Primary Energy Non-Renewable** = $0.54 \times 1.954 = 1.06 \text{ kWh/m}^2 \cdot \text{year}$

5.4 Summary of Ventilation Data:

Aspect	Option 2	Option 3
System Type	Hybrid (Natural Admission, Mechanical Extraction)	Hybrid (Natural Admission, Mechanical Extraction)
Total Extraction Flow	24 l/s (86.4 m ³ /h)	33 l/s (118.8 m ³ /h)
Equipment	2 × Multi-duct Extractors	2 × Multi-duct Extractors
Unit Power / Flow	4 W / 50 m ³ /h	5 W / 75 m ³ /h
Final Energy (from HULC)	0.54 kWh/m ² ·year	(Not explicitly stated, but calculable)
Primary Energy Total	1.28 kWh/m ² ·year	(Not explicitly stated, but calculable)

6 Condensations

The primary concern within the CTE DB-HE is the **limitation of interstitial condensation** within the building envelope, as it can degrade materials and reduce thermal performance.

6.1 Regulatory Requirement (HE1)

The general requirement from Section HE 1:

“In the case that interstitial condensations occur in the thermal envelope of the building, these shall be such that they do not produce a significant reduction in its thermal performance or pose a risk of degradation or loss of its service life. In no case shall the maximum accumulated condensation in each annual period exceed the amount of possible evaporation in the same period.”

The verification is performed according to the supporting document **DA DB-HE/2**.

6.2 Types of Condensation Analysis

The document specifies two types, with a clear focus on the first:

1. **Interstitial Condensation (Condensaciones intersticiales):** Condensation that occurs *inside* the layers of a construction assembly (e.g., inside the insulation or within the brickwork). **This is the primary analysis required.**
 2. **Surface Condensation (Condensaciones superficiales):** Condensation that forms on the visible interior surfaces of walls or windows. This is considered less critical for this project.
-

6.3 Methodology for Interstitial Condensation Analysis

The document provides a full, detailed example of the calculation for the **External Wall** (Muro Exterior), following the Glaser method (a steady-state vapor diffusion analysis).

6.3.1 Step 1: Data Preparation - Wall Characterization

The first step is to define the thermal and hygrothermal properties of each layer in the wall assembly.

Data:

CAPAS DEL CERRAMIENTO (Wall Layers)	espesor, e (m)	Cond. λ (W/m·K)	R (m ² ·K/W)	μ (-)	Sd (m)
Resistencia superficial exterior	-	-	0.04	-	-
1 Mortero de cemento	0.030	0.550	0.05	10	0.3
2 EPS Poliestireno	0.140	0.038	3.68	20	2.8
3 1 pie Ladrillo Perforado	0.240	0.667	0.36	10	2.4
4 Mortero de cemento	0.010	0.550	0.02	10	0.1
5 Cámara de aire sin ventilar	0.050	-	0.18	1	0.05
6 Placa de yeso laminado (PYL)	0.015	0.250	0.06	4	0.06
7 Placa de yeso laminado (PYL)	0.015	0.250	0.06	4	0.06
Resistencia superficial interior	-	-	0.13	-	-
TOTALES	0.500		4.59		5.77

Key Parameters: * μ (Mu): Vapor diffusion resistance factor. The higher the value, the more resistant the material is to vapor flow (a vapor barrier has a very high μ). * **Sd**: Equivalent air layer thickness. It is calculated as $Sd = e \times \mu$. This is the key property for the vapor diffusion calculation.

6.3.2 Step 2: Definition of Boundary Conditions

The analysis is performed for the most unfavorable average monthly conditions, which is **January**.

Calculation of Exterior Conditions (for location: Albarracín):

1. **Temperature:** The outside temperature is taken from the provincial capital (Teruel) and adjusted for altitude.

- Teruel (915m): 3.8 °C
- Albarracín (1200m): 1.0 °C (adjusted down by ~1°C per 100m altitude difference).

2. **Vapor Pressure (P_e):** This is more complex, as relative humidity changes with temperature.

- Calculate Saturation Pressure (P_{sat}) for Teruel at 3.8°C using the **Magnus formula**: $P_{sat} = 610.5 \cdot \exp\left(\frac{17.269 \cdot \theta_e}{237.3 + \theta_e}\right)$ $P_{sat} = 610.5 \cdot \exp\left(\frac{17.269 \cdot 3.8}{237.3 + 3.8}\right) = 801.48 \text{ Pa}$
- Calculate Actual Vapor Pressure (P_e) for Teruel: $P_e = HR_e \cdot P_{sat} = 0.72 \cdot 801.48 \text{ Pa} = 577.06 \text{ Pa}$
- Crucial Assumption:** The absolute humidity (vapor pressure) is the same in Albarracín. Calculate Saturation Pressure for Albarracín at 1.0°C: $P_{sat.loc} = 610.5 \cdot \exp\left(\frac{17.269 \cdot 1.0}{237.3 + 1.0}\right) = 656.38 \text{ Pa}$
- Calculate Relative Humidity for Albarracín: $HR_{e.loc} = P_e / P_{sat.loc} = 577.06 / 656.38 = 0.879$ (88%)

Interior Conditions: * **Temperature (θ_i):** 20 °C * **Relative Humidity (HR_i):** 55% (for a residential building with normal humidity production). * **Interior Vapor Pressure (P_i):** $P_i = HR_i \cdot P_{sat}(20^\circ\text{C}) = 0.55 \cdot 2337 \text{ Pa} = 1285.35 \text{ Pa}$ (Note: 2337 Pa is the saturation pressure at 20°C).

6.3.3 Step 3: Temperature Distribution Calculation

The temperature at each interface between layers is calculated proportionally to the thermal resistance.

Formula: $\theta_x = \theta_e + ((R_{se} + \Sigma R) / R_T) * (\theta_i - \theta_e)$

Where: * θ_x = Temperature at a specific point [°C] * ΣR = Sum of resistances from the exterior up to that point [m²·K/W]
 * R_T = Total thermal resistance of the wall (4.59 m²·K/W)

Resulting Temperature Distribution:

Point	Exterior	Surf. Ext.	Capa 1	Capa 2	Capa 3	Capa 4	Capa 5	Capa 6	Capa 7	Surf. Int.	Interior
Temp. (°C)	1.00	1.12	1.34	16.63	18.13	18.20	18.95	19.20	19.45	19.99	20.00

6.3.4 Step 4: Vapor Pressure Distribution Calculation

The vapor pressure at each interface is calculated proportionally to the vapor resistance (Sd).

Formula (Conceptual): $P_x = P_e + ((\Sigma Sd) / Sd_{Total}) * (P_i - P_e)$

Where: * P_x = Vapor pressure at a specific point [Pa] * ΣSd = Sum of Sd values from the exterior up to that point [m]
 * Sd_{Total} = Total vapor resistance of the wall (5.77 m)

6.3.5 Step 5: Compliance Check - The Graphical Method

The final and most critical step is to compare the **Saturation Vapor Pressure (P_{sat})** and the **Actual Vapor Pressure (P)** at every point in the wall.

- **Saturation Pressure Line:** Calculated from the temperature distribution (Step 3) using the Magnus formula. This line represents the *maximum* amount of vapor the air can hold at each temperature.
- **Vapor Pressure Line:** Calculated from the vapor diffusion (Step 4). This line represents the *actual* amount of vapor present.

Compliance Criterion: > “If any of the vapor pressure values reaches or exceeds the saturation vapor pressure at that point, condensation will occur.”

Result for the Example Wall: The document presents a graph showing that the two lines (**P_{sat}** and **P**) **do not intersect** at any point through the wall’s cross-section.

Conclusion: “For the established exterior (January) and interior conditions, **no interstitial condensation** occurs in any of the layers that form the analyzed enclosure.”

6.4

Summary

The document demonstrates a complete, code-compliant check for interstitial condensation: 1. **Defines** the wall’s thermal and hygric properties. 2. **Establishes** the worst-case realistic interior and exterior environmental conditions. 3. **Calculates** the temperature and vapor pressure profile through the wall. 4. **Verifies** that the vapor pressure remains below the saturation pressure everywhere, thus proving no risk of harmful interstitial condensation for the analyzed assembly.

7 Air Permeability of Openings (Permeabilidad al aire de los huecos)

The document addresses air tightness in two key areas: the individual components (windows/doors) and the entire building envelope.

This regulates the maximum allowed air leakage through windows, doors, and skylights under a standardized pressure test.

Standard: UNE-EN 12207:2017 **Test Condition:** Air permeability measured at a pressure differential of **100 Pa**, denoted as Q_{100} . **Unit:** $\text{m}^3/(\text{h}\cdot\text{m}^2)$ - (cubic meters per hour, per square meter of opening)

7.1 Compliance Table

The following table is used to verify that the proposed window and door classes meet the regulatory limits for the winter climate zone "E".

Component Type	Orientation / Location	Permeability Class	Q_{100} Value ($\text{m}^3/\text{h}\cdot\text{m}^2$)	Limit ($Q_{100,\text{lim}}$) ($\text{m}^3/\text{h}\cdot\text{m}^2$)	Compliance
Windows	North & East Facades	Class 3	9	≤ 9	COMPLIES
Windows	South & West Facades	Class 3	9	≤ 9	COMPLIES
Access Door	West Facade	(Wood, no class given)	(Not specified)	$\leq 9^*$	COMPLIES *
Skylights (Lucernarios)	Roof	Class 3	9	≤ 9	COMPLIES

*The door's specific permeability is not given, but it is stated to comply.

Key Requirement: For climate zone E, the permeability of all openings in the thermal envelope must not exceed **9 $\text{m}^3/(\text{h}\cdot\text{m}^2)$** . All proposed components with a Class 3 rating meet this requirement.

7.2 Building Envelope Air Tightness (Relación del cambio de aire n_{10})

This is a whole-building test that measures the air tightness of the entire thermal envelope, including leaks through walls, junctions, and installation gaps, not just the windows.

Standard: UNE-EN 13829:2002 (Fan Pressurization Test / Blower Door Test) **Test Condition:** Air changes per hour measured at a pressure differential of **50 Pa**, denoted as n_{50} . **Unit:** h^{-1} (air changes per hour)

7.2.1 Regulatory Limit

The permissible n_{50} value depends on the building's compactness (V/A).

Table 3.1.3.b-HE1

Compactness (V/A) [m^3/m^2]	n_{50} Limit [h^{-1}]
$V/A \leq 2.0$	6.00
$V/A \geq 4.0$	3.00

For intermediate compactness values ($2 < V/A < 4$), the limit is obtained by linear interpolation.

Applicability: This requirement is only mandatory for new residential buildings with a **useful floor area greater than 120 m^2** .

7.2.2 Calculation of Permeability (n_{50})

The document provides a method for calculating the n_{50} value without performing a test, using reference values.

Formula: $n_{50} = 0.629 \times (C_{o} \times A_{o} + C_{h} \times A_{h}) / V$

Where: * n_{50} : The calculated air change rate at 50 Pa [h^{-1}]. * **0.629**: Conversion factor between permeability at 100 Pa (Q_{100}) and 50 Pa (n_{50}). * C_o : Airflow coefficient for the **opaque** part of the envelope at 100 Pa. For new buildings, this is **16 $\text{m}^3/(\text{h} \cdot \text{m}^2)$** . * A_o : Area of the **opaque** part of the thermal envelope [m^2]. * C_h : Airflow coefficient for the **openings** (windows, doors) at 100 Pa. This is equal to their Q_{100} value. For Class 3 components, this is **9 $\text{m}^3/(\text{h} \cdot \text{m}^2)$** . * A_h : Total area of the **openings** (windows, doors) in the thermal envelope [m^2]. * V : Internal air volume enclosed by the thermal envelope (Volumen de "aire interior") [m^3].

7.2.3 Application and Compliance in the Document

The document states that due to the small size of the building, the n_{50} requirement only applies to **Option 3**, which has a useful area of 128 m^2 ($>120 \text{ m}^2$).

- **For Options 1 & 2:** The useful area is less than 120 m^2 , so justifying the n_{50} value is **not mandatory**.
- **Compliance Strategy for Option 3:** The document mentions that achieving compliance for small, detached buildings can be challenging. For Option 3, compliance is achieved by specifying even tighter **Class 4 windows** ($Q_{100} \leq 3 \text{ m}^3/(\text{h} \cdot \text{m}^2)$) to compensate for the less favorable compactness.

"...this requirement only applies in option 3 ($> 120 \text{ m}^2$ useful) and compliance is achieved by improving the tightness of the openings by incorporating Class 4 carpentry, which guarantees less than $3 \text{ m}^3/\text{h} \cdot \text{m}^2$."

7.3 Summary of Air Tightness Data:

Aspect	Requirement / Value	Notes
Openings (Q_{100})	Limit: $\leq 9 \text{ m}^3/(\text{h} \cdot \text{m}^2)$	For climate zone E.
Openings Class	Class 3	Standard proposed for most options.
Openings for Compliance	Class 4	Proposed for Option 3 to meet n_{50} .
Building (n_{50})	Limit: Function of Compactness	See table above.
n_{50} Applicability	Only for $> 120 \text{ m}^2$ useful area	Only mandatory for Option 3.
Calculation Method	$n_{50} = 0.629 \times (16 \cdot A_o + 9 \cdot A_h) / V$	For a standard case with Class 3 windows.
Opaque Coefficient (C_o)	16 $\text{m}^3/(\text{h} \cdot \text{m}^2)$	For new buildings.

In conclusion, the document demonstrates a two-tiered approach to air tightness: ensuring all individual components meet a minimum standard (Class 3), and for larger buildings, using higher-performance components (Class 4) to ensure the whole-building envelope meets the more stringent n₅₀ requirement.

8 Key Solar Energy Properties of Buildings

I can't directly access or read files from external links, including those in your Adobe Cloud. This is a security measure to protect your privacy and data.

However, I can be extremely helpful in two ways:

1. **If you have the text from the PDF**, you can copy and paste it here, and I can summarize, analyze, or answer specific questions about its content regarding the solar energy properties of buildings.
2. **I can provide a comprehensive overview of the key “solar energy properties of buildings” right now.** This might even help you know what to look for in your document.

Here is a summary of the critical solar energy properties of buildings:

The goal is to maximize beneficial solar gain (for heating and daylighting) while minimizing unwanted gain (that causes overheating).

8.0.0.1 1. Solar Orientation (Building Placement)

- **Southern Exposure (in the Northern Hemisphere):** The most critical factor. The south-facing side receives the most sunlight throughout the day and year.
- **Building Long Axis:** Ideally, the building's long axis should run east-west to maximize the area of the south-facing wall and roof for solar collection.

8.0.0.2 2. Building Envelope & Thermal Mass

- **Thermal Mass:** Materials like concrete, brick, stone, or tile that can absorb, store, and slowly release solar heat. They help stabilize indoor temperatures, keeping buildings warmer at night and cooler during the day.
- **Insulation:** High-quality insulation in walls, roofs, and floors is essential to retain the heat gained from the sun and prevent heat loss.
- **Airtightness:** Minimizing drafts and leaks ensures that the collected solar heat isn't lost through unintentional ventilation.

8.0.0.3 3. Windows and Glazing

- **Window-to-Wall Ratio (WWR):** The percentage of a wall that is glazed. South-facing windows should have a higher WWR than north-facing ones.
- **High-Performance Glazing:**
 - **Low-Emissivity (Low-E) Coatings:** Allow visible light and short-wave solar radiation to enter but reflect long-wave infrared heat radiation, trapping heat inside.
 - **Double or Triple Glazing:** The air or gas (e.g., argon) filled between panes acts as an excellent insulator.
 - **Solar Heat Gain Coefficient (SHGC):** Measures how well a window blocks heat from sunlight. A higher SHGC (e.g., 0.5-0.7) is desirable for south-facing windows in cold climates to collect heat. A lower SHGC (e.g., 0.25-0.4) is better for hot climates or east/west windows to prevent overheating.

8.0.0.4 4. Passive Solar Design Strategies

- **Direct Gain:** Sunlight enters through south-facing windows and directly heats the living space and thermal mass inside (e.g., a concrete floor).
- **Indirect Gain:** A thermal mass (like a “Trombe Wall”) is placed between the sun and the living space. The wall absorbs heat and slowly radiates it into the interior hours later.
- **Isolated Gain:** A solar collection system, like a sunspace (sunroom or greenhouse), is separate from the main living area. It collects heat that can be vented into the main building.

8.0.0.5 5. Shading and Overhangs

- **Fixed Overhangs:** Properly designed overhangs above south-facing windows can block high summer sun while allowing lower winter sun to enter and provide heat.
- **Operable Shading:** Devices like awnings, blinds, and shutters are crucial for managing solar gain on east and west facades, where the sun is low and harder to shade with fixed overhangs.

8.0.0.6 6. Active Solar Integration

- **Building-Integrated Photovoltaics (BIPV):** Solar panels are incorporated into the building envelope itself, serving as the roofing material, facades, or skylights, generating electricity.
- **Solar Thermal Collectors:** Panels that use the sun’s energy to heat water or air for domestic use or space heating.

8.0.0.7 7. Site and Landscape

- **Landscaping:** Deciduous trees planted on the south side provide shade in the summer and allow sunlight through in the winter after they lose their leaves.
- **Terrain:** The slope of the land can significantly affect solar access.

To get help with your specific PDF, please copy and paste the relevant text. I’m ready to help you analyze it!