


NOTE:


1. CONTRACTOR SHALL TV INSPECT SS W/O VENT BY DEPLOYING CAMERA FROM WITH THE MAIN SEWER. VERIFY NO ACTIVE CONNECTION, THEN LINE (E) 10" ISP SEWER W/ CIPL. NOTIFY CITY REPRESENTATIVE OF ANY DISCREPANCIES.



ELEVATION DATUM	SEWER SIZED BY D.R.
CITY	APPROVED BY N.B.



REFERENCE INFORMATION
& FILE NO. OF SURVEYS
A-13415
EX-4251



CITY AND COUNTY OF SAN FRANCISCO
SAN FRANCISCO PUBLIC WORKS
BUREAU OF ENGINEERING

DESIGNED BY LESLEY WONG DATE 04/2021	CHECKED BY FERNANDO CISNEROS DATE 04/2021	APPROVED BY J. J. MUTH DATE 04/2021
DESIGNED BY LESLEY WONG DATE 04/2021	CHECKED BY FERNANDO CISNEROS DATE 04/2021	APPROVED BY J. J. MUTH DATE 04/2021

CONTRACT NO. 10035252		
CITY AND COUNTY OF SAN FRANCISCO PUBLIC UTILITIES COMMISSION INFRASTRUCTURE DIVISION ENGINEERING MANAGEMENT BUREAU		
VARIOUS LOCATIONS PAVEMENT RENOVATION NO. 52 AND SEWER REPLACEMENT		
LUNDY'S LANE AND MONTESUMA STREET SEWER REPLACEMENT - END TO MATCHLINE "B" PLAN AND PROFILE		
DIRECTOR / APPROVED	DRAWN	SCALE AS SHOWN
DESIGN MANAGER	DESIGNED	DATE
APPROVED	APPROVED	
MANAGER, ENGINEERING MANAGEMENT BUREAU	ASSISTANT GENERAL MANAGER WASTE WATER DIVISION	
SHEET 52 OF 70	PLAN NO. SW-7	DRAWING FILE NO. 118,964
REVISIONS		REVISION NO. 0

HYD PROJECT NO. 11951