

Report of Calibration
PSC 4CH-MSS-BTA-Q12-Q8-Q7-Q11_ S/N 0008
2026-01-20 16:00:08

Calibration Current standard: BNL PSC ATE S/N 001
Calibration Volt standard: HP 3458A-002 S/N 2823A 23647
Calibration Res. standard: Fluke 742A-1 S/N 1063008
End Header

lab{2}:Chan1
Burden resistor = 8.0000

Measuring initial gains and offsets

Itest	dacSP	dcct1	dcct2	dacRB	err
-0.449617	0.491000	-0.588811	-0.583523	0.462058	-0.018106
-0.683027	217.500458	-0.820514	-0.815306	218.161850	9.999390

	dacSP	dcct1	dcct2	dacRB
Initial measured offsets:	417.531806	-0.142484	-0.137043	0.000000
Initial measured gains:	929.731835	0.992683	0.993025	1.003181
Gain corrections:	929.731835	1.007371	1.007024	1.000000

Writing gain and offset corrections for dacSP, dcct1, and dcct2 to PSC

Measuring DAC readback gain and offset

DAC SP	DAC RB
1.000000	0.462058
225.000000	218.161850

Measured offset: -0.030504
Measured gain: 1.003181
Gain correction: 0.996829

Writing gain and offset constants for dacRB to PSC

Itest	dacSP	dcct1	dcct2	dacRB	err
-0.449528	8.500000	-0.451413	-0.451836	-250.000000	-10.000000
-0.683325	232.500000	-0.685366	-0.685572	-250.000000	-10.000000
Itest	dacSP	dcct1	dcct2	dacRB	err
-0.449744	8.500000	-0.451653	-0.452110	-250.000000	-10.000000
-0.683045	232.500000	-0.684978	-0.685697	-250.000000	-10.000000
Itest	dacSP	dcct1	dcct2	dacRB	err
-0.001224	7.250000	250.042969	250.026672	-250.000000	0.084216
-0.000976	224.998456	250.041290	250.026703	-250.000000	0.016969
Itest	dacSP	dcct1	dcct2	dacRB	err
-0.001440	0.999247	250.040558	250.026672	-250.000000	0.011511
-0.001022	224.999432	250.040741	250.026672	-250.000000	0.006155
Itest	dacSP	dcct1	dcct2	dacRB	err
-0.001146	0.999834	250.040253	250.026657	-250.000000	0.006305
-0.001117	224.999664	250.040314	250.026840	-250.000000	0.005579