

# External Interface Board Test Results for EIB S/N: 0077

**Overall Test Status: Passed!**

Technician: David Toner, Life #: 26565

Test performed: 04/13/25, 09:09 AM

## PSC I/O and MPS 5069 PLC I/O Test Results

**Visual LED Status Test: Passed!**

I/O Port	Voltage	Pass/Fail
OUT1-PSC OFF	5.049 V	Pass
OUT1-PSC ON	0.032 V	Pass
OUT2-PSC OFF	5.07 V	Pass
OUT2-PSC ON	0.033 V	Pass
OUT3-PSC OFF	5.06 V	Pass
OUT3-PSC ON	0.033 V	Pass
OUT4-PSC OFF	5.089 V	Pass
OUT4-PSC ON	0.034 V	Pass
IN1-PSC OFF	-0.0 V	Pass
IN1-PSC ON	19.815 V	Pass
IN2-PSC OFF	0.0 V	Pass
IN2-PSC ON	19.98 V	Pass
IN3-PSC OFF	-0.0 V	Pass
IN3-PSC ON	19.79 V	Pass
IN4-PSC OFF	-0.0 V	Pass
IN4-PSC ON	19.675 V	Pass
24V_PS	24.235 V	Pass