

External Interface Board Test Results for EIB S/N: 0025

Overall Test Status: Passed!

Technician: Kevin Mandracchia, Life #: 25337

Test performed: 04/12/25, 10:25 AM

PSC I/O and MPS 5069 PLC I/O Test Results

Visual LED Status Test: Passed!

| I/O Port | Voltage | Pass/Fail |
|--------------|----------|-----------|
| OUT1-PSC OFF | 5.06 V | Pass |
| OUT1-PSC ON | 0.032 V | Pass |
| OUT2-PSC OFF | 5.057 V | Pass |
| OUT2-PSC ON | 0.032 V | Pass |
| OUT3-PSC OFF | 5.104 V | Pass |
| OUT3-PSC ON | 0.033 V | Pass |
| OUT4-PSC OFF | 5.051 V | Pass |
| OUT4-PSC ON | 0.033 V | Pass |
| IN1-PSC OFF | -0.0 V | Pass |
| IN1-PSC ON | 19.928 V | Pass |
| IN2-PSC OFF | -0.0 V | Pass |
| IN2-PSC ON | 19.785 V | Pass |
| IN3-PSC OFF | -0.0 V | Pass |
| IN3-PSC ON | 19.851 V | Pass |
| IN4-PSC OFF | 0.0 V | Pass |
| IN4-PSC ON | 19.92 V | Pass |
| 24V_PS | 24.236 V | Pass |