

# External Interface Board Test Results for EIB S/N: 0070

**Overall Test Status: Passed!**

Technician: David Toner, Life #: 26565

Test performed: 04/13/25, 08:28 AM

## PSC I/O and MPS 5069 PLC I/O Test Results

**Visual LED Status Test: Passed!**

I/O Port	Voltage	Pass/Fail
OUT1-PSC OFF	5.095 V	Pass
OUT1-PSC ON	0.033 V	Pass
OUT2-PSC OFF	5.112 V	Pass
OUT2-PSC ON	0.033 V	Pass
OUT3-PSC OFF	5.048 V	Pass
OUT3-PSC ON	0.033 V	Pass
OUT4-PSC OFF	5.031 V	Pass
OUT4-PSC ON	0.032 V	Pass
IN1-PSC OFF	-0.0 V	Pass
IN1-PSC ON	19.829 V	Pass
IN2-PSC OFF	-0.0 V	Pass
IN2-PSC ON	19.742 V	Pass
IN3-PSC OFF	-0.0 V	Pass
IN3-PSC ON	19.967 V	Pass
IN4-PSC OFF	-0.0 V	Pass
IN4-PSC ON	19.96 V	Pass
24V_PS	24.235 V	Pass