

External Interface Board Test Results for EIB S/N: 0003

Overall Test Status: Failed!

Technician: Kevin Mandracchia, Life #: 25337

Test performed: 04/12/25, 07:13 AM

PSC I/O and MPS 5069 PLC I/O Test Results

Visual LED Status Test: Failed!

I/O Port	Voltage	Pass/Fail
OUT1-PSC OFF	-0.001 V	Fail
OUT1-PSC ON	-0.001 V	Pass
OUT2-PSC OFF	0.0 V	Fail
OUT2-PSC ON	-0.0 V	Pass
OUT3-PSC OFF	-0.0 V	Fail
OUT3-PSC ON	-0.0 V	Pass
OUT4-PSC OFF	-0.001 V	Fail
OUT4-PSC ON	-0.0 V	Pass
IN1-PSC OFF	-0.0 V	Pass
IN1-PSC ON	-0.0 V	Fail
IN2-PSC OFF	-0.0 V	Pass
IN2-PSC ON	0.0 V	Fail
IN3-PSC OFF	-0.0 V	Pass
IN3-PSC ON	-0.001 V	Fail
IN4-PSC OFF	-0.0 V	Pass
IN4-PSC ON	-0.0 V	Fail
24V_PS	-0.0 V	Fail