

# External Interface Board Test Results for EIB S/N: 0007

**Overall Test Status: Passed!**

**Technician: Kevin Mandracchia, Life #: 25337**

**Test performed: 04/12/25, 07:32 AM**

## PSC I/O and MPS 5069 PLC I/O Test Results

**Visual LED Status Test: Passed!**

I/O Port	Voltage	Pass/Fail
OUT1-PSC OFF	5.114 V	Pass
OUT1-PSC ON	0.032 V	Pass
OUT2-PSC OFF	5.077 V	Pass
OUT2-PSC ON	0.033 V	Pass
OUT3-PSC OFF	5.098 V	Pass
OUT3-PSC ON	0.034 V	Pass
OUT4-PSC OFF	5.037 V	Pass
OUT4-PSC ON	0.033 V	Pass
IN1-PSC OFF	-0.0 V	Pass
IN1-PSC ON	19.985 V	Pass
IN2-PSC OFF	-0.0 V	Pass
IN2-PSC ON	19.849 V	Pass
IN3-PSC OFF	-0.0 V	Pass
IN3-PSC ON	20.017 V	Pass
IN4-PSC OFF	-0.0 V	Pass
IN4-PSC ON	19.879 V	Pass
24V_PS	24.235 V	Pass